

Victorian Transfer Limit Advice – Outages

March 2022

For the National Electricity Market

Important notice

PURPOSE

AEMO has prepared this document to provide information about voltage and transient stability limits for flows to and from Victoria, as at the date of publication.

DISCLAIMER

This document or the information in it may be subsequently updated or amended. This document does not constitute legal or business advice, and should not be relied on as a substitute for obtaining detailed advice about the National Electricity Law, the National Electricity Rules, or any other applicable laws, procedures or policies. AEMO has made every effort to ensure the quality of the information in this document but cannot guarantee its accuracy or completeness.

Accordingly, to the maximum extent permitted by law, AEMO and its officers, employees and consultants involved in the preparation of this document:

- make no representation or warranty, express or implied, as to the currency, accuracy, reliability or completeness of the information in this document; and
- are not liable (whether by reason of negligence or otherwise) for any statements or representations in this document, or any omissions from it, or for any use or reliance on the information in it.

VERSION CONTROL

| Version | Release date | Changes |
|---------|------------------|--|
| 41 | 28 March 2022 | Update system strength combo for outage of Moorabool – Sydenham 500 kV line. Update Voltage Oscillation Limit and Murraylink voltage stability limit for outage of Bendigo – Shepparton 220 kV line |
| 40 | 04 March 2022 | Update voltage stability import limits for outage of Dederang to South Morang 330 kV line for the trip of the largest generator in Victoria or Basslink or the trip of the remaining line, and update of voltage stability export limit for the trip of APD. |
| 39 | 15 January 2022 | Update system strength combo for outage of Moorabool – Sydenham 500 kV line and Hazelwood – Loy Yang 500kV line. Updated Kerang voltage collapse limit for Murraylink outage. Updated NSW to VIC voltage stability limits for Murraylink outage |
| 38 | 01 October 2021 | Updated voltage oscillation limits for the outage of Horsham SVC |
| 37 | 23 June 2021 | Updated Murraylink voltage stability limits for Bendigo - Kerang 220 kV lines outage. New voltage oscillation limits for the outage of Ballarat – Bendigo 220 kV line. |
| 36 | 31 May 2021 | Updated Murraylink voltage stability limits for Ararat – Waubra – Ballarat, Ararat – Waubra, Ballarat to Waubra 220 kV lines outages. |
| 35 | 20 May 2021 | Updated voltage oscillation limits and update to offsets to Vic to NSW voltage stability export and import limits for Buronga-Red Cliffs 220 kV lines outages. |
| 34 | 07 April 2021 | Updated voltage oscillation limits for Red Cliffs-Wemen-Kerang 220 kV lines outages |
| 33 | 22 March 2021 | Updated voltage oscillation limits for Kiamal to Red Cliffs outage |
| 32 | 25 February 2021 | Added system strength requirement for outage of Hazelwood – Loy Yang 500 kV line and Moorabool – Sydenham 500 kV line |
| 31 | 19 February 2021 | New voltage oscillation limits for outage of Moorabool – Sydenham 500 kV line |
| 30 | 5 February 2021 | Updated Murraylink voltage stability limits for Ararat – Waubra – Ballarat, Ararat – Waubra, Ballarat to Waubra 220 kV lines outages. Updated table of Parameter Definitions |
| 29 | 19 January 2021 | Updated voltage oscillation limits for Ararat – Waubra – Ballarat, Ararat – Waubra, Ballarat to Waubra and Ararat - Crowlands 220 kV lines outages. Merge outage section of Ararat to Waubra 220 kV line and Ballarat to Waubra 220 kV line into outage section of Ararat to Waubra to Ballarat 220 kV line. |
| 28 | 9 December 2020 | Updated voltage oscillation limits for Bulgana WF, Bulgana battery and Gannawarra battery for the Bendigo to Kerang outage. |
| 27 | 24 November 2020 | Updated voltage oscillation limits for Horsham and Kerang SVC outages. |
| 26 | 2 November 2020 | Moved outages in NSW and SA to new limits advice doc, added voltage oscillation and islanding limits for Bendigo to Kerang outage |
| 25 | 15 October 2020 | Updates to X3, X5, Wodonga-Dederang, Wodonga-Jindera, Jindera-Wagga, and Wagga-Darlington Point prior outage voltage oscillation limits. Updated Victorian export voltage stability limit from Victoria to NSW for loss of both APD Potlines, offsets for NSW prior outages |
| 24 | 1 September 2020 | Updates to voltage unbalance equations for Alcoa Portland to Heywood to Mortlake, Alcoa Portland to Heywood, Moorabool to Haunted Gully and Haunted Gully to Tarrone outages. Added voltage unbalance limits for Moorabool to Mortlake outage. Updated Kiamal limits for Ararat to Waubra to Ballarat and Horsham to Murra Warra to Kiamal. Changed all inverter limit text from “on-line” to “connected”. |

| Version | Release date | Changes |
|---------|-------------------|--|
| | | Added notes on all TransGrid line outages to indicate TransGrid provide outage advice for these. |
| 23 | 21 August 2020 | Updates to the Kerang to Wemen to Red Cliffs outage limits |
| 22 | 31 July 2020 | Updates to voltage oscillation and islanding limits for Kiamal to Red Cliffs and Horsham to Murra Warra to Kiamal outages |
| 21 | 1 May 2020 | Removed the references to the system normal output and inverter limits of Broken Hill, Bannerton, Gannawarra, Karadoc and Wemen solar farms. Corrected minor typos. |
| 20 | 20 April 2020 | Added Ballarat – Bendigo voltage oscillation limits for the condition Bulgana WF is constrained to 5 MW |
| 19 | 8 January 2020 | Added Buronga – Red Cliffs (OX1) voltage oscillation limits. Added information on when Balranald to Darlington Point (X5) is switched out with other line outages |
| 18 | 8 November 2019 | Added new limits for Horsham SVC outage. |
| 17 | 4 October 2019 | Added new limits for Kerang SVC outage, updated voltage oscillation limits for 220 kV outages between Horsham and Red Cliffs, updated islanding limits for wind farms for north-west Vic outages |
| 16 | 13 September 2019 | Added voltage oscillation limits for Buronga – Darlington Point (X5 and X3), Buronga – Red Cliffs (OX1) and Bendigo – Kerang outages, updated limits for Ararat – Waubra – Ballarat. Added limits for solar farms for north-west Vic outages. |
| 15 | 9 August 2019 | Added voltage oscillation limits for Bulgana to Crowlands line, updated information on operating Horsham SVC for north-west Vic outages. Updated Murra Warra limits for Crowlands to Bulgana to Horsham, Horsham to Murra Warra and Kerang to Wemen to Red Cliffs outages. Change inverters to maximum on-line instead of off. Removed voltage unbalance limits for APD-Heywood-Tarrone outage with one Mortlake in service. Added notes to north-west Vic outages that are being reviewed for voltage oscillation limits. |
| 14 | 29 May 2019 | Added voltage oscillation limits for Kerang to Wemen to Red Cliffs lines and changed to have all these line outages into one section in the doc. Added Murraylink voltage collapse limits for outages of Bendigo to Kerang, Ararat to Waubra and Ararat to Waubra to Ballarat lines. |
| 13 | 14 May 2019 | Added voltage oscillation limits for Horsham to Murra Warra line and Red Cliffs to Wemen lines. |
| 12 | 1 May 2019 | Added islanding limits for Ararat to Crowlands, Ararat to Waubra and Crowlands to Bulgana to Horsham outages. Further clean-up of section titles. Updated voltage oscillation limits for Bulgana to Horsham outage. |
| 11 | 5/4/2019 | Updated Murraylink limit for Ballarat to Waubra outage. |
| 10 | 2/4/2019 | Updated voltage oscillation limits for Ballarat to Waubra outage. Changed some section titles. |
| 9 | 20/3/2019 | Updated voltage oscillation limits for Horsham to Red Cliffs, editing and formatting fixes |
| 8 | 15/2/2019 | Added voltage oscillation limits for Ballarat to Waubra, Horsham to Red Cliffs, Kerang to Wemen to Red Cliffs and Crowlands to Horsham outages |
| 7 | 23/11/2018 | Updated Voltage stability limit equations, additional prior outage offsets and application of new template |
| 6 | 23/07/2018 | Updated Voltage stability limit equations |
| 5 | 01/08/2017 | Updated for Heywood Upgrade post series caps (system normal). Full document review. Updated to new AEMO template. Split multiple outages into separate document. Added voltage unbalance limits. |
| 4 | 31/03/2015 | Added further Victorian import and export limit equations |

| Version | Release date | Changes |
|---------|--------------|---|
| 3 | 21/08/2014 | Added Victorian import limit equations and updated to new AEMO template |
| 2 | 14/11/2013 | Updated initial equations, with term for Mount Mercer Wind Farm (MMWF) MW output, added additional prior outage equations |
| 1 | 12/03/2012 | Initial version |

Contents

| | | |
|-----------|--|-----------|
| 1. | Introduction | 13 |
| 1.1 | Other AEMO publications | 13 |
| 1.2 | Calculating transient and voltage stability limits | 13 |
| 1.3 | Calculating voltage unbalance limits | 13 |
| 1.4 | Calculating voltage oscillation limits | 14 |
| 1.5 | Conversion to Constraint Equations | 15 |
| 2. | Alcoa Portland to Heywood to Mortlake 500 kV line | 16 |
| 2.1 | Transient Stability – Vic to NSW | 16 |
| 2.2 | Voltage Unbalance | 16 |
| 3. | Alcoa Portland to Heywood 500 kV line | 17 |
| 3.1 | Voltage Unbalance | 17 |
| 4. | Alcoa Portland to Heywood to Tarrone 500 kV line | 18 |
| 4.1 | Transient Stability – Vic to NSW | 18 |
| 4.2 | Voltage Unbalance | 18 |
| 5. | Ararat to Crowlands 220 kV line | 19 |
| 5.1 | Transient Stability – Vic to NSW | 19 |
| 5.2 | Islanding | 19 |
| 5.3 | Voltage Oscillation | 19 |
| 6. | Ararat to Waubra to Ballarat 220 kV line | 21 |
| 6.1 | Transient Stability – Vic to NSW | 21 |
| 6.2 | Voltage Stability – Murraylink | 21 |
| 6.3 | Islanding | 22 |
| 6.4 | Voltage Oscillation | 22 |
| 7. | Ballarat to Bendigo 220 kV line | 24 |
| 7.1 | Transient Stability – Vic to NSW | 24 |
| 7.2 | Voltage Stability – Murraylink | 24 |
| 7.3 | Voltage Oscillation | 25 |
| 8. | Bendigo to Kerang 220 kV line | 27 |
| 8.1 | Transient Stability – Vic to NSW | 27 |
| 8.2 | Voltage Stability – Murraylink | 27 |
| 8.3 | Islanding | 28 |
| 8.4 | Voltage Oscillation | 28 |
| 9. | Bendigo to Shepparton 220 kV line | 30 |
| 9.1 | Voltage Stability – Murraylink | 30 |

| | | |
|------------|--|-----------|
| 9.2 | Voltage Oscillation | 30 |
| 10. | Buronga to Red Cliffs (OX1) 220 kV line | 32 |
| 10.1 | Voltage Oscillation | 32 |
| 10.2 | Voltage Stability – NSW to Vic | 32 |
| 10.3 | Voltage Stability – Vic to NSW | 33 |
| 11. | Cranbourne to Hazelwood 500 kV line | 34 |
| 11.1 | Transient stability – Vic to NSW | 34 |
| 12. | Crowlands to Bulgana to Horsham 220 kV line | 39 |
| 12.1 | Transient Stability – Vic to NSW | 39 |
| 12.2 | Islanding | 39 |
| 12.3 | Voltage Oscillation | 39 |
| 13. | Dederang to Mount Beauty 220 kV line | 41 |
| 13.1 | Transient Stability – Vic to NSW | 41 |
| 13.2 | Voltage Stability – NSW to Vic | 41 |
| 14. | Dederang to Murray 330 kV line | 42 |
| 14.1 | Transient Stability – Vic to NSW | 42 |
| 14.2 | Voltage Stability – NSW to Vic | 44 |
| 15. | Dederang to South Morang 330 kV line | 47 |
| 15.1 | Transient Stability – Vic to NSW | 47 |
| 15.2 | Voltage Stability – NSW to Vic | 49 |
| 15.3 | Voltage Stability – Vic to NSW | 50 |
| 16. | Dederang Substation No. 1 or No. 2 330 kV Bus | 51 |
| 16.1 | Voltage Stability – NSW to Vic | 51 |
| 17. | Dederang to Wodonga 330 kV line | 52 |
| 17.1 | Transient Stability – Vic to NSW | 52 |
| 17.2 | Voltage Stability – NSW to Vic | 52 |
| 17.3 | Voltage Oscillation | 53 |
| 18. | Eildon to Mount Beauty 220 kV line | 54 |
| 18.1 | Transient Stability – Vic to NSW | 54 |
| 18.2 | Voltage Stability – NSW to Vic | 54 |
| 19. | Eildon To Thomastown 220 kV line | 55 |
| 19.1 | Transient Stability – Vic to NSW | 55 |
| 19.2 | Voltage Stability – NSW to Vic | 56 |
| 20. | Hazelwood to Loy Yang 500 kV line | 57 |
| 20.1 | System Strength | 57 |

| | | |
|------------|---|-----------|
| 21. | Hazelwood To South Morang 500 kV line | 58 |
| 21.1 | Transient Stability – Vic to NSW | 58 |
| 22. | Heywood to South East 275 kV line | 63 |
| 22.1 | Transient Stability – Vic to NSW | 63 |
| 23. | Horsham SVC | 64 |
| 23.1 | Voltage Oscillation | 64 |
| 24. | Horsham to Murra Warra to Kiamal 220 kV line | 65 |
| 24.1 | Transient Stability – Vic to NSW | 65 |
| 24.2 | Voltage Stability – Murraylink | 65 |
| 24.3 | Islanding | 67 |
| 24.4 | Voltage Oscillation | 67 |
| 25. | Jindera to Wodonga (060) 330 kV line | 68 |
| 25.1 | Transient Stability – Vic to NSW | 68 |
| 25.2 | Voltage Stability – NSW to Vic | 68 |
| 25.3 | Voltage Oscillation | 69 |
| 26. | Keilor to Sydenham 500 kV line | 70 |
| 26.1 | Transient Stability – Vic to NSW | 70 |
| 27. | Kerang SVC | 71 |
| 27.1 | Voltage Oscillation | 71 |
| 28. | Kerang to Wemen to Red Cliffs 220 kV line | 72 |
| 28.1 | Transient Stability – Vic to NSW | 72 |
| 28.2 | Voltage Stability – Murraylink | 72 |
| 28.3 | Islanding | 73 |
| 28.4 | Voltage Oscillation | 73 |
| 29. | Kiamal to Red Cliffs 220 kV line | 75 |
| 29.1 | Transient Stability – Vic to NSW | 75 |
| 29.2 | Voltage Stability – Murraylink | 75 |
| 29.3 | Islanding | 77 |
| 29.4 | Voltage Oscillation | 77 |
| 30. | Moorabool to Mortlake 500 kV line | 78 |
| 30.1 | Transient Stability – Vic to NSW | 78 |
| 30.2 | Voltage Unbalance | 78 |
| 31. | Moorabool To Sydenham 500 kV line | 79 |
| 31.1 | Transient Stability – Vic to NSW | 79 |
| 31.2 | Voltage Stability – Vic to SA | 79 |
| 31.3 | Voltage Oscillation | 80 |

| | | |
|------------|---|-----------|
| 31.4 | System Strength | 80 |
| 32. | Moorabool to Haunted Gully or Haunted Gully to Tarrone 500 kV line | 82 |
| 32.1 | Transient Stability – Vic to NSW | 82 |
| 32.2 | Voltage Unbalance | 82 |
| 32.3 | Fault Levels | 82 |
| 33. | Moorabool A2 Transformer 500/220 kV | 83 |
| 33.1 | Transient Stability – Vic to NSW | 83 |
| 34. | Murraylink | 84 |
| 34.1 | Voltage Stability – Wemen to Kerang limit | 84 |
| 34.2 | Voltage Stability – NSW to Vic | 84 |
| 35. | Rowville to South Morang 500 kV line | 85 |
| 35.1 | Transient Stability – Vic to NSW | 85 |
| 36. | South Morang Series Capacitor | 86 |
| 36.1 | Transient Stability – Vic to NSW | 86 |
| 36.2 | Voltage Stability – NSW to Vic | 86 |
| 37. | South Morang Substation No. 2 330 kV bus | 87 |
| 37.1 | Transient Stability – Vic to NSW | 87 |
| 38. | South Morang F2 Transformer 500 / 330 kV | 88 |
| 38.1 | Transient Stability – Vic to NSW | 88 |
| 38.2 | Voltage Stability – NSW to Vic | 92 |
| 39. | South Morang H1 or H3 Transformer 330 / 220 kV | 93 |
| 39.1 | Voltage Stability – NSW to Vic | 93 |
| 40. | South Morang to Sydenham 500 kV line | 94 |
| 40.1 | Transient Stability – Vic to NSW | 94 |
| 41. | South Morang to Thomastown 220 kV line | 95 |
| 41.1 | Transient Stability – Vic to NSW | 95 |
| A1. | Measures and Definitions | 96 |
| | Units of Measure | 96 |
| | Parameter Definitions | 96 |
| | Glossary | 102 |

Tables

| | | |
|----------|---|----|
| Table 1 | V::N APD-HYTS-MOPS_V/Q/S/S_decel offsets | 16 |
| Table 2 | V::N APD-HYTS-TRTS_V/Q/S_decel offsets | 18 |
| Table 3 | V::N ARTS-HOTS_V/Q/S/S_decel offsets | 19 |
| Table 4 | V::N ARTS-WBTS-BATS_V/Q/S/S_decel offsets | 21 |
| Table 5 | V^S [MRLK] ARTS-WBTS-BATS | 22 |
| Table 6 | V::N BATS-BETS_V/Q/S/S_decel offsets | 24 |
| Table 7 | V^S [MRLK] BATS-BETS_X5 | 25 |
| Table 8 | V::N BETS-KGTS_V/Q/S/S_decel offsets | 27 |
| Table 9 | V^S [MRLK] BETS-KGTS | 28 |
| Table 10 | V^S [MRLK] BETS-SHTS_X5 | 30 |
| Table 11 | N^V MSS-UTSS_BLVG offsets | 33 |
| Table 12 | V^N_2xAPD offset | 33 |
| Table 13 | V::N CBTS-HWTS-V coefficients | 35 |
| Table 14 | V::N CBTS-HWTS-V coefficients | 36 |
| Table 15 | V::N CBTS-HWTS-S coefficients | 37 |
| Table 16 | V::N CBTS-HWTS-S_decel coefficients | 38 |
| Table 17 | V::N ARTS-HOTS_V/Q/S/S_decel offsets | 39 |
| Table 18 | V::N DDTS-MBTS_V/Q/S/S_decel offsets | 41 |
| Table 19 | V::N DDTS-MSS-V coefficients | 43 |
| Table 20 | V::N DDTS-MSS-S coefficients | 44 |
| Table 21 | V^N DDTS-MSS BLVG coefficients | 45 |
| Table 22 | V^N DDTS-MSS DDMS coefficients | 46 |
| Table 23 | V::N DDTS-SMTS-V coefficients | 48 |
| Table 24 | V::N DDTS-SMTS-S coefficients | 49 |
| Table 25 | NIL_VI_BLVG offset | 49 |
| Table 26 | NIL_VI_BLVG offset | 50 |
| Table 27 | V^N_2xAPD offset | 50 |
| Table 28 | V::N DDTS-WOTS_V/Q/S/S_decel offsets | 52 |
| Table 29 | - V^N DDTS-WOTS_BLVG offset | 52 |
| Table 30 | V::N EPS-MBTS_V/Q/S/S_decel offsets | 54 |
| Table 31 | V::N EPS-TTS -V coefficients | 55 |

| | |
|---|----|
| Table 32 V::N EPS-TTS-S coefficients | 56 |
| Table 33 Hazelwood – Loy Yang outage system strength minimum generator combinations | 57 |
| Table 34 V::N HWTS-SMTS-V coefficients | 59 |
| Table 35 V::N HWTS-SMTS-Q coefficients | 60 |
| Table 36 V::N HWTS-SMTS-S coefficients | 61 |
| Table 37 V::N HWTS-SMTS-S_decel coefficients | 62 |
| Table 38 V::N HYTS-SESS_V/Q/S/S_decel offsets | 63 |
| Table 39 V::N HOTS-RCTS_V/Q/S/S_decel offsets | 65 |
| Table 40 V^S [MRLK] HOTS-RCTS_X5 | 66 |
| Table 41 V^S [MRLK] HOTS-RCTS_BEKG | 66 |
| Table 42 V::N JIND-WOTS_V/Q/S/S_decel offsets | 68 |
| Table 43 V^N JIND-WOTS_BLVG offset | 68 |
| Table 44 V::N KTS-SYTS_V/Q/S/S_decel offsets | 70 |
| Table 45 V::N KTS-SYTS_V/Q/S/S_decel offsets | 72 |
| Table 46 V^S [MRLK] KGTS-WETS-RCTS | 73 |
| Table 47 V::N HOTS-RCTS_V/Q/S/S_decel offsets | 75 |
| Table 48 V^S [MRLK] HOTS-RCTS_X5 | 76 |
| Table 49 V^S [MRLK] HOTS-RCTS_BEKG | 76 |
| Table 50 V::N MLTS-MOPS_V/Q/S/S_decel offsets | 78 |
| Table 51 V::N MLTS-SYTS_V/Q/S/S_decel offsets | 79 |
| Table 52 V^S[HEY]_MLTS-SYTS coefficients | 80 |
| Table 53 Moorabool – Sydenham outage system strength minimum generator combinations | 81 |
| Table 54 V::N MLTS-TRTS_V/Q/S/S_decel offsets | 82 |
| Table 55 V::N MLTS-A2_V/Q/S/S_decel offsets | 83 |
| Table 56 V^V MRLK_KERANG offset | 84 |
| Table 57 V^N MRLK_BLVG offset | 84 |
| Table 58 V^N MRLK_ARWBBA offset | 84 |
| Table 59 V::N ROTS-SMTS _V/Q/S/S_decel offsets | 85 |
| Table 60 V::N SMTS-CAP_V/Q/S/S_decel offsets | 86 |
| Table 61 V::N SMTS-B2_V/Q/S/S_decel offsets (HWTS-SMTS 500 kV fault) | 87 |
| Table 62 V::N SMTS-B2_V/Q/S/S_decel offsets (SMTS-TTS 220 kV fault) | 87 |
| Table 63 V::N SMTS-F2_V coefficients | 89 |
| Table 64 V::N SMTS-F2_Q coefficients | 90 |
| Table 65 V::N SMTS-F2_S coefficients | 91 |
| Table 66 V::N SMTS-F2_S_decel coefficients | 92 |
| Table 67 V^N SMTS_F2_BLVG offsets | 92 |

| | |
|---|----|
| Table 68 V::N SMTS-SYTS_V/Q/S/S_decel offsets | 94 |
| Table 69 V::N SMTS-TTS_V/Q/S/S_decel offsets | 95 |

1. Introduction

AEMO is responsible for calculating the maximum transient and voltage stability limits into and out of Victoria, as well as voltage unbalance and voltage oscillation constraints to keep the system within specified limits, in accordance with the National Electricity Rules (NER) S5.1.2.3 and the Power System Stability Guidelines¹. This document describes the values for these transfer limits for single prior outage conditions in Victoria.

This limits advice document also describes the methodology used by AEMO to determine the transient and voltage stability limits, voltage unbalance limits and the voltage oscillation limits.

The limit equations for system normal cases are described in a separate document, *Victorian Transfer Limit Advice – System Normal*. Limit equations for outages in NSW and SA are described in *Victorian Transfer Limit Advice – Outages in Adjacent Regions* and multiple prior outages are described in *Victorian Transfer Limit Advice – Multiple Outages*. Both of these documents are available on the AEMO website².

1.1 Other AEMO publications

Other limit advice documents are located at: <https://www.aemo.com.au/energy-systems/electricity/national-electricity-market-nem/system-operations/congestion-information-resource/limits-advice>

1.2 Calculating transient and voltage stability limits

Transfer limit equations are developed for power transfers into and out of Victoria (known as import and export limits respectively). Maximum export is limited by transient stability, whereas maximum import is determined by voltage stability.

Transient stability limit equations are derived from a large number of transient stability studies. Stability studies are based on the application of a 2-phase to ground fault at the most critical fault location.

Voltage stability limit equations are derived from a large number of load flow studies. Studies consider the trip of a large generator, the loss of Basslink when exporting from Tasmania (Tas.) to Victoria (Vic.), and where appropriate the fault and trip of a critical transmission line or transformer.

1.2.1 Methodology

The methodology for calculating voltage and transient stability limits is given below:

1. Generate a set of Power System Simulator for Engineering (PSS/E) cases to represent a wide range of operating conditions.
2. Execute a binary search algorithm to search for limiting interconnector power transfer.
3. Linear regression and statistical limit determination.

1.3 Calculating voltage unbalance limits

Voltage unbalance is based on the levels of negative sequence voltage. As specified in S5.1a.1 of the NER, the negative sequence voltage needs to be limited to 0.5% of nominal voltage for busbars greater than 100 kV. With the introduction of generation in the southwest of Victoria, AEMO has determined that under specific

¹ AEMO, *Power System Stability Guidelines*, Available at: <http://www.aemo.com.au/Electricity/National-Electricity-Market-NEM/Security-and-reliability/Congestion-information>, Viewed on 31 August 2016.

² Available at: <https://www.aemo.com.au/energy-systems/electricity/national-electricity-market-nem/system-operations/congestion-information-resource/limits-advice>

outage conditions, the voltage unbalance at the Portland smelter (APD) 500 kV busbar can exceed these levels.

The limit equations are defined such that the simulated negative sequence voltage on the APD 500 kV bus does not exceed 0.4 % of nominal voltage³ for system normal and prior circuit outage conditions. This allows for a margin of 0.1%, which is considered a minimum requirement to account for the following:

- Other sources of unbalance, including effect of loads and generation that were not represented. The simulation results only represent unbalance associated with the transmission network.
- Sufficient measurements of voltage unbalance in the APD area that are not presently available to enable verification or calibration of the simulation model.

As well, the maximum simulated voltage unbalance at APD without the additional generation in the south west of Victoria is 0.4%.

The voltage unbalance levels at APD are influenced by a combination of:

- Voltage balancing effect (or reduction of negative sequence voltage) at Mortlake caused by the Mortlake generators.
- Power flow and associated negative sequence voltage across the Mortlake (MOPS) to Moorabool (MLTS), and Mortlake (MOPS) to Heywood (HYTS) to APD No. 2 500 kV lines (which are not fully transposed).
- Power flow on the Moorabool (MLTS) to Tarrone (TRTS) to Heywood (HYTS) to APD No. 1 500 kV line and mutual coupling with the MOPS-MLTS and MOPS-HYTS-APD No. 2 500 kV lines.

These factors can produce additive or counteractive effects on negative sequence voltage at APD, depending on the direction of power flow in the MOPS-MLTS and MOPS-HYTS-APD No. 2 500 kV lines and adjacent MLTS-TRTS-HYTS-APD No. 1 500 kV line.

1.3.1 Methodology

A number of voltage unbalance simulations were performed using a Power Systems Computer Aided Design (PSCAD) model of the 500 kV network. From these results, limit equations were produced to keep the level of voltage unbalance at APD at or below 0.4% during specific outages on the 500 kV network. These equations quantify the relationship between generation, Vic to SA transfer (via Heywood), and where relevant, APD load, such that the simulated voltage unbalance at APD will not exceed 0.4%.

It is assumed that the net APD load can vary between 405 MW to 615 MW, and Portland wind farm is capable of generating up to 100 MW.

1.4 Calculating voltage oscillation limits

Voltage oscillations and associated instability can occur in parts of the power system that have low system strength, especially during prior outage conditions. To mitigate such oscillations in Western Victoria power system, voltage oscillatory stability limits are determined for low system strength conditions including prior outage conditions. Simulations of large disturbances such as two-phase to ground fault and trip of critical lines are undertaken using PSCAD to determine if the voltage oscillations occur in the power system post-contingency.

Large disturbance simulations of several operating conditions are undertaken to determine the limiting operating conditions of the power system which prevent voltage oscillations from occurring.

1.4.1 Methodology

Voltage oscillation stability limits were determined by performing electromagnetic-transient simulations using PSCAD on a model of the north-west Victorian and south-west NSW networks. Several possible power system

³ Line to Line = 2 kV and Line to Neutral = 1.15 kV

scenarios including Murraylink power import and export conditions, wind farm and solar farm operating conditions, battery operating conditions and special protection schemes were considered in the simulations.

1.5 Conversion to Constraint Equations

This document does not describe how AEMO implements these limit equations as constraint equations in the National Electricity Market (NEM) market systems. That is covered in the Constraint Formulation Guidelines, Constraint Naming Guidelines and Constraint Implementation Guidelines. These documents are located in the Congestion Information Resource on the AEMO website:

<https://www.aemo.com.au/energy-systems/electricity/national-electricity-market-nem/system-operations/congestion-information-resource>

2. Alcoa Portland to Heywood to Mortlake 500 kV line

The following limit equations are enabled during an outage of the Alcoa Portland to Heywood to Mortlake 500 kV line and associated line reactor.

2.1 Transient Stability – Vic to NSW

To manage the Victorian transient stability export limit from Victoria to NSW for fault and trip of a Hazelwood to South Morang 500 kV line, apply the following prior outage offsets to system normal equations NILV, NILQ, NILS and NILS decelerating. The limit equation is of the form:

$$\text{Victoria to NSW} \leq \text{Sum [Term Values * System Normal Coefficients]} + \text{Offset}$$

Table 1 V::N APD-HYTS-MOPS_V/Q/S/S_decel offsets

| Term | Offset |
|---|--|
| Offset to system normal equation NILV | -30 |
| Offset to system normal equation NILQ | 0 |
| Offset to system normal equation NILS | -30 |
| Offset to system normal equation NILS_decel | N/A [VIC->SA transfer limited to 250 MW] |

2.2 Voltage Unbalance

The following limit equation should be applied to manage the voltage unbalance at APD 500kV and Heywood 275kV buses:

$$\text{Mortlake} + \text{Dundonnell generation} - 3.1488 \times \text{Macarthur generation} + 1.9538 \times \text{Vic to SA (Heywood)} \leq 324$$

3. Alcoa Portland to Heywood 500 kV line

The following limit only applies to the Alcoa Portland to Heywood No.1 500 kV line. No limits are applied to the No.2 line.

3.1 Voltage Unbalance

The following voltage unbalance limit should be applied to manage the voltage unbalance at APD 500kV and Heywood 275kV buses:

$$1.85 \times \text{APD Net Load} + \text{Mortlake} + \text{Dundonnell generation} \leq 1535$$

4. Alcoa Portland to Heywood to Tarrone 500 kV line

The following limit equations are enabled during an outage of the Alcoa Portland to Heywood to Tarrone 500 kV line.

4.1 Transient Stability – Vic to NSW

To manage the Victorian transient stability export limit from Victoria to NSW for fault and trip of Hazelwood to South Morang 500 kV line, apply the following prior outage offsets to system normal equations NILV, NILQ, NILS and NILS_decelerating. The limit equation is of the form:

$$\text{Victoria to NSW} \leq \text{Sum} [\text{Term Values} * \text{System Normal Coefficients}] + \text{Offset}$$

Table 2 V::N APD-HYTS-TRTS_V/Q/S_decel offsets

| Term | Offset |
|---|--|
| Offset to system normal equation NILV | -30 |
| Offset to system normal equation NILQ | 0 |
| Offset to system normal equation NILS | -30 |
| Offset to system normal equation NILS_decel | N/A [VIC->SA transfer limited to 250 MW] |

4.2 Voltage Unbalance

Note: for this outage, all three Heywood transformers remain on load.

For one Mortlake generator in service only:

No MW limit for a single unit in service. For two Mortlake generators in service:

These limits are under review based on measurements made during the outage with only a single Mortlake generator in service,

$$\text{Mortlake generation} + 0.353 \times \text{Vic. to SA (Heywood)} \leq 60 - 1.28 \times (\text{APD load} - \text{Portland WF} - 485)$$

Note: in actual outage conditions, it was revealed that the National Electricity Network Dispatch Engine (NEMDE) produced unfeasible market results with the above limit equations (such as exporting more generation from SA than was available with contingency frequency control ancillary services). As a result, the above limit equations have been replaced by constraining Mortlake generation to zero MW.

$$\text{Mortlake generation} = 0$$

5. Ararat to Crowlands 220 kV line

The following limit equations are enabled during an outage of the Ararat to Crowlands 220 kV line.

5.1 Transient Stability – Vic to NSW

To manage the Victorian transient stability export limit from Victoria to NSW for fault and trip of a Hazelwood to South Morang 500 kV line, apply the following prior outage offsets to system normal equations NILV, NILQ, NILS and NILS decelerating. The limit equation is of the form:

$$\text{Victoria to NSW} \leq \text{Sum} [\text{Term Values} * \text{System Normal Coefficients}] + \text{Offset}$$

Table 3 V::N ARTS-HOTS_V/Q/S/S_decel offsets

| Term | Offset |
|---|--------|
| Offset to system normal equation NILV | -80 |
| Offset to system normal equation NILQ | -40 |
| Offset to system normal equation NILS | -80 |
| Offset to system normal equation NILS_decel | -80 |

5.2 Islanding

Limitation to prevent islanding of local load following the trip of the Kiamal to Red Cliffs 220 kV line.

Bulgana wind farm ≤ 0 MW

Bulgana battery = 0 MW with all inverters disconnected

Crowlands wind farm ≤ 0 MW

Kiata wind farm ≤ 0 MW

Kiamal solar farm ≤ 0 MW with all inverters disconnected

Kiamal SynCon switched off

5.3 Voltage Oscillation

To prevent voltage oscillations for trip of a Bendigo to Kerang 220 kV line the following limits are applied:

Ararat wind farm ≤ 60 MW

Bannerton solar farm ≤ 20 MW

Broken Hill solar farm ≤ 25 MW

Coleambally Solar Farm ≤ 60 MW

Darlington Point Solar Farm ≤ 110 MW

Finley Solar Farm ≤ 55 MW

Gannawarra solar farm ≤ 15 MW

Karadoc solar farm ≤ 20 MW

Limondale 1 Solar Farm ≤ 85 MW

Limondale 2 Solar Farm ≤ 15 MW

Murra Warra wind farm ≤ 60 MW

Murraylink (SA to Vic) ≤ 150 MW

Murraylink (Vic to SA) ≤ 150 MW

Silverton wind farm ≤ 80 MW

Sunraysia Solar Farm ≤ 80 MW

Waubra wind farm switched off

Wemen solar farm ≤ 20 MW

Yatpool solar farm ≤ 20 MW

Horsham SVC switched off or set to manual mode with a fixed Q setpoint

6. Ararat to Waubra to Ballarat 220 kV line

The following limit equations are enabled during an outage of the Ararat to Waubra to Ballarat 220 kV line, or Ararat to Waubra 220 kV line or Ballarat to Waubra 220 kV line unless indicated.

6.1 Transient Stability – Vic to NSW

To manage the Victorian transient stability export limit from Victoria to NSW for fault and trip of a Hazelwood to South Morang 500 kV line, apply the following prior outage offsets to system normal equations NILV, NILQ, NILS and NILS decelerating. The limit equation is of the form:

$$\text{Victoria to NSW} \leq \text{Sum} [\text{Term Values} * \text{System Normal Coefficients}] + \text{Offset}$$

Table 4 V::N ARTS-WBTS-BATS_V/Q/S/S_decel offsets

| Term | Offset |
|---|--------|
| Offset to system normal equation NILV | -100 |
| Offset to system normal equation NILQ | 0 |
| Offset to system normal equation NILS | -100 |
| Offset to system normal equation NILS_decel | -100 |

6.2 Voltage Stability – Murraylink

To manage the Murraylink voltage stability export limit from Victoria to SA for fault and trip of the Bendigo to Kerang 220 kV line, apply the following prior outage limit equations. Studies assume the Red Cliffs Voltage source controller (VSC) is in voltage control mode with the Very Fast Runback (VFRB) scheme disabled. Studies monitored post-contingent voltages and reactive power margin in southern NSW and the Victorian state grid. The limit equation is of the form:

$$\text{Victoria to SA (Murraylink)} \leq \text{Sum} [\text{Term Values} * \text{Coefficients}]$$

Table 5 VAS [MRLK] ARTS-WBTS-BATS

| Term | Coefficient |
|-------------------------------|-------------|
| Intercept | 243 |
| RCTS-MLK_MVAR | -0.7445 |
| WETS Load | -2.126 |
| BETS Load | -0.7796 |
| DARL_PT_3WTX_MW | 0.253 |
| HOTS-66CAP | 1.565 |
| Confidence Level (95%) offset | -53.6 |

6.3 Islanding

Limitation to prevent islanding of local load following the trip of the Kiamal to Red Cliffs 220 kV line.

Ararat wind farm ≤ 0 MW

Bulgana wind farm ≤ 0 MW

Bulgana battery = 0 MW with all inverters disconnected

Crowlands wind farm ≤ 0 MW

Kiata wind farm ≤ 0 MW

Kiamal solar farm ≤ 0 MW with all inverters disconnected

Kiamal SynCon switched off

6.4 Voltage Oscillation

To prevent voltage oscillations for trip of a Bendigo to Kerang 220 kV line the following limits are applied:

Bannerton solar farm ≤ 20 MW

Broken Hill solar farm ≤ 25 MW

Coleambally Solar Farm ≤ 60 MW

Darlington Point Solar Farm ≤ 110 MW

Finley Solar Farm ≤ 55 MW

Gannawarra solar farm ≤ 15 MW

Karadoc solar farm ≤ 20 MW

Limondale 1 Solar Farm ≤ 85 MW

Limondale 2 Solar Farm ≤ 15 MW

Murra Warra wind farm ≤ 60 MW

Murraylink (SA to Vic) ≤ 150 MW

Murraylink (Vic to SA) ≤ 150 MW

Silverton wind farm ≤ 80 MW

Sunraysia Solar Farm ≤ 80 MW

Waubra wind farm switched off

Wemen solar farm ≤ 20 MW

Yatpool solar farm ≤ 20 MW

Horsham SVC switched off or set to manual mode with a fixed Q setpoint

7. Ballarat to Bendigo 220 kV line

The following limit equations are enabled during an outage of the Ballarat to Bendigo 220 kV line.

7.1 Transient Stability – Vic to NSW

To manage the Victorian transient stability export limit from Victoria to NSW for fault and trip of a Hazelwood to South Morang 500 kV line, apply the following prior outage offsets to system normal equations NILV, NILQ, NILS and NILS decelerating. The limit equation is of the form:

$$\text{Victoria to NSW} \leq \text{Sum} [\text{Term Values} * \text{System Normal Coefficients}] + \text{Offset}$$

Table 6 V::N BATS-BETS_V/Q/S/S_decel offsets

| Term | Offset |
|---|--------|
| Offset to system normal equation NILV | -60 |
| Offset to system normal equation NILQ | 0 |
| Offset to system normal equation NILS | -60 |
| Offset to system normal equation NILS_decel | -60 |

7.2 Voltage Stability – Murraylink

To manage the Murraylink voltage stability export limit from Victoria to SA for fault and trip of the Buronga to Balranald to Darlington point 220 kV line, apply the following prior outage limit equations. Studies assume the Red Cliffs Voltage source controller (VSC) is in voltage control mode with the Very Fast Runback (VFRB) scheme disabled. Studies monitored post-contingent voltages and reactive power margin in southern NSW and the Victorian state grid. The limit equation is of the form:

$$\text{Victoria to SA (Murraylink)} \leq \text{Sum} [\text{Term Values} * \text{Coefficients}]$$

Table 7 **VAS [MRLK] BATS-BETS_X5**

| Term | Coefficient |
|-------------------------------|-------------|
| Intercept | 497.4 |
| RCTS Load | -1.003 |
| KGTS Load | -2.599 |
| HOTS Load | -1.978 |
| BATS TX MW | -0.2051 |
| BKNH TX MW | -0.5091 |
| BHSS220 Load | -1.122 |
| HOTS SVC Out of Service | -14.20 |
| KGTS SVC Out of Service | -18.67 |
| VIC to NSW | 0.01021 |
| Confidence Level (95%) offset | -33 |

7.3 Voltage Oscillation

To prevent voltage oscillations for trip of Bendigo to Shepparton 220kV line the following limits applied:

Ararat wind farm ≤ 120 MW

Bannerton solar farm ≤ 25 MW

Bulgana wind farm ≤ 50 MW

Broken Hill solar farm ≤ 25 MW

Coleambally solar farm ≤ 40 MW

Crowland wind farm ≤ 40 MW

Darlington Point solar farm ≤ 60 MW

Finley solar farm ≤ 40 MW

Ganawarra solar farm ≤ 25 MW

Karadoc solar farm ≤ 25 MW

Kiamal solar farm ≤ 50 MW

Limondale 1 solar farm ≤ 50 MW

Limondale 2 solar farm ≤ 10 MW

Murra Warra wind farm ≤ 60 MW

Murraylink (Vic to SA) ≤ 150 MW

Murraylink (SA to Vic) ≤ 150 MW

Silverton WF ≤ 50

Sunraysia solar farm ≤ 60 MW

Wemen solar farm ≤ 25 MW

Yatpool solar farm ≤ 25 MW

Horsham SVC switched off or set to manual mode with a fixed Q setpoint

Kerang SVC switched off or set to manual mode with a fixed Q setpoint

8. Bendigo to Kerang 220 kV line

The following limit equations are enabled during an outage of the Bendigo to Kerang 220 kV line.

8.1 Transient Stability – Vic to NSW

To manage the Victorian transient stability export limit from Victoria to NSW for fault and trip of a Hazelwood to South Morang 500 kV line, apply the following prior outage offsets to system normal equations NILV, NILQ, NILS and NILS decelerating. The limit equation is of the form:

$$\text{Victoria to NSW} \leq \text{Sum} [\text{Term Values} * \text{System Normal Coefficients}] + \text{Offset}$$

Table 8 V::N BETS-KGTS_V/Q/S/S_decel offsets

| Term | Offset |
|---|--------|
| Offset to system normal equation NILV | -50 |
| Offset to system normal equation NILQ | 0 |
| Offset to system normal equation NILS | -50 |
| Offset to system normal equation NILS_decel | -50 |

8.2 Voltage Stability – Murraylink

To manage the Murraylink voltage stability export limit from Victoria to SA for fault and trip of the Ararat to Waubra to Ballarat 220 kV line, apply the following prior outage limit equations. Studies assume the Red Cliffs Voltage source controller (VSC) is in voltage control mode with the Very Fast Runback (VFRB) scheme disabled. Studies monitored post-contingent voltages and reactive power margin in southern NSW and the Victorian state grid. The limit equation is of the form:

$$\text{Victoria to SA (Murraylink)} \leq \text{Sum} [\text{Term Values} * \text{Coefficients}]$$

Table 9 VAS [MRLK] BETS-KGTS

| Term | Coefficient |
|-------------------------------|-------------|
| Intercept | 269.3 |
| RCTS Load | -0.4457 |
| WETS Load | -1.828 |
| KGTS Load | -2.276 |
| RCTS-MLK_MVAR | -0.7164 |
| Q3-REDCLF 220 | 0.6137 |
| Q2-BURNGA 220 | 0.5999 |
| HOTS_TX1_TX2 MW | -0.5086 |
| HOTS_TX1_TX2 MVAR | -0.2575 |
| Confidence Level (95%) offset | -45 |

8.3 Islanding

Limitation to prevent islanding of local load following the trip of the Kerang to Wemen to Red Cliffs 220 kV line.

Cohuna Solar Farm ≤ 0 MW with all inverters disconnected

Gannawarra solar farm ≤ 0 MW with all inverters disconnected

Gannawarra battery = 0 MW with all inverters disconnected

8.4 Voltage Oscillation

To prevent voltage oscillations for trip of Ararat to Waubra to Ballarat 220 kV line the following limits applied:

Bannerton solar farm ≤ 25 MW

Broken Hill solar farm ≤ 25 MW

Coleambally solar farm ≤ 45 MW

Darlington Point solar farm ≤ 80 MW

Finley solar farm ≤ 45 MW

Karadoc solar farm ≤ 25 MW

Kiamal solar farm ≤ 50 MW

Kiata wind farm ≤ 0 MW (can be operated in 'Pause Mode')

Limondale 1 solar farm ≤ 60 MW

Limondale 2 solar farm ≤ 25 MW

Murra Warra wind farm ≤ 0 MW (can be operated in 'Pause Mode')

Murraylink (Vic to SA) ≤ 150 MW

Murraylink (SA to Vic) ≤ 150 MW

Sunraysia solar farm ≤ 60 MW

Wemen solar farm ≤ 25 MW

Yatpool solar farm ≤ 25 MW

9. Bendigo to Shepparton 220 kV line

The following limit equations are enabled during an outage of the Bendigo to Shepparton 220 kV line.

9.1 Voltage Stability – Murraylink

To manage the Murraylink voltage stability export limit from Victoria to SA for fault and trip of Buronga to Balranald to Darlington point 220 kV line, apply the following prior outage limit equation. Studies assume the Red Cliffs Voltage source controller (VSC) is in voltage control mode with the Very Fast Runback (VFRB) scheme disabled. Studies monitored post-contingent voltages and reactive power margin in southern NSW and the Victorian state grid.

*Victoria to SA (Murraylink) \leq Sum [Term Values * Coefficients]*

Table 10 VAS [MRLK] BETS-SHTS_X5

| Term | Coefficient |
|-------------------------------|-------------|
| Intercept | 376.5 |
| RCTS Load | -1.151 |
| KGTS Load | -2.486 |
| BHSS220 Load | -2.267 |
| BKNH TX MW | -0.5398 |
| BATS TX MW | -0.8298 |
| HOTS SVC out of service | -19.85 |
| KGTS SVC out of service | -20.73 |
| Confidence Level (95%) offset | -29.78 |

9.2 Voltage Oscillation

To prevent voltage oscillations the following limits applied:

Ararat wind farm \leq 70 MW

Bannerton solar farm \leq 25 MW

Broken Hill solar farm \leq 25 MW

Bulgana wind farm \leq 30 MW

Coleambally Solar Farm \leq 90 MW

Crowlands wind farm ≤ 25 MW

Darlington Point Solar Farm ≤ 165 MW

Finley Solar Farm ≤ 90 MW

Gannawarra solar farm ≤ 15 MW

Karadoc solar farm ≤ 30 MW

Kiata wind farm ≤ 10 MW

Kiamal solar farm ≤ 60 MW

Limondale 1 Solar Farm ≤ 120 MW

Limondale 2 Solar Farm ≤ 15 MW

Murra Warra wind farm ≤ 60 MW

Murraylink (SA to Vic) ≤ 150 MW

Silverton wind farm ≤ 100 MW

Sunraysia Solar Farm ≤ 120 MW

Wemen solar farm ≤ 25 MW

Yatpool solar farm ≤ 25 MW

10. Buronga to Red Cliffs (0X1) 220 kV line

The following limit equations are enabled during an outage of the Buronga to Red Cliffs (0X1) 220 kV line.

Note: these limits are in addition to the limits provided by TransGrid for this outage.

10.1 Voltage Oscillation

To prevent voltage oscillations for trip of a Ararat to Waubra to Ballarat or Bendigo to Kerang 220 kV line the following limits applied:

Bannerton solar farm ≤ 45 MW

Bulgana wind farm ≤ 60 MW

Coleambally solar farm ≤ 60 MW

Darlington Point solar farm ≤ 100 MW

Finley solar farm ≤ 50 MW

Gannawarra solar farm ≤ 30 MW

Horsham SVC switched off or set to manual mode with a fixed Q setpoint

Karadoc solar farm ≤ 25 MW

Kerang SVC switched off or set to manual mode with a fixed Q setpoint

Kiamal solar farm ≤ 50 MW Limondale 2 solar farm ≤ 15 MW

Murra Warra wind farm ≤ 90 MW

Murraylink (SA to Vic) ≤ 150 MW

Wemen solar farm ≤ 45 MW

Yatpool solar farm ≤ 25 MW

10.2 Voltage Stability – NSW to Vic

Largest Vic generator or Basslink trip

To manage the Victorian voltage stability import limit from NSW to Victoria for fault and trip of Basslink or the loss of the largest Victorian generator, apply the following prior outage offset to the system normal equation NIL_VI_BLVG. The limit equation is of the form:

*NSW to Victoria $\leq [-1 * \text{Sum} [\text{Term Values} * \text{System Normal Coefficients}]] + \text{Offset}$*

Table 11 **N^V MSS-UTSS_BLVG offsets**

| Term | Offset |
|---------------------------------------|--------|
| Offset to system normal equation NILV | -200 |

10.3 Voltage Stability – Vic to NSW

To manage the Vic to NSW voltage stability export limit from Victoria to NSW for loss of both APD Potlines, apply the following prior outage offset to the system normal equation V^N_{2xAPD} . The limit equation is of the form:

$$\text{Victoria to NSW} \leq \text{Sum} [\text{Term Values} * \text{Coefficients}] + \text{Offset}$$

Table 12 **V^N_2xAPD offset**

| Term | Offset |
|---------------------------------------|--------|
| Offset to system normal V^N_{2xAPD} | -50 |

11. Cranbourne to Hazelwood 500 kV line

The following limit equations are enabled during an outage of the Cranbourne to Hazelwood 500 kV line.

11.1 Transient stability – Vic to NSW

11.1.1 V::N CBTS-HWTS-V

To manage the Victorian transient stability export limit from Victoria to NSW for fault and trip of a Hazelwood to South Morang 500 kV line (where Victoria accelerates ahead of the other states), apply the following limit equation:

*Victoria to NSW \leq Sum [Term Values * Coefficients]*

Table 13 V::N CBTS-HWTS-V coefficients

| Term | Coefficient |
|---|-------------|
| Intercept | 1024 |
| Basslink | 0.4251 |
| Vic. to SA (Heywood) | -0.3073 |
| Vic. to SA (Heywood)^2 | -8.43e-4 |
| Vic. to SA (Murraylink) | -1.091 |
| LV 500 Inertia | 8.719 |
| EPS Inertia | 20.56 |
| MOPS Inertia | 11.24 |
| LV 220 Inertia | 7.848 |
| SNOWY Inertia | 1.033 |
| VIC METRO Gen Inertia | 2.628 |
| Murray Gen | 0.7519 |
| Kiewa Gen | 0.9978 |
| LV 220 Gen | 0.2923 |
| VIC Metro Gen | 0.6395 |
| State Grid Load North | -0.9315 |
| APD Load | -0.9224 |
| Vic Wind & Solar | 0.4395 |
| VIC Demand - State Grid Load North - APD Load | -0.421 |
| 220 kV_Caps | -0.1575 |
| Num. ROTS SVC | 35.16 |
| Num. SESS SVC | 26.32 |
| Confidence Level (95%) offset | -99 |

11.1.2 V::N CBTS-HWTS-Q

To manage the Victorian transient stability export limit from Victoria to NSW for fault and trip of a Hazelwood to South Morang 500 kV line (where Queensland accelerates ahead of the other states), apply the following limit equation:

$$\text{Victoria to NSW} \leq \text{Sum} [\text{Term Values} * \text{Coefficients}]$$

Table 14 V::N CBTS-HWTS-V coefficients

| Term | Coefficient |
|-------------------------------|-------------|
| Intercept | 1554 |
| Basslink | 0.537 |
| Vic. to SA (Heywood) | -1.145 |
| Vic. to SA (Murraylink) | 0.8559 |
| LV 500 Inertia | 9.357 |
| MOPS Inertia | 11.93 |
| Murray Gen | 0.9247 |
| Kiewa Gen | 0.7993 |
| LV 220 Gen | 0.6185 |
| VIC Metro Gen | 0.6665 |
| Vic Wind & Solar | 0.6197 |
| State Grid Load | -0.7364 |
| VIC Demand - State Grid Load | -0.5799 |
| Confidence Level (95%) offset | -71 |

Note: this equation should only be applied when power transfers are above 900 MW from Queensland to New South Wales.

11.1.3 V::N CBTS-HWTS-S

To manage the Victorian transient stability export limit from Victoria to NSW for fault and trip of a Hazelwood to South Morang 500 kV line (where South Australia accelerates ahead of the other states), apply the following limit equation:

$$Victoria\ to\ NSW \leq Sum\ [Term\ Values * Coefficients]$$

Table 15 V::N CBTS-HWTS-S coefficients

| Term | Coefficient |
|--|-------------|
| Intercept | 903 |
| Basslink | 0.4955 |
| Vic. to SA (Heywood) | -0.5772 |
| Vic. to SA (Heywood)^2 | -6.19e-4 |
| Vic. to SA (Murraylink) | -1.053 |
| LV 500 Inertia | 8.706 |
| EPS Inertia | 21.63 |
| MOPS Inertia | 11.53 |
| LV 220 Inertia | 7.143 |
| KIEWA Inertia | 4.477 |
| VIC METRO Gen Inertia | 6.347 |
| Murray Gen | 0.8904 |
| Kiewa Gen | 0.797 |
| LV 220 Gen | 0.4175 |
| VIC Metro Gen | 0.3353 |
| State Grid Load North | -1.033 |
| APD Load | -0.4133 |
| Vic Wind & Solar | 0.5446 |
| VIC1 Demand - State Grid Load North - APD Load | -0.4714 |
| 220 kV_Caps | -0.1566 |
| Num. ROTS SVC | 33.88 |
| Num. SESS SVC | 24.1 |
| Confidence Level (95%) offset | -88 |

11.1.4 V::N CBTS-HWTS- S_decel

To manage the Victorian transient stability export limit from Victoria to NSW for fault and trip of a Hazelwood to South Morang 500 kV line (where South Australia decelerates away from the other states), apply the following limit equation:

$$Victoria\ to\ NSW \leq Sum\ [Term\ Values * Coefficients]$$

Table 16 V::N CBTS-HWTS-S_decel coefficients

| Term | Coefficient |
|--|-------------|
| Intercept | 763 |
| Basslink | 0.469 |
| Vic. to SA (Heywood)^2 | -0.00151 |
| Vic. to SA (Murraylink) | -1.204 |
| LV 500 Inertia | 9.302 |
| EPS Inertia | 18.57 |
| MOPS Inertia | 14.51 |
| KIEWA Inertia | 17.13 |
| VIC METRO Gen Inertia | 4.581 |
| Murray Gen | 0.8825 |
| LV 220 Gen | 0.6197 |
| VIC Metro Gen | 0.5306 |
| State Grid Load North | -0.8816 |
| APD Load | -0.3837 |
| Vic Wind & Solar | 0.514 |
| VIC1 Demand - State Grid Load North - APD Load | -0.4703 |
| 220 kV_Caps | -0.3296 |
| Confidence Level (95%) offset | -113 |

Note: this equation should only be applied when power transfers are above 500 MW from Victoria to South Australia

12. Crowlands to Bulgana to Horsham 220 kV line

The following limit equations are enabled during an outage of the Crowlands to Bulgana, Bulgana to Horsham or Crowlands to Bulgana to Horsham 220 kV lines unless indicated.

12.1 Transient Stability – Vic to NSW

To manage the Victorian transient stability export limit from Victoria to NSW for fault and trip of a Hazelwood to South Morang 500 kV line, apply the following prior outage offsets to system normal equations NILV, NILQ, NILS and NILS decelerating. The limit equation is of the form:

$$\text{Victoria to NSW} \leq \text{Sum [Term Values * System Normal Coefficients]} + \text{Offset}$$

Table 17 V::N ARTS-HOTS_V/Q/S/S_decel offsets

| Term | Offset |
|---|--------|
| Offset to system normal equation NILV | -80 |
| Offset to system normal equation NILQ | -40 |
| Offset to system normal equation NILS | -80 |
| Offset to system normal equation NILS_decel | -80 |

12.2 Islanding

Limitation to prevent islanding of local load following the trip of the Horsham to Red Cliffs 220 kV line.

$$\text{Kiata wind farm} \leq 0 \text{ MW}$$

For an outage of the Bulgana to Crowlands 220 kV line section the following islanding limit also applied:

$$\text{Bulgana wind farm} \leq 0 \text{ MW}$$

12.3 Voltage Oscillation

To prevent voltage oscillations for trip of a Bendigo to Kerang 220 kV line the following limits are applied:

$$\text{Bannerton solar farm} \leq 45 \text{ MW with } \leq 22 \text{ inverters connected, otherwise } 0 \text{ MW}$$

$$\text{Broken Hill solar farm} \leq 30 \text{ MW with } \leq 44 \text{ inverters connected, otherwise } 0 \text{ MW}$$

$$\text{Gannawarra solar farm} \leq 30 \text{ MW with } \leq 12 \text{ inverters connected, otherwise } 0 \text{ MW}$$

$$\text{Karadoc solar farm} \leq 45 \text{ MW with } \leq 21 \text{ inverters connected, otherwise } 0 \text{ MW}$$

$$\text{Murra Warra wind farm} \leq 15 \text{ MW with } \leq 30 \text{ turbines connected, otherwise } 0 \text{ MW}$$

$$\text{Wemen solar farm} \leq 45 \text{ MW with } \leq 21 \text{ inverters connected, otherwise } 0 \text{ MW}$$

$$\text{Horsham SVC switched off or set to manual mode with a fixed Q setpoint}$$

Kerang SVC switched off or set to manual mode with a fixed Q setpoint

For the outage of the Bulgana to Horsham 220 kV line the following limit is also applied:

Bulgana wind farm ≤ 130 MW

13. Dederang to Mount Beauty 220 kV line

The following limit equations are enabled during an outage of one Dederang to Mount Beauty 220 kV line.

13.1 Transient Stability – Vic to NSW

To manage the Victorian transient stability export limit from Victoria to NSW for fault and trip of a Hazelwood to South Morang 500 kV line, apply the following prior outage offsets to system normal equations NILV, NILQ, NILS and NILS decelerating. The limit equation is of the form:

$$\text{Victoria to NSW} \leq \text{Sum [Term Values * System Normal Coefficients]} + \text{Offset}$$

Table 18 V::N DDTS-MBTS_V/Q/S/S_decel offsets

| Term | Offset |
|---|--------|
| Offset to system normal equation NILV | -30 |
| Offset to system normal equation NILQ | 0 |
| Offset to system normal equation NILS | -30 |
| Offset to system normal equation NILS_decel | -30 |

13.2 Voltage Stability – NSW to Vic

The system normal voltage stability equation NIL_VI_BLVG will manage voltage stability associated with the loss of Basslink or the largest Victorian generator or the loss of a Dederang to Murray 330 kV line. Therefore no additional offset is required.

14. Dederang to Murray 330 kV line

The following limit equations are enabled during an outage of one Dederang to Murray 330 kV line.

Note: these limits are in addition to the limits provided by TransGrid for this outage.

14.1 Transient Stability – Vic to NSW

14.1.1 V::N DDTS-MSS-V

To manage the Victorian transient stability export limit from Victoria to NSW for fault and trip of a Dederang to Murray 330 kV line (where Victoria accelerates ahead of the other states), apply the following limit equation:

*Victoria to NSW \leq Sum [Term Values * Coefficients]*

Table 19 V::N DDTS-MSS-V coefficients

| Term | Coefficient |
|------------------------------------|-------------|
| Intercept | 994.7 |
| Basslink | 0.1248 |
| Vic. to SA (Heywood) | 0.07176 |
| Vic. to SA (Heywood)^2 | -2.59e-4 |
| Vic. to SA (Murraylink) | -0.5758 |
| LV 500 Inertia | 1.439 |
| EPS Inertia | 3.446 |
| MOPS Inertia | 2.061 |
| KIEWA Inertia | 6.499 |
| SNOWY Inertia | 1.392 |
| Murray Gen | 0.8731 |
| LV 220 Gen | 0.09512 |
| VIC Metro Gen | 0.1612 |
| State Grid Load North | -0.4595 |
| Vic Wind & Solar | 0.06173 |
| VIC Demand - State Grid Load North | -0.4486 |
| 220 kV_Caps | -0.1013 |
| Num. ROTS SVC | 13.52 |
| Confidence Level (95%) offset | -64 |

14.1.2 V::N DDTS-MSS-S

To manage the Victorian transient stability export limit from Victoria to NSW for fault and trip of a Dederang to Murray 330 kV line (where South Australia accelerates ahead of the other states), apply the following limit equation:

$$Victoria\ to\ NSW \leq Sum [Term\ Values * Coefficients]$$

Table 20 V::N DDTS-MSS-S coefficients

| Term | Coefficient |
|---|-------------|
| Intercept | 1036 |
| Basslink | 0.08914 |
| Vic. to SA (Heywood) | -0.0383 |
| Vic. to SA (Heywood)^2 | -1.2e-4 |
| Vic. to SA (Murraylink) | -0.5229 |
| LV 500 Inertia | 1.072 |
| EPS Inertia | 4.662 |
| MOPS Inertia | 1.288 |
| LV 220 Inertia | -4.738 |
| KIEWA Inertia | 2.931 |
| SNOWY Inertia | 1.081 |
| Murray Gen | 0.8924 |
| Kiewa Gen | 0.206 |
| LV 220 Gen | 0.2181 |
| VIC Metro Gen | 0.149 |
| State Grid Load North | -0.3608 |
| APD Load | -0.07564 |
| Vic Wind & Solar | 0.07921 |
| VIC Demand - State Grid Load North - APD Load | -0.04914 |
| 220 kV_Caps | -0.070 |
| Num. ROTS SVC | 15.68 |
| Confidence Level (95%) offset | -67 |

14.2 Voltage Stability – NSW to Vic

14.2.1 Largest Vic generator or Basslink trip

To manage Victorian voltage stability import limit from NSW to Victoria for fault and trip of Basslink or the loss of the largest Victorian generator, apply the following limit equation. Studies monitor post-contingent voltages and reactive power margin in northern Victoria and southern NSW. The limit equation is of the form:

$$NSW\ to\ Victoria \leq -1 * Sum [Term\ Values * Coefficients]$$

Table 21 VAN DDTS-MSS BLVG coefficients

| Term | Coefficient |
|-------------------------------|-------------|
| Intercept | -1535 |
| Contingent_MW | 0.9062 |
| SW_NSW | 0.7723 |
| NSWd-SW_NSW | 0.02759 |
| STH_NSW_GEN | -0.07476 |
| UTUM1SC+UTUM2SC | -20.47 |
| LTUM3SC | -67.3 |
| MSS2SC | -52.63 |
| DD330Cap | -0.2519 |
| WAGGACap | -0.2607 |
| MSSReac | -0.3413 |
| YASSReac | -0.1853 |
| U_TUMUT_Gen | -0.4923 |
| L_TUMUT_Gen | -0.3274 |
| MURRAY_Gen | 0.61 |
| UQT Gen | -0.516 |
| BKNH_GEN | -1.038 |
| Num. MSS1 on | -19.27 |
| Confidence Level (95%) offset | +65.0 |

14.2.2 Dederang to Murray 330 kV line trip

To manage the Victorian voltage stability import limit from NSW to Victoria for fault and trip of the remaining Dederang to Murray 330 kV line, apply the following limit equation. Studies monitor post-contingent voltages and reactive power margin in northern Victoria and southern NSW. The limit equation is of the form:

$$NSW \text{ to Victoria} \leq -1 * \text{Sum} [\text{Term Values} * \text{Coefficients}]$$

Table 22 VAN DDTS-MSS DDMS coefficients

| Term | Coefficient |
|-------------------------------|-------------|
| Intercept | -886 |
| SW_NSW | 0.6468 |
| UTUM1SC+UTUM2SC | -14.75 |
| LTUM3SC | -32.13 |
| MSS2SC | -19.60 |
| WAGGACap | -0.1989 |
| DLPTshnt | -0.4695 |
| MSSReac | -0.1648 |
| YASSReac | -0.09942 |
| U_TUMUT_Gen | -0.1822 |
| L_TUMUT_Gen | -0.04036 |
| MURRAY_Gen | 0.9568 |
| UQT Gen | -0.4729 |
| HUME VIC GEN | -1.819 |
| BKNH GEN | -0.9831 |
| Num. MSS1 on | -10.66 |
| Confidence Level (95%) offset | +65 |

15. Dederang to South Morang 330 kV line

The following limit equations are enabled during an outage of one Dederang to South Morang 330 kV line.

15.1 Transient Stability – Vic to NSW

15.1.1 V::N DDTS-SMTS-V

To manage the Victorian transient stability export limit from Victoria to NSW for fault and trip of the remaining Dederang to South Morang 330 kV line (where Victoria accelerates ahead of the other states), apply the following limit equation:

*Victoria to NSW \leq Sum [Term Values * Coefficients]*

Table 23 V::N DDTS-SMTS-V coefficients

| Term | Coefficient |
|------------------------------------|-------------|
| Intercept | 847.5 |
| Basslink | 0.1478 |
| Vic. to SA (Heywood) | 0.1098 |
| Vic. to SA (Heywood)^2 | -4.28e-4 |
| Vic. to SA (Murraylink) | -0.901 |
| LV 500 Inertia | 1.95 |
| EPS Inertia | 16.34 |
| MOPS Inertia | 1.854 |
| SNOWY Inertia | 0.836 |
| VIC Metro Gen Inertia | 1.558 |
| Murray Gen | 0.8631 |
| Kiewa Gen | 1.057 |
| LV 220 Gen | 0.1268 |
| VIC Metro Gen | 0.1087 |
| State Grid Load North | -0.8808 |
| Vic Wind & Solar | 0.1184 |
| VIC Demand - State Grid Load North | -0.08903 |
| Both TAIL- SESS Series Caps Out | 17.552 |
| Num. ROTS SVC | 18.34 |
| Confidence Level (95%) offset | -67 |

15.1.2 V::N DDTS-SMTS-S

To manage the Victorian transient stability export limit from Victoria to NSW for fault and trip of the remaining Dederang to South Morang 330 kV line (where South Australia accelerates ahead of the other states), apply the following limit equation

$$Victoria\ to\ NSW \leq Sum\ [Term\ Values * Coefficients]$$

Table 24 V::N DDTS-SMTS-S coefficients

| Term | Coefficient |
|------------------------------------|-------------|
| Intercept | 972.9 |
| Basslink | 0.1097 |
| Vic. to SA (Heywood)^2 | -2.74e-4 |
| Vic. to SA (Murraylink) | -0.849 |
| LV 500 Inertia | 1.527 |
| EPS Inertia | 19.58 |
| MOPS Inertia | 2.563 |
| KIEWA Inertia | 2.001 |
| SNOWY Inertia | 0.5206 |
| VIC Metro Gen Inertia | 3.017 |
| Murray Gen | 0.9295 |
| Kiewa Gen | 0.9608 |
| LV 220 Gen | 0.09506 |
| State Grid Load North | -0.8921 |
| Vic Wind & Solar | 0.1513 |
| VIC Demand - State Grid Load North | -0.09823 |
| Num. ROTS SVC | 19.1 |
| Confidence Level (95%) offset | -70 |

15.2 Voltage Stability – NSW to Vic

15.2.1 Largest Vic generator or Basslink trip

To manage the Victorian voltage stability import limit from NSW to Victoria for fault and trip of Basslink or the loss of the largest Victorian generator, apply the following prior outage offset to the system normal equation NIL_VI_BLVG. The limit equation is of the form:

$$NSW\ to\ Victoria \leq [-1 * Sum [Term\ Values * System\ Normal\ Coefficients]] + Offset$$

Table 25 NIL_VI_BLVG offset

| Term | Offset |
|--|--------|
| Offset to system normal equation NIL_VI_BLVG | -100 |

15.2.2 Dederang to Murray 330 kV line trip

To manage the Victorian voltage stability import limit from NSW to Victoria for fault and trip of the remaining Dederang to South Morang 330 kV line, apply the following prior outage offset to the system normal equation NIL_VI_BLVG. The limit equation is of the form:

$$NSW\ to\ Victoria \leq [-1 * Sum [Term\ Values * System\ Normal\ Coefficients]] + Offset$$

Table 26 NIL_VI_BLVG offset

| Term | Offset |
|--|--------|
| Offset to system normal equation NIL_VI_BLVG | -150 |

15.3 Voltage Stability – Vic to NSW

To manage the Vic to NSW voltage stability export limit from Victoria to NSW for loss of both APD Potlines, apply the following prior outage offset to the system normal equation V^N_2xAPD. The limit equation is of the form:

$$Victoria\ to\ NSW \leq Sum [Term\ Values * Coefficients] + Offset$$

Table 27 V^N_2xAPD offset

| Term | Offset |
|-----------------------------------|--------|
| Offset to system normal V^N_2xAPD | -150 |

16. Dederang Substation No. 1 or No. 2 330 kV Bus

The following limit equation is enabled during an outage of a Dederang 330 kV bus.

16.1 Voltage Stability – NSW to Vic

The system normal voltage stability equation NIL_VI_BLVG will manage voltage stability associated with the fault and trip of Basslink or the loss of the largest Victorian generator or loss of a Dederang to South Morang 330 kV line and series capacitor and the subsequent offloading of a Dederang to Murray 330 kV line. Therefore no additional offset is required.

17. Dederang to Wodonga 330 kV line

The following limit equations are enabled during an outage of the Dederang to Wodonga 330 kV line.

Note: these limits are in addition to the limits provided by Transgrid for this outage.

17.1 Transient Stability – Vic to NSW

To manage the Victorian transient stability export limit from Victoria to NSW for fault and trip of a Hazelwood to South Morang 500 kV line, apply the following prior outage offsets to system normal equations NILV, NILQ, NILS and NILS decelerating. The limit equation is of the form:

$$\text{Victoria to NSW} \leq \text{Sum} [\text{Term Values} * \text{System Normal Coefficients}] + \text{Offset}$$

Table 28 V::N DDTS-WOTS_V/Q/S/S_decel offsets

| Term | Offset |
|---|--------|
| Offset to system normal equation NILV | -110 |
| Offset to system normal equation NILQ | -15 |
| Offset to system normal equation NILS | -85 |
| Offset to system normal equation NILS_decel | -60 |

17.2 Voltage Stability – NSW to Vic

17.2.1 Largest Vic generator or Basslink trip

To manage the Victorian voltage stability import limit from NSW to Victoria for fault and trip of Basslink or the loss of the largest Victorian generator, apply the following prior outage offset to the system normal equation NIL_VI_BLVG. Studies monitored post-contingent voltages and reactive power margin in northern Victoria and southern NSW. The limit equation is of the form:

$$\text{NSW to Victoria} \leq [-1 * \text{Sum} [\text{Term Values} * \text{System Normal Coefficients}]] + \text{Offset}$$

Table 29 - V^N DDTS-WOTS_BLVG offset

| Term | Offset |
|--|--------|
| Offset to system normal equation NIL_VI_BLVG | -60 |

17.2.2 Dederang to Murray 330 kV line trip

The system normal voltage stability equation NIL_VI_BLVG will manage voltage stability associated with the loss of a Dederang to Murray 330 kV line. Therefore no additional offset is required.

17.3 Voltage Oscillation

To prevent voltage oscillations for the trip of Ararat to Waubra to Ballarat or Bendigo to Kerang 220 kV line the following limits are applied:

Ararat wind farm ≤ 0 MW (can be operated in 'Pause Mode')

Bannerton solar farm ≤ 45 MW

Bulgana wind farm ≤ 0 MW (can be operated in 'Pause Mode')

Bulgana battery = 0 MW with all inverters disconnected.

Crowlands wind farm ≤ 0 MW (can be operated in 'Pause Mode')

Gannawarra solar farm ≤ 30 MW

Horsham SVC switched off or set to manual mode with a fixed Q setpoint

Karadoc solar farm ≤ 25 MW

Kerang SVC switched off or set to manual mode with a fixed Q setpoint

Kiamal solar farm ≤ 50 MW

Limondale 2 solar farm ≤ 0 with all inverters disconnected

Murra Warra wind farm ≤ 90 MW

Murraylink SA-VIC ≤ 125 MW

Wemen solar farm ≤ 45 MW

Yatpool solar farm ≤ 25 MW

18. Eildon to Mount Beauty 220 kV line

The following limit equations are enabled during an outage of one Eildon to Mount Beauty 220 kV line.

18.1 Transient Stability – Vic to NSW

To manage the Victorian transient stability export limit from Victoria to NSW for fault and trip of a Hazelwood to South Morang 500 kV line, apply the following prior outage offsets to system normal equations NILV, NILQ, NILS and NILS decelerating. The limit equation is of the form:

$$\text{Victoria to NSW} \leq \text{Sum [Term Values * System Normal Coefficients]} + \text{Offset}$$

Table 30 V::N EPS-MBTS_V/Q/S/S_decel offsets

| Term | Offset |
|---|--------|
| Offset to system normal equation NILV | -30 |
| Offset to system normal equation NILQ | 0 |
| Offset to system normal equation NILS | -30 |
| Offset to system normal equation NILS_decel | -30 |

18.2 Voltage Stability – NSW to Vic

The system normal voltage stability equation NIL_VI_BLVG will manage voltage stability associated with the fault and trip of Basslink or the loss of the largest Victorian generator or a Dederang to Murray 330 kV line. Therefore no additional offset is required.

19. Eildon To Thomastown 220 kV line

The following limit equation is enabled during an outage of the Eildon to Thomastown 220 kV line.

19.1 Transient Stability – Vic to NSW

19.1.1 V::N EPS-TTS -V

To manage the Victorian transient stability export limit from Victoria to NSW for fault and trip of a Dederang to South Morang 330 kV line where Victoria accelerates ahead of the other states, apply the following limit equation:

$$\text{Victoria to NSW} \leq \text{Sum} [\text{Term Values} * \text{Coefficients}]$$

Table 31 V::N EPS-TTS -V coefficients

| Term | Coefficient |
|------------------------------------|-------------|
| Intercept | 1239 |
| Basslink | 0.217 |
| Vic. to SA (Heywood)^2 | -5.05e-4 |
| Vic. to SA (Murraylink) | -0.9143 |
| LV 500 Inertia | 3.003 |
| EPS Inertia | 16.9 |
| MOPS Inertia | 4.407 |
| LV 220 Inertia | 6.021 |
| SNOWY Inertia | 3.11 |
| Murray Gen | 0.7123 |
| Kiewa Gen | 0.9577 |
| VIC Metro Gen | 0.2778 |
| State Grid Load North | -0.8903 |
| Vic Wind & Solar | 0.1359 |
| VIC Demand - State Grid Load North | -0.1087 |
| 220 kV_Caps | -0.1669 |
| Confidence Level (95%) offset | -84 |

19.1.2 V::N EPS-TTS -S

To manage the Victorian transient stability export limit from Victoria to fault and trip of a Dederang to South Morang 330 kV line (where South Australia accelerates ahead of the other states), apply the following limit equation:

$$\text{Victoria to NSW} \leq \text{Sum} [\text{Term Values} * \text{Coefficients}]$$

Table 32 V::N EPS-TTS-S coefficients

| Term | Coefficient |
|------------------------------------|-------------|
| Intercept | 1241 |
| Basslink | 0.207 |
| Vic. to SA (Heywood) | -0.1075 |
| Vic. to SA (Heywood)^2 | -4.30e-4 |
| Vic. to SA (Murraylink) | -0.9241 |
| LV 500 Inertia | 3.313 |
| EPS Inertia | 18.36 |
| MOPS Inertia | 4.039 |
| SNOWY Inertia | 1.55 |
| VIC Metro Gen Inertia | 4.291 |
| Murray Gen | 0.894 |
| Kiewa Gen | 1.095 |
| LV 220 Gen | 0.182 |
| State Grid Load North | -0.777 |
| Vic Wind & Solar | 0.1821 |
| VIC Demand - State Grid Load North | -0.156 |
| 220 kV_Caps | -0.1031 |
| Num. ROTS SVC | 22.35 |
| Num. SESS SVC | 18.94 |
| Confidence Level (95%) offset | -75 |

19.2 Voltage Stability – NSW to Vic

The system normal voltage stability equation NIL_VI_BLVG will manage voltage stability associated with the fault and trip of Basslink or the loss of the largest Victorian generator or a Dederang to South Morang 330 kV line. Therefore no additional offset is required.

20. Hazelwood to Loy Yang 500 kV line

The following limit equation is enabled during an outage of the Hazelwood to Loy Yang 500 kV line.

20.1 System Strength

Electro Magnetic Transient (EMT) studies identified the requirement of minimum number of synchronous generators in Victoria to be available prior to this outage. This is to maintain sufficient system strength in Victoria network for the loss of all three Hazelwood to Loy Yang 500 kV lines. Verified combinations are listed below.

Table 33 Hazelwood – Loy Yang outage system strength minimum generator combinations

| Combination | Bogong | Dartmouth | Jeeralang A+B | Mortlake | Murray (unit 1-10) | Murray (unit 11-14) | Newport | Yallourn |
|-------------|--------|-----------|------------------|----------|-----------------------|------------------------|---------|----------|
| 1 | | | 4 | | | 4 | | 3 |
| 2 | | | | | | 4 | 1 | 3 |
| 3 | | | | 2 | | 4 | | 3 |
| 4 | | | 4 | 1 | | 4 | | 2 |
| 5 | | 1 | 4 | 1 | | 2 | | 2 |
| 6 | 1 | 1 | 4 | 1 | 1 | 1 | | 2 |

21. Hazelwood To South Morang 500 kV line

The following limit equations are enabled during an outage of one Hazelwood to South Morang 500 kV line.

21.1 Transient Stability – Vic to NSW

21.1.1 V::N HWTS-SMTS -V

To manage the Victorian transient stability export limit from Victoria to NSW for fault and trip of the remaining Hazelwood to South Morang 500 kV line (where Victoria accelerates ahead of the other states), apply the following limit equation:

*Victoria to NSW \leq Sum [Term Values * Coefficients]*

Table 34 V::N HWTS-SMTS-V coefficients

| Term | Coefficient |
|---|-------------|
| Intercept | 1282 |
| Basslink | 0.4379 |
| Vic. to SA (Heywood) | -0.3323 |
| Vic. to SA (Heywood)^2 | -9.229e-4 |
| Vic. to SA (Murraylink) | -1.092 |
| LV 500 Inertia | 7.984 |
| EPS Inertia | 24.30 |
| MOPS Inertia | 8.864 |
| LV 220 Inertia | 6.883 |
| Murray Gen | 0.8310 |
| Kiewa Gen | 1.167 |
| LV 220 Gen | 0.3025 |
| VIC Metro Gen | 0.9260 |
| State Grid Load North | -0.7591 |
| APD Load | -1.176 |
| Vic Wind & Solar | 0.4519 |
| VIC Demand - State Grid Load North - APD Load | -0.4406 |
| Num. ROTS SVC | 32.41 |
| Num. SESS SVC | 27.43 |
| Confidence Level (95%) offset | -88 |

21.1.2 V::N HWTS-SMTS-Q

To manage the Victorian transient stability export limit from Victoria to NSW for fault and trip of the remaining Hazelwood to South Morang 500 kV line (where Queensland accelerates ahead of the other states), apply the following limit equation:

$$\text{Victoria to NSW} \leq \text{Sum} [\text{Term Values} * \text{Coefficients}]$$

Table 35 V::N HWTS-SMTS-Q coefficients

| Term | Coefficient |
|-------------------------------|-------------|
| Intercept | 1748 |
| Basslink | 0.619 |
| Vic. to SA (Heywood) | -1.275 |
| Vic. to SA (Murraylink) | -0.6562 |
| LV 500 Inertia | 9.343 |
| MOPS Inertia | 16.42 |
| Murray Gen | 0.7247 |
| Kiewa Gen | 0.7898 |
| LV 220 Gen | 0.5231 |
| Vic Wind & Solar | 0.719 |
| State Grid Load | -0.7987 |
| VIC Demand - State Grid Load | -0.615 |
| Confidence Level (95%) offset | -78 |

Note: this equation should only be applied when power transfers are above 900 MW from Queensland to New South Wales.

21.1.3 V::N HWTS-SMTS-S

To manage the Victorian transient stability export limit from Victoria to NSW for fault and trip of the remaining Hazelwood to South Morang 500 kV line (where South Australia accelerates ahead of the other states), apply the following limit equation:

$$\text{Victoria to NSW} \leq \text{Sum} [\text{Term Values} * \text{Coefficients}]$$

Table 36 V::N HWTS-SMTS-S coefficients

| Term | Coefficient |
|---|-------------|
| Intercept | 970.8 |
| Basslink | 0.5021 |
| Vic. to SA (Heywood) | -0.5782 |
| Vic. to SA (Heywood)^2 | -5.973e-4 |
| Vic. to SA (Murraylink) | -1.149 |
| LV 500 Inertia | 8.332 |
| EPS Inertia | 22.71 |
| MOPS Inertia | 10.68 |
| LV 220 Inertia | 17.10 |
| KIEWA Inertia | 4.865 |
| VIC METRO Gen Inertia | 7.135 |
| Murray Gen | 0.9213 |
| Kiewa Gen | 0.7844 |
| VIC Metro Gen | 0.2938 |
| State Grid Load North | -1.166 |
| APD Load | -0.4342 |
| Vic Wind & Solar | 0.5615 |
| VIC Demand - State Grid Load North - APD Load | -0.4538 |
| 220 kV_Caps | -0.1530 |
| Num. ROTS SVC | 33.88 |
| Num. SESS SVC | 22.04 |
| Confidence Level (95%) offset | -92 |

21.1.4 V::N HWTS-SMTS-S_decel

To manage the Victorian transient stability export limit from Victoria to NSW for fault and trip of the remaining Hazelwood to South Morang 500 kV line (where South Australia decelerates away from the other states), apply the following limit equation:

$$\text{Victoria to NSW} \leq \text{Sum} [\text{Term Values} * \text{Coefficients}]$$

Table 37 V::N HWTS-SMTS-S_decel coefficients

| Term | Coefficient |
|------------------------------------|-------------|
| Intercept | 1211 |
| Basslink | 0.4028 |
| Vic. to SA (Heywood) | -1.772 |
| Vic. to SA (Murraylink) | -1.065 |
| LV 500 Inertia | 9.683 |
| MOPS Inertia | 11.69 |
| LV 220 Inertia | 18.59 |
| KIEWA Inertia | 18.86 |
| VIC METRO Gen Inertia | 7.38 |
| Murray Gen | 0.8217 |
| State Grid Load North | -0.8141 |
| Vic Wind & Solar | 0.565 |
| VIC Demand - State Grid Load North | -0.4551 |
| Confidence Level (95%) offset | -128 |

Note: this equation should only be applied when power transfers are above 500 MW from Victoria to South Australia.

22. Heywood to South East 275 kV line

The following limit equations are enabled during an outage of one Heywood to South East 275 kV line.

22.1 Transient Stability – Vic to NSW

To manage the Victorian transient stability export limit from Victoria to NSW for fault and trip of a Hazelwood to South Morang 500 kV line, apply the following prior outage offsets to system normal equations NILV, NILQ, NILS and NILS decelerating. The limit equation is of the form:

$$\text{Victoria to NSW} \leq \text{Sum} [\text{Term Values} * \text{System Normal Coefficients}] + \text{Offset}$$

Table 38 V::N HYTS-SESS_V/Q/S/S_decel offsets

| Term | Offset |
|---|---|
| Offset to system normal equation NILV | -70 |
| Offset to system normal equation NILQ | 0 |
| Offset to system normal equation NILS | -27 |
| Offset to system normal equation NILS_decel | N/A [VIC->SA transfer limited to 250MW] |

23. Horsham SVC

23.1 Voltage Oscillation

To prevent voltage oscillations for trip of an Ararat to Waubra to Ballarat 220 kV line or Bendigo to Kerang 220 kV line the following limits applied:

Ararat wind farm ≤ 145 MW

Bannerton solar farm ≤ 53 MW

Broken Hill solar farm ≤ 32 MW

Bulgana wind farm ≤ 111 MW

Cohuna solar farm ≤ 17 MW

Coleambally solar farm ≤ 105 MW

Crowlands wind farm ≤ 48 MW

Darlington Point solar farm ≤ 193 MW

Finley solar farm ≤ 93 MW

Gannawarra solar farm ≤ 30 MW

Karadoc solar farm ≤ 54 MW

Kiamal solar farm ≤ 120 MW

Kiata wind farm ≤ 18 MW

Limondale 1 solar farm ≤ 132 MW

Limondale 2 solar farm ≤ 18 MW

Murra Warra wind farm ≤ 135 MW

Silverton wind farm ≤ 119 MW

Sunraysia solar farm ≤ 120 MW

Wemen solar farm ≤ 53 MW

Yatpool solar farm ≤ 49 MW

24. Horsham to Murra Warra to Kiamal 220 kV line

The following limit equations are enabled during an outage of the Horsham to Murra Warra, Murra Warra to Kiamal or Horsham to Murra Warra to Kiamal 220 kV lines unless indicated.

24.1 Transient Stability – Vic to NSW

To manage the Victorian transient stability export limit from Victoria to NSW for fault and trip of a Hazelwood to South Morang 500 kV line, apply the following prior outage offsets to system normal equations NILV, NILQ, NILS and NILS decelerating. The limit equation is of the form:

$$\text{Victoria to NSW} \leq \text{Sum} [\text{Term Values} * \text{System Normal Coefficients}] + \text{Offset}$$

Table 39 V::N HOTS-RCTS_V/Q/S/S_decel offsets

| Term | Offset |
|---|--------|
| Offset to system normal equation NILV | -60 |
| Offset to system normal equation NILQ | 0 |
| Offset to system normal equation NILS | -40 |
| Offset to system normal equation NILS_decel | -50 |

24.2 Voltage Stability – Murraylink

24.2.1 Buronga to Balranald to Darlington Point (X5) trip

To manage the Murraylink voltage stability export limit from Victoria to SA for fault and trip of the Buronga to Balranald to Darlington point 220 kV line, apply the following prior outage limit equation. Studies assume the Red Cliffs Voltage source controller (VSC) is in voltage control mode with the Very Fast Runback (VFRB) scheme disabled. Studies monitored post-contingent voltages and reactive power margin in southern NSW and the Victorian state grid. The limit equation is of the form:

$$\text{Victoria to SA (Murraylink)} \leq \text{Sum} [\text{Term Values} * \text{Coefficients}]$$

Table 40 VAS [MRLK] HOTS-RCTS_X5

| Term | Coefficient |
|-------------------------------|-------------|
| Intercept | 277.7 |
| RCTS Load | -0.9364 |
| KGTS Load | -1.225 |
| BETS Load | -0.1876 |
| WETS Load | -0.6805 |
| BKNH TX MW | -0.7594 |
| VIC2NSW | 0.01024 |
| KGTS SVC out of service | -18.79 |
| Confidence Level (95%) offset | -32 |

24.2.2 Bendigo to Kerang trip

To manage the Murraylink voltage stability export limit from Victoria to SA for fault and trip of the Bendigo to Kerang 220 kV line, apply the following prior outage limit equation. Studies assume the Red Cliffs Voltage source controller (VSC) is in voltage control mode with the Very Fast Runback (VFRB) scheme disabled. Studies monitored post-contingent voltages and reactive power margin in southern NSW and the Victorian state grid. The limit equation is of the form:

$$\text{Victoria to SA (Murraylink)} \leq \text{Sum [Term Values * Coefficients]}$$

Table 41 VAS [MRLK] HOTS-RCTS_BEKG

| Term | Coefficient |
|-------------------------------|-------------|
| Intercept | 164.4 |
| RCTS Load | -0.9846 |
| KGTS Load | -0.6067 |
| WETS Load | -0.89 |
| BKNH TX MW | -1.071 |
| BHSS220 Load | -0.7057 |
| KGTS SVC out of service | -6.367 |
| Confidence Level (95%) offset | -31 |

24.3 Islanding

Limitation to prevent islanding of local load following the trip of the Ararat to Waubra to Ballarat or Kiamal to Red Cliffs 220 kV lines.

Kiata wind farm ≤ 0 MW

24.4 Voltage Oscillation

To prevent voltage oscillations for trip of the Bendigo to Kerang 220 kV line the following limits are applied:

Bannerton solar farm ≤ 45 MW

Broken Hill solar farm ≤ 30 MW

Gannawarra solar farm ≤ 0 MW with all inverters disconnected

Gannawarra battery ≤ 0 MW

Karadoc solar farm ≤ 45 MW

Kiamal ≤ 40 MW

Wemen solar farm ≤ 45 MW

Yatpool solar farm ≤ 40 MW

For an outage of the Horsham to Murra Warra 220 kV line the following limits are also applied:

Murra Warra ≤ 15 MW

Horsham SVC switched off or set to manual mode with a fixed Q setpoint

Kerang SVC switched off or set to manual mode with a fixed Q setpoint

For outage of Murra Warra to Kiamal 220 kV line the following limits are also applied:

Murra Warra ≤ 15 MW from collector groups 3 and 4, otherwise 0 MW

Horsham SVC switched off or set to manual mode with a fixed Q setpoint

25. Jindera to Wodonga (060) 330 kV line

The following limit equations are enabled during an outage of the Jindera to Wodonga 330 kV line.

Note: these limits are in addition to the limits provided by TransGrid for this outage.

Note 2: Balranald to Darlington Point (X5) line is also out of service for this outage and the limits for an X5 outage also apply (see Vic Transfer Limit Advice – Outages in Adjacent Regions).

25.1 Transient Stability – Vic to NSW

To manage the Victorian transient stability export limit from Victoria to NSW for fault and trip of a Hazelwood to South Morang 500 kV line, apply the following prior outage offsets to system normal equations NILV, NILQ, NILS and NILS decelerating. The limit equation is of the form:

$$\text{Victoria to NSW} \leq \text{Sum [Term Values * System Normal Coefficients]} + \text{Offset}$$

Table 42 V::N JIND-WOTS_V/Q/S/S_decel offsets

| Term | Offset |
|---|--------|
| Offset to system normal equation NILV | -60 |
| Offset to system normal equation NILQ | 0 |
| Offset to system normal equation NILS | -70 |
| Offset to system normal equation NILS_decel | -50 |

25.2 Voltage Stability – NSW to Vic

25.2.1 Largest Vic generator or Basslink trip

To manage the Victorian voltage stability import limit from NSW to Victoria for fault and trip of Basslink or the loss of the largest Victorian generator, apply the following prior outage offset to the system normal equation NIL_VI_BLVG. Studies monitored post-contingent voltages and reactive power margin in northern Victoria and southern NSW. The limit equation is of the form:

$$\text{NSW to Victoria} \leq [-1 * \text{Sum [Term Values * System Normal Coefficients]}] + \text{Offset}$$

Table 43 VAN JIND-WOTS_BLVG offset

| Term | Offset |
|--|--------|
| Offset to system normal equation NIL_VI_BLVG | -60 |

25.2.2 Dederang to Murray 330 kV line trip

The system normal voltage stability equation NIL_VI_BLVG will manage voltage stability associated with the loss of a Dederang to Murray 330 kV line. Therefore no additional offset is required.

25.3 Voltage Oscillation

To prevent voltage oscillations for the trip of Ararat to Waubra to Ballarat or Bendigo to Kerang 220 kV line the limits of Section 17.3 are applied.

26. Keilor to Sydenham 500 kV line

The following limit equations are enabled during an outage of the Keilor to Sydenham 500 kV line.

26.1 Transient Stability – Vic to NSW

To manage the Victorian transient stability export limit from Victoria to NSW for fault and trip of a Hazelwood to South Morang 500 kV line, apply the following prior outage offsets to system normal equations NILV, NILQ, NILS and NILS decelerating. The limit equation is of the form:

$$\text{Victoria to NSW} \leq \text{Sum} [\text{Term Values} * \text{System Normal Coefficients}] + \text{Offset}$$

Table 44 V::N KTS-SYTS_V/Q/S/S_decel offsets

| Term | Offset |
|---|--------|
| Offset to system normal equation NILV | -25 |
| Offset to system normal equation NILQ | 0 |
| Offset to system normal equation NILS | -10 |
| Offset to system normal equation NILS_decel | -10 |

27. Kerang SVC

The following limit equations are enabled during an outage of the Kerang SVC.

27.1 Voltage Oscillation

To prevent voltage oscillations for trip of an Ararat to Waubra to Ballarat 220 kV line or Bendigo to Kerang 220 kV line the following limits applied:

Bannerton solar farm $\leq 25\text{MW}$

Broken Hill solar farm $\leq 25\text{ MW}$

Coleambally solar farm $\leq 30\text{ MW}$

Darlington Point solar farm $\leq 80\text{ MW}$

Finley solar farm $\leq 30\text{ MW}$

Gannawarra solar farm $\leq 25\text{ MW}$

Horsham SVC switched off or set to manual mode with a fixed Q setpoint

Karadoc solar farm $\leq 25\text{ MW}$

Kiamal solar farm $\leq 50\text{ MW}$

Limondale 1 solar farm $\leq 50\text{ MW}$

Limondale 2 solar farm $\leq 25\text{ MW}$

Murra Warra wind farm $\leq 90\text{ MW}$

Murraylink (SA to Vic) $\leq 150\text{ MW}$

Sunraysia solar farm $\leq 50\text{ MW}$

Wemen solar farm $\leq 25\text{ MW}$

Yatpool solar farm $\leq 25\text{ MW}$

28. Kerang to Wemen to Red Cliffs 220 kV line

The following limit equations are enabled during an outage of the Kerang to Wemen, Red Cliffs to Wemen or Kerang to Wemen to Red Cliffs 220 kV lines unless indicated.

Note: For the outage of Kerang to Wemen to Red Cliffs 220 kV line Bannerton solar farm and Wemen solar farm are disconnected as they are connected to Wemen.

28.1 Transient Stability – Vic to NSW

To manage the Victorian transient stability export limit from Victoria to NSW for fault and trip of a Hazelwood to South Morang 500 kV line, apply the following prior outage offsets to system normal equations NILV, NILQ, NILS and NILS decelerating. The limit equation is of the form:

$$\text{Victoria to NSW} \leq \text{Sum} [\text{Term Values} * \text{System Normal Coefficients}] + \text{Offset}$$

Table 45 V::N KTS-SYTS_V/Q/S/S_decel offsets

| Term | Offset |
|---|--------|
| Offset to system normal equation NILV | -50 |
| Offset to system normal equation NILQ | 0 |
| Offset to system normal equation NILS | -50 |
| Offset to system normal equation NILS_decel | -50 |

28.2 Voltage Stability – Murraylink

To manage the Murraylink voltage stability export limit from Victoria to SA for fault and trip of the Ararat to Horsham 220 kV line, apply the following prior outage limit equations. Studies assume the Red Cliffs Voltage source controller (VSC) is in voltage control mode with the Very Fast Runback (VFRB) scheme disabled. Studies monitored post-contingent voltages and reactive power margin in southern NSW and the Victorian state grid. The limit equation is of the form:

$$\text{Victoria to SA (Murraylink)} \leq \text{Sum} [\text{Term Values} * \text{Coefficients}]$$

Table 46 VAS [MRLK] KGTS-WETS-RCTS

| Term | Coefficient |
|-------------------------------|-------------|
| Intercept | 188.3 |
| RCTS Load | -0.8288 |
| KGTS Load | -0.857 |
| WETS load | -1.156 |
| BKNH TX MW | -1.023 |
| BHSS220 Load | -1.137 |
| Confidence Level (95%) offset | -25.7 |

28.3 Islanding

Limitation to prevent islanding of local load:

Cohuna solar farm ≤ 0 MW with all inverters disconnected

Gannawarra solar farm ≤ 0 MW with all inverters disconnected

Gannawarra battery=0 MW with all inverters disconnected

Wemen solar farm ≤ 0 MW with all inverters disconnected

Bannerton solar farm ≤ 0 MW with all inverters disconnected

28.4 Voltage Oscillation

To prevent voltage oscillations for trip of the Ararat to Waubra to Ballarat 220 kV line the following limits are applied:

Ararat wind farm ≤ 160 MW

Broken Hill solar farm ≤ 30 MW

Bulgana wind farm ≤ 40 MW

Crowlands wind farm ≤ 55 MW

Coleambally Solar Farm ≤ 45 MW

Darlington Point Solar Farm ≤ 85 MW

Finley Solar Farm ≤ 45 MW

Karadoc solar farm ≤ 20 MW

Kiamal solar farm ≤ 50 MW

Kiata wind farm ≤ 15 MW

Limondale1 Solar Farm ≤ 60 MW

Limondale2 Solar Farm ≤ 15 MW

Murra Warra wind farm ≤ 80 MW

Murraylink (Vic to SA) ≤ 150 MW

Murraylink (SA to Vic) ≤ 150 MW

Silverton wind farm ≤ 100 MW

Sunraysia Solar Farm ≤ 60 MW

Yatpool solar farm ≤ 20 MW

Horsham SVC switched off or set to manual mode with a fixed Q setpoint

For the outage of the Kerang to Wemen or Kerang to Wemen to Red Cliffs 220 kV lines the following limits are also applied:

Kerang SVC switched off or set to manual mode with a fixed Q setpoint

29. Kiamal to Red Cliffs 220 kV line

29.1 Transient Stability – Vic to NSW

To manage the Victorian transient stability export limit from Victoria to NSW for fault and trip of a Hazelwood to South Morang 500 kV line, apply the following prior outage offsets to system normal equations NILV, NILQ, NILS and NILS decelerating. The limit equation is of the form:

$$\text{Victoria to NSW} \leq \text{Sum} [\text{Term Values} * \text{System Normal Coefficients}] + \text{Offset}$$

Table 47 V::N HOTS-RCTS_V/Q/S/S_decel offsets

| Term | Offset |
|---|--------|
| Offset to system normal equation NILV | -60 |
| Offset to system normal equation NILQ | 0 |
| Offset to system normal equation NILS | -40 |
| Offset to system normal equation NILS_decel | -50 |

29.2 Voltage Stability – Murraylink

29.2.1 Buronga to Balranald to Darlington Point (X5) trip

To manage the Murraylink voltage stability export limit from Victoria to SA for fault and trip of the Buronga to Balranald to Darlington point 220 kV line, apply the following prior outage limit equation. Studies assume the Red Cliffs Voltage source controller (VSC) is in voltage control mode with the Very Fast Runback (VFRB) scheme disabled. Studies monitored post-contingent voltages and reactive power margin in southern NSW and the Victorian state grid. The limit equation is of the form:

$$\text{Victoria to SA (Murraylink)} \leq \text{Sum} [\text{Term Values} * \text{Coefficients}]$$

Table 48 VAS [MRLK] HOTS-RCTS_X5

| Term | Coefficient |
|-------------------------------|-------------|
| Intercept | 277.7 |
| RCTS Load | -0.9364 |
| KGTS Load | -1.225 |
| BETS Load | -0.1876 |
| WETS Load | -0.6805 |
| BKNH TX MW | -0.7594 |
| VIC2NSW | 0.01024 |
| KGTS SVC out of service | -18.79 |
| Confidence Level (95%) offset | -32 |

29.2.2 Bendigo to Kerang trip

To manage the Murraylink voltage stability export limit from Victoria to SA for fault and trip of the Bendigo to Kerang 220 kV line, apply the following prior outage limit equation. Studies assume the Red Cliffs Voltage source controller (VSC) is in voltage control mode with the Very Fast Runback (VFRB) scheme disabled. Studies monitored post-contingent voltages and reactive power margin in southern NSW and the Victorian state grid. The limit equation is of the form:

$$\text{Victoria to SA (Murraylink)} \leq \text{Sum [Term Values * Coefficients]}$$

Table 49 VAS [MRLK] HOTS-RCTS_BEKG

| Term | Coefficient |
|-------------------------------|-------------|
| Intercept | 164.4 |
| RCTS Load | -0.9846 |
| KGTS Load | -0.6067 |
| WETS Load | -0.89 |
| BKNH TX MW | -1.071 |
| BHSS220 Load | -0.7057 |
| KGTS SVC out of service | -6.367 |
| Confidence Level (95%) offset | -31 |

29.3 Islanding

Limitation to prevent islanding of local load following the trip of the Ararat to Waubra to Ballarat 220 kV line.

Kiata wind farm ≤ 0 MW

Kiamal solar farm ≤ 0 MW with all inverters disconnected

29.4 Voltage Oscillation

To prevent voltage oscillations for trip of the Bendigo to Kerang 220 kV line the following limits are applied:

Bannerton solar farm ≤ 45 MW

Broken Hill solar farm ≤ 30 MW

Coleambally solar farm ≤ 40 MW

Darlington Point solar farm ≤ 65 MW

Finley solar farm ≤ 40 MW

Gannawarra solar farm ≤ 0 MW with all inverters disconnected

Gannawarra battery = 0 MW

Karadoc solar farm ≤ 45 MW

Limondale 1 solar farm ≤ 50 MW

Limondale 2 solar farm ≤ 10 MW

Murraylink (SA to Vic) ≤ 150 MW

Murra Warra ≤ 15 MW from collector groups 3 and 4, otherwise 0 MW

Silverton wind farm ≤ 50 MW

Sunraysia solar farm ≤ 60 MW

Wemen solar farm ≤ 45 MW

Yatpool solar farm ≤ 40 MW

30. Moorabool to Mortlake 500 kV line

The following limit equations are enabled during an outage of the Moorabool to Mortlake 500 kV line.

30.1 Transient Stability – Vic to NSW

To manage the Victorian transient stability export limit from Victoria to NSW for fault and trip of a Hazelwood to South Morang 500 kV line, apply the following prior outage offsets to system normal equations NILV, NILQ, NILS and NILS_decelerating. The limit equation is of the form:

$$\text{Victoria to NSW} \leq \text{Sum [Term Values * System Normal Coefficients]} + \text{Offset}$$

Table 50 V::N MLTS-MOPS_V/Q/S/S_decel offsets

| Term | Offset |
|---|---|
| Offset to system normal equation NILV | -30 |
| Offset to system normal equation NILQ | 0 |
| Offset to system normal equation NILS | -30 |
| Offset to system normal equation NILS_decel | N/A [VIC->SA transfer limited to 250MW] |

30.2 Voltage Unbalance

The following limit equations are enabled to manage the voltage unbalance at APD 500kV and Heywood 275kV buses. These equations are only for VIC to SA power transfer. If flow is SA to VIC, including zero power transfer, no limitations are required.

$$6.5562 \times \text{APD Net Load} + \text{Mortlake} + \text{Dundonnell generation} - 34.965 \times \text{Macarthur generation} + 16.6738 \times \text{VIC to SA (Heywood)} \leq 10931$$

$$\text{APD Net Load} - 0.6605 \times (\text{Mortlake} + \text{Dundonnell generation}) - 2.6368 \times \text{Macarthur generation} + 1.9966 \times \text{VIC to SA (Heywood)} \leq 1015$$

31. Moorabool To Sydenham 500 kV line

The following limit equations are enabled during an outage of one Moorabool to Sydenham 500 kV line.

31.1 Transient Stability – Vic to NSW

To manage the Victorian transient stability export limit from Victoria to NSW for fault and trip of a Hazelwood to South Morang 500 kV line, apply the following prior outage offsets to system normal equations NILV, NILQ, NILS, NILS_decelerating. The limit equation is of the form:

$$\text{Victoria to NSW} \leq \text{Sum} [\text{Term Values} * \text{System Normal Coefficients}] + \text{Offset}$$

Table 51 V::N MLTS-SYTS_V/Q/S/S_decel offsets

| Term | Offset |
|---|--------|
| Offset to system normal equation NILV | -50 |
| Offset to system normal equation NILQ | 0 |
| Offset to system normal equation NILS | -20 |
| Offset to system normal equation NILS_decel | -100 |

Studies assume the Emergency Moorabool Transformer Tripping Scheme (EMTT) is disabled. The equation is also valid when the scheme is enabled but the post-contingent conditions do not result in scheme operation.

31.2 Voltage Stability – Vic to SA

To manage the Victorian voltage stability export limit from Victoria to SA for fault and trip of the remaining Moorabool to Sydenham 500 kV line, apply the following limit equation:

$$\text{Victoria to SA (Heywood)} \leq \text{Sum} [\text{Term Values} * \text{Coefficients}]$$

Table 52 VAS[HEY]_MLTS-SYTS coefficients

| Term | Coefficient (dVs) | Coefficient |
|-------------------------------|-------------------|-------------|
| Intercept | 930.6 | 1008 |
| APD-HYTS_MW | 0.4953 | 0.4813 |
| APD-HYTS_MVAR | 0.3203 | 0.5232 |
| GTS_LOAD | -0.5702 | -0.6298 |
| MOPS_Gen | 0.7568 | 0.5596 |
| MCAR_Gen | 0.7757 | 0.312 |
| MLTS_220_Reactors | 0 | -10.04 |
| MLTS_Line_Reactors | -42.64 | -43.67 |
| Confidence Level (95%) offset | -85.97 | -78.21 |

Studies assume the Emergency Moorabool Transformer Tripping Scheme (EMTT) is disabled. The equation is also valid when the scheme is enabled but the post-contingent conditions do not result in scheme operation

31.3 Voltage Oscillation

To prevent voltage oscillations for trip of the remaining Moorabool – Sydenham 500 kV line which results in offloading multiple 500 kV lines between Sydenham and South Morang, the following limits are applied:

Macarthur wind farm ≤ 0 MW

Moorabool wind farm ≤ 150 MW with ≤ 50 turbines connected, otherwise 0 MW

31.4 System Strength

Electro Magnetic Transient (EMT) studies identified the requirement of minimum number of synchronous generators in Victoria to be online prior to this outage. This is to prevent undamped oscillations in Victoria network following a credible contingency of the remaining Moorabool – Sydenham 500 kV line which results in offloading multiple 500 kV lines between Sydenham and South Morang. Verified combinations are listed below.

Table 53 Moorabool – Sydenham outage system strength minimum generator combinations

| Combination | Bogong | Dartmouth | Jeeralang A | Loy Yang | Mortlake | Murray (unit 1-10) | Murray (unit 11-14) | Newport | Valley Power | Yallourn | Loy Yang + Yallourn |
|-------------|--------|-----------|-------------|----------|----------|--------------------|---------------------|---------|--------------|----------|---------------------|
| 1 | | | | | | | | | | | 7 |
| 2 | | 1 | | 4 | 1 | 2 | | | | 2 | |
| 3 | | | | 4 | | | | 1 | | 2 | |
| 4 | | | | | | | 4 | | | | 5 |
| 5 | | | 4 | | | | | | | | 5 |
| 6 | | | | | 2 | | | | | | 5 |
| 7 | 1 | 1 | | | | | | | | | 5 |
| 8 | | | | | 1 | | | 1 | | | 5 |
| 9 | | | | | | | | | 4 | | 5 |

32. Moorabool to Haunted Gully or Haunted Gully to Tarrone 500 kV line

The following limit equations are enabled during an outage of the Moorabool to Haunted Gully or Haunted Gully to Tarrone 500 kV line.

32.1 Transient Stability – Vic to NSW

To manage the Victorian transient stability export limit from Victoria to NSW for fault and trip of a Hazelwood to South Morang 500 kV line, apply the following prior outage offsets to system normal equations NILV, NILQ, NILS and NILS decelerating. The limit equation is of the form:

$$\text{Victoria to NSW} \leq \text{Sum} [\text{Term Values} * \text{System Normal Coefficients}] + \text{Offset}$$

Table 54 V::N MLTS-TRTS_V/Q/S/S_decel offsets

| Term | Offset |
|---|---|
| Offset to system normal equation NILV | -30 |
| Offset to system normal equation NILQ | 0 |
| Offset to system normal equation NILS | 0 |
| Offset to system normal equation NILS_decel | N/A [VIC->SA transfer limited to 250MW] |

32.2 Voltage Unbalance

The following limit equations are enabled to manage the voltage unbalance at APD 500kV and Heywood 275kV buses:

$$4.73 \times \text{APD Net Load} + \text{Mortlake} + \text{Dundonnell generation} + 1.07 \times \text{Macarthur generation} + 2.4 \times \text{VIC to SA (Heywood)} \leq 4665$$

$$1.61 \times \text{APD Net Load} + 1.18 \times \text{Macarthur generation} + \text{VIC to SA (Heywood)} \leq 2146$$

32.3 Fault Levels

Limitation due to insufficient fault level for converter operation at Macarthur wind farm.

$$\text{Macarthur wind farm} \leq 0$$

33. Moorabool A2 Transformer 500/220 kV

The following limit equations are enabled during an outage of the Moorabool A2 500 kV transformer.

33.1 Transient Stability – Vic to NSW

To manage the Victorian transient stability export limit from Victoria to NSW for fault and trip of a Hazelwood to South Morang 500 kV line, apply the following prior outage offsets to system normal equations NILV, NILQ, NILS and NILS_decelerating. The limit equation is of the form:

$$\text{Victoria to NSW} \leq \text{Sum} [\text{Term Values} * \text{System Normal Coefficients}] + \text{Offset}$$

Table 55 V::N MLTS-A2_V/Q/S/S_decel offsets

| Term | Offset |
|---|--------|
| Offset to system normal equation NILV | -50 |
| Offset to system normal equation NILQ | 0 |
| Offset to system normal equation NILS | -40 |
| Offset to system normal equation NILS_decel | -50 |

34. Murraylink

34.1 Voltage Stability – Wemen to Kerang limit

To manage the Wemen to Kerang flow limit to prevent voltage collapse at Kerang or Wemen for the loss of the Crowlands to Bulgana to Horsham or Horsham to Murra Warra to Kiamal 220kV line apply the following prior outage offset to the system normal equation NIL_KERANG. The limit equation is of the form:

Table 56 V^{AN} MRLK_KERANG offset

| Term | Offset |
|------------------------------------|--------|
| Offset to system normal NIL_KERANG | -45 |

34.2 Voltage Stability – NSW to Vic

34.2.1 Largest Vic generator or Basslink trip

To manage the Victorian voltage stability import limit from NSW to Victoria for fault and trip of Basslink or the loss of the largest Victorian generator, apply the following prior outage offset to the system normal equation NIL_VI_BLVG. Studies monitored post-contingent voltages and reactive power margin in northern Victoria and southern NSW. The limit equation is of the form:

$$NSW\ to\ Victoria \leq [-1 * Sum [Term\ Values * System\ Normal\ Coefficients]] + Offset$$

Table 57 V^{AN} MRLK_BLVG offset

| Term | Offset |
|--|--------|
| Offset to system normal equation NIL_VI_BLVG | -100 |

34.2.2 Ballarat to Waubra to Ararat 220kV line trip

To manage the Victorian voltage stability import limit from NSW to Victoria for fault and trip of Ballarat to Waubra to Ararat 220kV line (this also trips Waubra, Ararat and Crowlands, Bulgana and Murra Warra WFs), apply the following prior outage offset to the system normal equation NIL_VI_ARWBBA. Studies monitored post-contingent voltages and reactive power margin in northern Victoria and southern NSW. The limit equation is of the form:

$$NSW\ to\ Victoria \leq [-1 * Sum [Term\ Values * System\ Normal\ Coefficients]] + Offset$$

Table 58 V^{AN} MRLK_ARWBBA offset

| Term | Offset |
|--|--------|
| Offset to system normal equation NIL_VI_ARWBBA | -100 |

35. Rowville to South Morang 500 kV line

The following limit equations are enabled during an outage of the Rowville to South Morang 500 kV line.

35.1 Transient Stability – Vic to NSW

To manage the Victorian transient stability export limit from Victoria to NSW for fault and trip of a Hazelwood to South Morang 500 kV line, apply the following prior outage offsets to system normal equations NILV, NILQ, NILS and NILS decelerating. The limit equation is of the form:

$$\text{Victoria to NSW} \leq \text{Sum [Term Values * System Normal Coefficients]} + \text{Offset}$$

Table 59 V::N ROTS-SMTS _V/Q/S/S_decel offsets

| Term | Offset |
|---|--------|
| Offset to system normal equation NILV | -230 |
| Offset to system normal equation NILQ | -100 |
| Offset to system normal equation NILS | -150 |
| Offset to system normal equation NILS_decel | -200 |

36. South Morang Series Capacitor

The following limit equations are enabled during an outage of one South Morang series capacitor.

36.1 Transient Stability – Vic to NSW

To manage the Victorian transient stability export limit from Victoria to NSW for fault and trip of a Hazelwood to South Morang 500 kV line, apply the following prior outage offsets to system normal equations NILV, NILQ, NILS and NILS decelerating. The limit equation is of the form:

$$\text{Victoria to NSW} \leq \text{Sum} [\text{Term Values} * \text{System Normal Coefficients}] + \text{Offset}$$

Table 60 V::N SMTS-CAP_V/Q/S/S_decel offsets

| Term | Offset |
|---|--------|
| Offset to system normal equation NILV | -50 |
| Offset to system normal equation NILQ | 0 |
| Offset to system normal equation NILS | -50 |
| Offset to system normal equation NILS_decel | -50 |

36.2 Voltage Stability – NSW to Vic

The system normal voltage stability equation NIL_VI_BLVG will manage voltage stability associated with the fault and trip of Basslink, the loss of the largest Victorian generator, the loss of a Dederang to Murray 330 kV line, the loss of a Dederang 330/220 kV transformer or the loss of the parallel Dederang to South Morang 330 kV line and series capacitor. Therefore no additional offset is required.

37. South Morang Substation No. 2 330 kV bus

The following limit equation is enabled during an outage of the South Morang B2 330 kV bus.

37.1 Transient Stability – Vic to NSW

37.1.1 Hazelwood to South Morang trip

To manage the Victorian transient stability export limit from Victoria to NSW for fault and trip of a Hazelwood to South Morang 500 kV line, apply the following prior outage offsets to SMTS F2 prior outage equations NILV, NILQ, NILS and NILS decelerating. The limit equation is of the form:

$$\text{Victoria to NSW} \leq \text{Sum} [\text{Term Values} * \text{SMTS F2 Prior Outage Coefficients}] + \text{Offset}$$

Table 61 V::N SMTS-B2_V/Q/S/S_decel offsets (HWTS-SMTS 500 kV fault)

| Term | Offset |
|--|--------|
| Offset to SMTS F2 prior outage equation NILV | -50 |
| Offset to SMTS F2 prior outage equation NILQ | 0 |
| Offset to SMTS F2 prior outage equation NILS | -50 |
| Offset to SMTS F2 prior outage equation NILS_decel | -50 |

37.1.2 South Morang to Thomastown trip

To manage the Victorian transient stability export limit from Victoria to NSW for fault and trip of the South Morang to Thomastown No 1 220 kV line, apply the following prior outage offsets to system normal equations NILV, NILQ, NILS and NILS decelerating. The limit equation is of the form:

$$\text{Victoria to NSW} \leq \text{Sum} [\text{Term Values} * \text{System Normal Coefficients}] + \text{Offset}$$

Table 62 V::N SMTS-B2_V/Q/S/S_decel offsets (SMTS-TTS 220 kV fault)

| Term | Offset |
|---|--------|
| Offset to system normal equation NILV | -20 |
| Offset to system normal equation NILQ | 0 |
| Offset to system normal equation NILS | -20 |
| Offset to system normal equation NILS_decel | 0 |

38. South Morang F2 Transformer 500 / 330 kV

The following limit equations are enabled during an outage of the South Morang F2 500 / 330 kV transformer.

38.1 Transient Stability – Vic to NSW

38.1.1 V::N SMTS-F2_V

To manage the Victorian transient stability export limit from Victoria to NSW for fault and trip of a Hazelwood to South Morang 500 kV line (where Victoria accelerates ahead of the other states), apply the following limit equation:

*Victoria to NSW \leq Sum [Term Values * Coefficients]*

Table 63 V::N SMTS-F2_V coefficients

| Term | Coefficient |
|---|-------------|
| Intercept | 929 |
| Basslink | 0.4031 |
| Vic. to SA (Heywood) | -0.1602 |
| Vic. to SA (Heywood)^2 | -8.24e-4 |
| Vic. to SA (Murraylink) | -1.09 |
| LV 500 Inertia | 7.414 |
| EPS Inertia | 18.68 |
| MOPS Inertia | 10.58 |
| LV 220 Inertia | 8.461 |
| SNOWY Inertia | 1.347 |
| VIC Metro Gen Inertia | 3.332 |
| Murray Gen | 0.766 |
| Kiewa Gen | 0.9235 |
| LV 220 Gen | 0.1746 |
| VIC Metro Gen | 0.4473 |
| State Grid Load North | -0.938 |
| APD Load | -0.7043 |
| Vic Wind & Solar | 0.32 |
| VIC Demand - State Grid Load North - APD Load | -0.3325 |
| 220 kV_Caps | -0.1765 |
| Num. ROTS SVC | 25.8 |
| Num. SESS SVC | 21.73 |
| Confidence Level (95%) offset | -92 |

38.1.2 V::N SMTS-F2_Q

To manage the Victorian transient stability export limit from Victoria to NSW for fault and trip of a Hazelwood to South Morang 500 kV line (where Queensland accelerates ahead of the other states), apply the following limit equation is of the form:

$$Victoria\ to\ NSW \leq Sum\ [Term\ Values * Coefficients]$$

Table 64 V::N SMTS-F2_Q coefficients

| Term | Coefficient |
|-------------------------------|-------------|
| Intercept | 1632 |
| Basslink | 0.5317 |
| Vic. to SA (Heywood) | -1.192 |
| Vic. to SA (Murraylink) | -0.8195 |
| LV 500 Inertia | 8.32 |
| MOPS Inertia | 9.365 |
| Murray Gen | 0.9399 |
| Kiewa Gen | 0.9622 |
| LV 220 Gen | 0.425 |
| State Grid Load | -0.663 |
| Vic Wind & Solar | 0.4482 |
| VIC Demand – State Grid Load | -0.5102 |
| Confidence Level (95%) offset | -80 |

Note: this equation should only be applied when power transfers are above 900 MW from Queensland to New South Wales

38.1.3 V::N SMTS-F2_S

To manage the Victorian transient stability export limit from Victoria to NSW for fault and trip of a Hazelwood to South Morang 500 kV line (where Queensland accelerates ahead of the other states), apply the following limit equation is of the form:

$$Victoria\ to\ NSW \leq Sum\ [Term\ Values * Coefficients]$$

Table 65 V::N SMTS-F2_S coefficients

| Term | Coefficient |
|---|-------------|
| Intercept | 833.3 |
| Basslink | 0.4764 |
| Vic. to SA (Heywood) | -0.4127 |
| Vic. to SA (Heywood)^2 | -5.93e-4 |
| Vic. to SA (Murraylink) | -1.017 |
| LV 500 Inertia | 7.366 |
| EPS Inertia | 22.56 |
| MOPS Inertia | 9.875 |
| LV 220 Inertia | 9.283 |
| VIC METRO Gen Inertia | 10.06 |
| Murray Gen | 0.8986 |
| Kiewa Gen | 1.04 |
| LV 220 Gen | 0.2476 |
| State Grid Load North | -0.9763 |
| APD Load | -0.2712 |
| Vic Wind & Solar | 0.4478 |
| VIC Demand - State Grid Load North - APD Load | -0.3879 |
| 220 kV_Caps | -0.1567 |
| Num. ROTS SVC | 26.67 |
| Num. SESS SVC | 21.68 |
| Confidence Level (95%) offset | -82 |

Note: this equation should only be applied when power transfers are from South Australia to Victoria

38.1.4 V::N SMTS-F2_S_decel

To manage the Victorian transient stability export limit from Victoria to NSW for fault and trip of a Hazelwood to South Morang 500 kV line (where South Australia decelerates away from the other states), apply the following limit equation:

$$\text{Victoria to NSW} \leq \text{Sum} [\text{Term Values} * \text{Coefficients}]$$

Table 66 V::N SMTS-F2_S_decel coefficients

| Term | Coefficient |
|---|-------------|
| Intercept | 709.7 |
| Basslink | 0.4699 |
| Vic. to SA (Heywood)^2 | -0.00161 |
| Vic. to SA (Murraylink) | -1.128 |
| LV 500 Inertia | 9.785 |
| MOPS Inertia | 13.05 |
| KIEWA Inertia | 19.58 |
| VIC Metro Gen Inertia | 11.25 |
| Murray Gen | 0.833 |
| LV 220 Gen | 0.5818 |
| State Grid Load North | -0.5924 |
| APD Load | -0.4469 |
| Vic Wind & Solar | 0.4344 |
| VIC Demand - State Grid Load North - APD Load | -0.4643 |
| Confidence Level (95%) offset | -123 |

Note: this equation should only be applied when power transfers from Victoria to South Australia are above 500 MW.

38.2 Voltage Stability – NSW to Vic

38.2.1 Largest Vic generator or Basslink trip

To manage the Victorian voltage stability import limit from NSW to Victoria for fault and trip of Basslink or the loss of the largest Victorian generator, apply the following prior outage offset to the system normal equation NIL_VI_BLVG. Studies monitored post-contingent voltages and reactive power margin in northern Victoria and southern NSW. The limit equation is of the form:

$$NSW\ to\ Victoria \leq [-1 * Sum [Term\ Values * System\ Normal\ Coefficients]] + Offset$$

Table 67 V^N SMTS_F2_BLVG offsets

| Term | Offset |
|--|--------|
| Offset to system normal equation NIL_VI_BLVG | -120 |

38.2.2 Dederang to Murray 330 kV line trip

The system normal voltage stability equation NIL_VI_BLVG will manage voltage stability associated with the loss of a Dederang to Murray 330 kV line. Therefore no additional offset is required.

39. South Morang H1 or H3 Transformer 330 / 220 kV

The following limit equations are enabled during an outage of the South Morang H1 or H3 330/220 kV transformer.

39.1 Voltage Stability – NSW to Vic

The system normal voltage stability equation NIL_VI_BLVG will manage voltage stability associated with the fault and trip of Basslink, the loss of the largest Victorian generator, the loss of a Dederang to Murray 330 kV line, the loss of a Dederang to South Morang 330 kV line, the loss of the parallel H3 or H1 transformer, the loss of the F2 transformer, or the loss of a Dederang transformer. Therefore no additional offset is required.

40. South Morang to Sydenham 500 kV line

The following limit equations are enabled during an outage of the South Morang to Sydenham 500 kV line.

40.1 Transient Stability – Vic to NSW

To manage the Victorian transient stability export limit from Victoria to NSW for fault and trip of a Hazelwood to South Morang 500 kV line, apply the following prior outage offsets to system normal equations NILV, NILQ, NILS and NILS decelerating. The limit equation is of the form:

$$\text{Victoria to NSW} \leq \text{Sum} [\text{Term Values} * \text{System Normal Coefficients}] + \text{Offset}$$

Table 68 V::N SMTS-SYTS_V/Q/S/S_decel offsets

| Term | Offset |
|---|--------|
| Offset to system normal equation NILV | -50 |
| Offset to system normal equation NILQ | 0 |
| Offset to system normal equation NILS | -20 |
| Offset to system normal equation NILS_decel | -100 |

41. South Morang to Thomastown 220 kV line

The following limit equations are enabled during an outage of one South Morang to Thomastown 220 kV line.

41.1 Transient Stability – Vic to NSW

To manage the Victorian transient stability export limit from Victoria to NSW for fault and trip of a Hazelwood to South Morang 500 kV line, apply the following prior outage offsets to system normal equations NILV, NILQ, NILS and NILS decelerating. The limit equation is of the form:

$$\text{Victoria to NSW} \leq \text{Sum} [\text{Term Values} * \text{System Normal Coefficients}] + \text{Offset}$$

Table 69 V::N SMTS-TTS_V/Q/S/S_decel offsets

| Term | Offset |
|---|--------|
| Offset to system normal equation NILV | -30 |
| Offset to system normal equation NILQ | 0 |
| Offset to system normal equation NILS | -30 |
| Offset to system normal equation NILS_decel | -30 |

A1. Measures and Definitions

Units of Measure

| Abbreviation | Unit of measure |
|---------------|--|
| kV | Kilovolt |
| MVA | Megavolt amperes |
| MVAR | Megavolt amperes reactive |
| MW | A Megawatt (MW) is one million watts. A watt (W) is a measure of power and is defined as one joule per second and it measures the rate of energy conversion or transfer. |
| MW.sec | Megawatt seconds – a measure of the inertia of a generating unit. |

Parameter Definitions

| Abbreviation | Definition |
|----------------------|---|
| 220 kV Caps | MVAR output from capacitors connected at 220 kV busbars (i.e. Altona, Brooklyn, Dederang, Fishermans Bend, Keilor, Moorabool, Rowville, Ringwood, Templestowe and Thomastown) |
| APD-HYTS_MVAR | Alcoa Portland smelter (APD) reactive power export (measured at 500 kV feeders). A negative value indicates that APD is importing MVar. |
| APD-HYTS_MW | APD real power export (measured at 500 kV feeders. A negative value indicates that APD is importing MW). |
| APD Load | APD MW load at 33 kV and 22 kV |
| APD Net Load | Net load measured at APD 500kV bus (Actual APD load consumption – Portland wind farm generation) |
| BANReac | MVAR output of Bannaby reactors. Values associated with this term are negative. |
| Basslink | MW flow on the Basslink interconnector (measured at the receiving end) |
| BATS TX MW | MW flow through 220/66kV transformers at Ballarat (measured at HV side, positive value indicates load MW) |
| BETS Load | Bendigo (BETS) customer load (MW) |
| BHSS220 Load | Broken Hill 220 kV MW industrial (mine) load |
| BKNH GEN | MW output from Broken Hill Generation |

| Abbreviation | Definition |
|---------------------------------------|---|
| BRKNHLSF_SilvWF | MW output from Broken Hill SF and Silverton WF |
| BKNH TX MW | MW flow through 220/22kV transformers at Broken Hill (measured at HV side, positive value indicates load MW) |
| BOPS+MKPS GEN | MW output from Bogong and McKay Power Station [BOPS & MKPS]. |
| Both TAIL-SESS Series Caps Out | Both Tailem Bend – South East series caps out of service (1= Both series caps are out of service) |
| BRGAshnt | MVAR output of Buronga shunt devices. Values associated with this term can be positive or negative |
| CANCap | MVAR output of Canberra 220 kV capacitor banks. Values associated with this term are positive. |
| CMACap | MVAR output of Cooma capacitor banks. Values associated with this term are positive. |
| Constraint equation | These are the mathematical representations that AEMO uses to model power system limitations and FCAS requirements in National Electricity Market Dispatch Engine (NEMDE). |
| Contingent MW | Maximum of: <ul style="list-style-type: none"> a) MW Transfer from Tas to Vic via Basslink (measured at Loy Yang). Values associated with this term are positive for flows from Tas to Vic. b) MW output of a single generating unit in Vic (MW associated with the contingency: Loss of the Largest Generator). Values associated with this term are positive. |
| CUECap | MVAR output of Queanbeyan capacitor banks. Values associated with this term are positive. |
| DARL_PT_3WTX_MW | MW flow through 3 winding 330/220/33 transformers at Darlington point measured at 330kV transformer terminal with positive values indicate MW flow into transformers from 330kV side. |
| DARL_PT_3WTX_MVAR | MVAR flow through 3 winding 330/220/33 transformers at Darlington point measured at 330kV transformer terminal with positive values indicate MVAR flow into transformers from 330kV side. |
| DD220Cap | MVAR output of Dederang 220 kV capacitor banks. Values associated with this term are positive. |
| DD330Cap | MVAR output of Dederang 330 kV capacitor banks. Values associated with this term are positive. |
| DLPTshunt | MVAR output of Darlington Point shunt devices. Values associated with this term can be positive or negative |
| DPS GEN | MW output from Dartmouth Power Station [DPS]. |
| EPS Inertia | Inertia from Eildon Power Station (EPS). Inertia is on a 100 MVA base (MW.sec / 100 MVA) as per EMS. |
| GEN EPS on | Number of Eildon Power station (EPS) units online. |
| GEN DPS on | Number of Dartmouth Power station units online [DPS]. |
| GEN BOPS on | Number of Bogong Power station units online [BOPS]. |
| Gen_Lower_NW_VIC_MW | Sum of generation MW output from lower NorthWest Victoria wind farms including Ararat WF, Bulgana WF, Crowlands WF, Kiata WF, Murra Warra WF, Waubra WF. |
| GEN MKPS on | Number of McKay Power station units online [MKPS]. |
| GEN WKPS on | Number of West Kiewa Power station units online [WKPS]. |
| Gen_Upper_NW_VIC_MW | Sum of generation MW output from upper NorthWest Victoria wind and solar farms including Bannerton SF, Cohuna SF, Gannawarra SF, Gannawarra Battery, Karadoc SF, Kiamal SF, Wemen SF, Yatpool SF |

| Abbreviation | Definition |
|--------------------------------|---|
| Guthega GEN | MW output from Guthega Power Station [GGA]. |
| Guthega Inertia | Inertia from Guthega Power Station [GGA]. Inertia is on a 100 MVA base (MW.sec / 100 MVA) as per EMS. |
| HOTS Load | Horsham (HOTS) customer load (MW) |
| HOTS SVC out of service | Horsham SVC out of service, This term is equal to 0 when the SVC is in service, and equal to 1 when the SVC is out of service. |
| HOTS_TX1_TX2 MW | Sum of MW flow on Horsham B2 and B3 220/66 kV transformers. Positive value indicates power flow from HV to LV side. |
| HOTS_TX1_TX2 MVAR | Sum of MVAR flow on Horsham B2 and B3 220/66 kV transformers. Positive value indicates power flow from HV to LV side. |
| HOTS-66REC | MVAR output from Horsham 66kV reactor. Values associated with this term are negative. |
| HOTS-66CAP | MVAR output from Horsham 66kV Capacitor. Values associated with this term are positive. |
| HUME VIC GEN | MW output from Hume Power station (Victorian connection) |
| HYTS_CAP_Status | Heywood capacitor status (1 = capacitor in service). |
| JBE Pump | MW at Jindabyne Power Station [JBE]. Values associated with this term are negative. |
| KGTS Load | Kerang (KGTS) customer load (MW) |
| KGTS SVC MVAR | MVAR flow through SVC installed at Kerang. |
| KGTS SVC out of service | Kerang SVC out of service, This term is equal to 0 when the SVC is in service, and equal to 1 when the SVC is out of service. |
| Kiewa Gen | MW output from Kiewa hydro scheme generators (Bogong, Clover, Dartmouth, McKay and West Kiewa). |
| Kiewa Inertia | Inertia from Kiewa hydro scheme generators (Bogong, Clover, Dartmouth, McKay and West Kiewa). Inertia is on a 100 MVA base (MW.sec / 100 MVA). |
| L_TUMUT_Gen | MW output from Lower Tumut 3 power station (LTSS). Values associated with this term can be positive or negative due to the ability of Lower Tumut units to operate in pumping mode |
| LTUM3SC | Number of generator units operating as synchronous condensers at Lower Tumut. |
| LV 220 Gen | MW output from Latrobe Valley generation on the 220 kV network (Yallourn W2, 3, and 4, and Yallourn unit 1 when connected to the 220 kV network). |
| LV 220 Inertia | Inertia associated with Latrobe Valley generation on the 220 kV network (Yallourn W2, 3, and 4, and Yallourn unit 1 when connected to the 220 kV network). |
| LV 500 Inertia | Inertia associated with Latrobe Valley generation on the 500 kV network (Loy Yang (A, B, and Valley Power), Jeeralang, Bairnsdale, and Yallourn W unit 1 when connected to the 500 kV network). |
| MCAR_Gen | MW output from the Macarthur Wind Farm (MCAR). |
| MLTS_220_Reactors | Count of MLTS 220 kV reactors. |
| MLTS_Line_Reactors | Count of MLTS line reactors (2=both reactors in service). |
| MMWF_Gen | MW output from the Mount Mercer Wind Farm (MMWF). |

| Abbreviation | Definition |
|---|--|
| MOPS Inertia | Inertia from Mortlake Power Station (MOPS). Inertia is on a 100 MVA base (MW.sec / 100 MVA) as per EMS. |
| MSS2SC | Number of generator units operating as synchronous condensers at Murray 2. |
| MSSReac | MVAR output of Murray reactors. Values associated with this term are negative. |
| Murray Gen | MW output from Murray Power Station (Murray 1 and Murray 2). |
| Num. MSS1 on | Number of generator units operating at Murray 1. |
| Num. ROTS SVC | Number of Static Var Compensators (SVCs) at Rowville in service. |
| Num. SESS SVC | Number of SVCs at South East in service. |
| NSW_D | New South Wales demand |
| NSWd- SW_NSW | NSW demand (customer load + losses) minus the load in southern NSW. |
| NSW_H | Inertia of New South Wales generators excluding Murray, Lower Tumut and Upper Tumut (Eraring, Vales Point, Bayswater, Munmorah, Redbank, Mt Piper, Liddell, Bendeela, Kangaroo Valley, Colongra, Tallawarra, Uranquinty) |
| Parallel System | Victorian system operating in "Parallel" mode, This term is equal to 0 when operating in radial mode, and equal to 1 when operating in parallel mode. |
| Portland WF | Portland wind farm generation, MW |
| QLD_H | Inertia of Queensland generators (Swanbank B, Gladstone, Tarong, Wivenhoe, Callide B, Stanwell, Callide C, Tarong North, Swanbank E, Barcaldine, Barron Gorge, Callide A, Collinsville, Invicta, Kareeya, Mackay, Mt Stuart, Townsville, Oakey, Millmerran, Braemar, Darling Downs, Condamine, Braemar 2, Kogan Creek) |
| Q2-BURNGA 220 | MVAR output from the two line reactors on the X2 and X3 line at Buronga. Values associated with this term are negative. |
| Q3-REDCLF 220 | MVAR output from Redcliff Capacitor at 220kV bus. Values associated with this term are positive. |
| RCTS Load | Red Cliffs (RCTS) customer load (MW) |
| RCTS-MLK_MVAR | MVAR flow from Redcliff to Murraylink 220kV line. Measured at Redcliff. Flow is positive from Redcliff to Murraylink. |
| Rowville SVC1 or SVC2 out of service | Rowville SVC out of service, This term is equal to 0 when the SVC is in service, and equal to 1 when one SVC is out of service. |
| SNOWY Inertia | Inertia from the Snowy area (Murray, Lower Tumut and Upper Tumut). Inertia is on a 100 MVA base (MW.sec / 100 MVA). |
| SNOWY_GSC_H | Inertia of Snowy generation (Murray, Guthega, Lower Tumut and Upper Tumut) minus the inertia of Lower Tumut machines running as pumps. Inertia is on a 100 MVA base (i.e. MW.sec / 100 MVA). |
| State Grid Load | Vic State Grid Load. This is the sum of the State Grid Load North (SGLN) and State Grid Load South (SGLS). |
| State Grid Load North | Vic State Grid Load north is the sum of load at the following bulk supply points: Bendigo (BETS), Fosterville (FVTS), Glenrowan (GNTS), Kerang (KGTS), Mt Beauty (MBTS), Red Cliffs (RCTS), Shepparton (SHTS), Wemen (WETS), and Wodonga (WOTS) |
| State Grid Load South | Vic State Grid Load south is the sum of load at the following bulk supply points: Ararat (ARTS), Ballarat (BATS), Horsham (HOTS), Stawell (STA) and Terang (TGTS). |

| Abbreviation | Definition |
|--|--|
| SW_NSW | Load in Southern NSW is the sum of customer load at the following bulk supply points: Broken Hill (BKH_S1-22 and BKH-220), Gadara (GAD-11), Jounama (JOU-66), Darlington Point (DLP-132), Morven (MOR-132), Albury (ALB-132), AMN-132, Coleambally (CLY-132), Marulan (MRN-132, GOU-132), Wagga (WAN-132, WAN-66, WAW-132), Murrumburrah (MRU-66), Deniliquin (DNQ-66), Yass (YAS-66), Balranald (BRD-22), Finley (FNY-132), Griffith (GRF-132), Mulwala (MUL-132), Corowa (COR-132), and Yanco (YNC-33) |
| STH_NSW_GEN | Generation in southern NSW. Values associated with this term are positive. Generation in this region are Gullen Range WF, Gullen SF, Capital WF, Cullerin Range WF, Coleambally SF, Gunning WF, Boco Rock WF, Taralga WF, Woodlawn WF, Burrinjuck Hydro, Blowering Hydro, Gadara, and Jounama Hydro Embedded generation |
| System normal | The configuration of the power system where: <ul style="list-style-type: none"> a) All transmission elements are in service, or b) The network is operating in its normal network configuration. |
| TNSP | Transmission Network Service Provider |
| Tumut Pump | MW of Lower Tumut machines in pumping mode (this MW value is negative). |
| UQT Gen | MW output from Uranquinty (UQT) Power Station. |
| U_TUMUT_Gen | MW output from Upper Tumut 1 and Upper Tumut 2 Power Station (UTSS). |
| UTUM1SC+UTUM2SC | Number of generator units operating as synchronous condensers at Upper Tumut 1 and Upper Tumut 2. |
| V_MLTS5 | MLTS 500 kV voltage (typical values between 450 and 550 kV). |
| V_MSS3330 | Voltage (kV) at the Murray Power Station 330 kV bus. |
| VIC220_Gen | MW output from Latrobe Valley generation on the 220 kV network (Yallourn W units 2, 3 and 4 and unit 1 when connected to 220 kV network). |
| Vic Demand | Vic MW demand (calculated as generation minus export). |
| Vic to SA (Heywood) | MW transfer from Vic to SA via Heywood (measured at South East end). The interconnector direction and lines it consists of follow the NEM standard. |
| Vic to SA (Murraylink) | MW transfer from Vic to SA via Murraylink (measured at Red Cliffs end). |
| VIC to NSW | MW transfer from Vic to NSW |
| Vic Demand - State Grid Load | Vic Demand (MW) minus Vic State Grid Load (SGL). |
| Vic Demand - State Grid Load North – APD Load | Vic Demand (MW) minus Vic State Grid Load North (SGLN) minus APD Load. |
| Vic Metro Gen | MW output from Vic metropolitan generators (Newport, Somerton, and Laverton North). |
| Vic Metro Gen Inertia | Inertia from Vic metropolitan generators (Newport, Somerton and Laverton North). Inertia is on a 100 MVA base (MW.sec / 100 MVA) as per EMS. |
| Vic Wind & Solar | MW Generation from all Vic windfarms and solar plant. This includes Ararat WF, Bald Hills WF, Ballarat Battery (Gen Component), Bannerton SF, Bulgana WF, Challcum Hills WF, Crowlands WF, Gannawarra Battery (Gen component), Gannawarra SF, Karadoc SF, Kiata WF, Macarthur WF, Moorabool WF, Mortons Lane WF, Mount Gelibrand WF, Mount Mercer WF, Murra Warra WF, Numerkah SF, Oaklands Hill WF, Portland WF, Salt Creek WF, Waubra WF, Wemen SF, Yaloak South WF, Yambuk WF, Yatpool SF and Yendon SF |

| Abbreviation | Definition |
|------------------|--|
| WAGGACap | MVAR output of Wagga Wagga capacitor banks. Values associated with this term are positive. |
| WKPS GEN | MW output from West Kiewa Power Station [WKPS]. |
| WETS Load | Wemen (WETS) customer load (MW) |
| WOTSCap | MVAR output of Wodonga capacitor banks. Values associated with this term are positive. |
| YASSCap | MVAR output of Yass capacitor banks. Values associated with this term are positive. |
| YASSReac | MVAR output of Yass reactors. Values associated with this term are negative. |

Glossary

This document uses many terms that have meanings defined in the National Electricity Rules (NER). The NER meanings are adopted unless otherwise specified.

| Term | Definition |
|----------------------------|--|
| Constraint equation | These are the mathematical representations that AEMO uses to model power system limitations and FCAS requirements in National Electricity Market Dispatch Engine (NEMDE). |
| System normal | The configuration of the power system where: <ul style="list-style-type: none">• All transmission elements are in service, or• The network is operating in its normal network configuration |
| TNSP | Transmission Network Service Provider |