


# Marginal Loss Factors: Financial Year 2022-23

April 2022

A report for the National Electricity  
Market





# Important notice

## Purpose

This document has been prepared by AEMO as the 'Regions Publication' under clause 2A.1.3 of the National Electricity Rules (Rules), and to inform Registered Participants of the 2022-23 inter-regional loss equations under clause 3.6.1 of the Rules and 2022-23 intra-regional loss factors under clause 3.6.2 of the Rules. This document has effect only for the purposes set out in the Rules.

The Rules and the National Electricity Law (Law) prevail over this document to the extent of any inconsistency.

## Disclaimer

The calculation of the loss factors presented in this document incorporates information and forecasts from third parties. AEMO has made every reasonable effort to ensure the quality of the information in this publication but cannot guarantee that any information, forecasts and assumptions are accurate, complete or appropriate for your circumstances.

Explanatory information in this document does not constitute legal or business advice, and should not be relied on as a substitute for obtaining detailed and specific advice about the Law, the Rules, any other applicable laws, procedures or policies or the future development of the National Electricity Market power system. Accordingly, to the maximum extent permitted by law, AEMO and its officers, employees and consultants involved in the preparation of this document:


- make no representation or warranty, express or implied, as to the currency, accuracy, reliability or completeness of the information in this document; and
- are not liable (whether by reason of negligence or otherwise) for any statements, opinions, information or other matters contained in or derived from this document, or any omissions from it, or in respect of a person's use or reliance on the information in it.

## Copyright

© 2022 Australian Energy Market Operator Limited. The material in this publication may be used in accordance with [the copyright permissions on AEMO's website](#).

## Version control

| Version | Release date | Changes  |
|---------|--------------|--|
| 1       | 1/4/2022     | Final 2022-23 MLFs published   |
| 2       | 6/4/2022     | Removed incorrect statement from Appendix A2.4 relating to limits under review   |
| 3       | 13/07/2022   | <ul style="list-style-type: none"><li>• July 2022 including the following new and revised connection points:</li><li>• QLD Generation: Columboola Solar Farm, Woolooga Solar Farm</li><li>• SA Generation: Happy Valley BESS, Happy Valley Solar Farm , Christies Beach BESS, Christies Beach Biogas, Christies Beach Diesel 1, Christies Beach Diesel 2, Christies Beach Solar 1, Christies Beach Solar 2, Mannum-Adelaide Pipeline Pumping Station No 3 Solar Farm</li><li>• NSW Generation: Queanbeyan BESS</li></ul> |



| Version | Release date | Changes  |
|---------|--------------|--|
|         |              | <ul style="list-style-type: none"><li>• ACT Generation: Mugga Lane Landfill</li><li>• VIC Generation: Mortlake South Wind Farm</li><li>• TAS Load: Fisher 220 DNSP</li></ul> |

# Introduction

This document sets out the 2022-23 National Electricity Market (NEM) intra-regional loss factors, commonly referred to as marginal loss factors (MLFs), calculated under clause 3.6.2 of the National Electricity Rules (Rules). MLFs represent electrical transmission losses within each of the five regions in the NEM – Queensland, New South Wales, Victoria, South Australia, and Tasmania.

As well as the MLFs, this document provides the following information for the 2022-23 financial year:

- Connection point transmission node identifiers (TNIs),
- Virtual transmission nodes (VTNs),
- NEM inter-regional loss factor equations and loss equations calculated under clause 3.6.1 of the Rules.

This document also serves as the Regions Publication under clause 2A.1.3 of the Rules, providing the following information for the 2022-23 financial year:

- Regions.
- Regional reference nodes (RRNs).
- Region boundaries.

Loss factors apply for 2022-23 only, and should not be relied on as an indicator for future years.

## Context

In recent years, supply and demand patterns in the NEM have been changing at an increasing rate, driven by new technology and a changing generation mix. This has led to large year-on-year changes in MLFs, particularly in areas of high renewable penetration that are electrically weak and remote from load centres.

The large year-on-year changes in MLFs demonstrate the ongoing need for comprehensive planning of both generation and transmission to minimise costs to consumers. All-of-system planning documents, such as the Integrated System Plan (ISP)<sup>1</sup>, are critical in the provision of information to participants regarding the needs of, and changes to, the power system.

## Improving transparency

In December 2021, AEMO published a preliminary report on MLFs for 2022-23<sup>2</sup>, intended to provide an early indication to stakeholders of both the potential direction and extent of movement in MLFs across the NEM between 2021-22 and 2022-23. The preliminary report was based on a limited study using some inputs from the 2021-22 study with generation profiles updated to reflect committed generation as of August 2021.

---

<sup>1</sup> Available at <https://www.aemo.com.au/energy-systems/major-publications/integrated-system-plan-isp>.

<sup>2</sup> At <https://www.aemo.com.au/energy-systems/electricity/national-electricity-market-nem/market-operations/loss-factors-and-regional-boundaries>.



### Structure of the report

This document has been structured as follows:

- Section 1 outlines the MLFs for loads and generators in 2022-23.
- Section 2 summarises the key changes that have been observed in MLFs between 2021-22 and 2022-23.
- Section 3 outlines the inter-regional loss factor equations for 2022-23.
- Section 4 outlines the inter-regional loss equations for 2022-23.
- Section 5 outlines the Basslink, Murraylink and Terranora loss equations for 2022-23.
- Section 6 outlines the proportioning of inter-regional losses to regions for 2022-23.
- Section 7 defines the regions and regional reference nodes for 2022-23.
- Section 8 outlines the virtual transmission nodes for 2022-23.
- Appendix A1 provides a background to MLFs.
- Appendix A2 outlines the methodology, inputs, and assumptions that have been used to determine the MLFs for 2022-23.

### Quality control

AEMO applied a number of quality assurance steps when calculating the 2022-23 MLFs. These included engaging an independent consultant to review the quality and accuracy of the MLF calculation process. The consultant is satisfied that AEMO is appropriately applying the published Methodology based on the data provided by registered participants, historical market data, and AEMO's electricity consumption forecasts, and a review of the process applied to the calculation of MLF values.

### Changes since draft report

AEMO published a draft report on 2022-23 MLFs on 1 March 2022, and sought feedback from stakeholders.

AEMO made a number of minor improvements to modelling compared to the study used for the draft report, as part of the quality assurance steps undertaken. This has resulted in a small number of connection points having a minor change in the final MLF value when compared to the draft report.

### Observations and trends

For the 2022-23 MLF study, the primary observation is that new committed generation expected to become operational over the 2022-23 financial year is predominantly located within Queensland and New South Wales.

Within New South Wales, the new generation capacity has been largely spread across central and northern areas, whereas over the last several years a large portion of the new generation capacity has been located within the south-west and south New South Wales. This has resulted in a slight increase of MLFs for certain generators in south-west New South Wales which have been trending downward for the last several years as the capacity of generation within this sub-region grew.

The output of thermal generation continues to decrease, offset by low marginal cost renewable generation. Additionally, the Liddell closure is forecast to occur within 2022-23 resulting in a reduction of the capacity of thermal generation within New South Wales.

# Contents

|   |    |
|---|----|
| Introduction  | 4  |
| 1 Marginal loss factors by region   | 9  |
| 1.1 Queensland marginal loss factors  | 9  |
| 1.2 New South Wales marginal loss factors                                   | 16 |
| 1.3 Victoria marginal loss factors  | 24 |
| 1.4 South Australia marginal loss factors                                   | 30 |
| 1.5 Tasmania marginal loss factors  | 35 |
| 2 Changes in marginal loss factors  | 38 |
| 2.1 Marginal loss factors in the NEM  | 38 |
| 2.2 Reasons marginal loss factors change                                    | 38 |
| 2.3 Changes between the preliminary 2022-23 MLFs and the final 2022-23 MLFs | 39 |
| 2.4 Changes between 2021-22 MLFs and 2022-23 MLFs                           | 39 |
| 3 Inter-regional loss factor equations                                      | 48 |
| 4 Inter-regional loss equations   | 52 |
| 5 Basslink, Murraylink, Terranora loss equations                            | 55 |
| 5.1 Basslink  | 55 |
| 5.2 Murraylink  | 56 |
| 5.3 Terranora   | 58 |
| 6 Proportioning of inter-regional losses to regions                         | 60 |
| 7 Regions and regional reference nodes                                      | 61 |
| 7.1 Regions and Regional Reference Nodes                                    | 61 |
| 7.2 Region boundaries   | 61 |
| 8 Virtual transmission nodes  | 63 |
| 8.1 New South Wales virtual transmission nodes                              | 63 |
| 8.2 South Australia virtual transmission nodes                              | 63 |
| 8.3 Tasmania virtual transmission nodes                                     | 63 |
| A1. Background to marginal loss factors                                     | 64 |
| A1.1 Rules requirements   | 64 |
| A1.2 Application of marginal loss factors                                   | 65 |
| A2. Methodology, inputs, and assumptions                                    | 67 |
| A2.1 Marginal loss factors calculation methodology                          | 67 |
| A2.2 Load data requirements for the MLF calculation                         | 67 |
| A2.3 Generation data requirements for the MLF calculation                   | 68 |
| A2.4 Intra-regional limit management  | 70 |

|      |   |    |
|------|---|----|
| A2.5 | Network representation in the marginal loss factors calculation | 71 |
| A2.6 | Interconnector capacity   | 74 |
| A2.7 | Calculation of MLFs   | 74 |
| A3.  | Impact of technology on MLF outcomes                            | 76 |
|      | Glossary  | 78 |

## Tables

|          |   |    |
|----------|---|----|
| Table 1  | Queensland loads  | 9  |
| Table 2  | Queensland generation   | 12 |
| Table 3  | New South Wales loads   | 16 |
| Table 4  | New South Wales generation  | 20 |
| Table 5  | ACT loads   | 24 |
| Table 6  | ACT generation  | 24 |
| Table 7  | Victoria loads  | 24 |
| Table 8  | Victoria generation   | 26 |
| Table 9  | South Australia loads   | 30 |
| Table 10 | South Australia generation  | 32 |
| Table 11 | Tasmania loads  | 35 |
| Table 12 | Tasmania generation   | 36 |
| Table 13 | Preliminary vs draft/final study variations   | 39 |
| Table 14 | Queensland sub-region year-on-year average MLF variation  | 41 |
| Table 15 | New South Wales sub-region year-on-year average MLF variation   | 43 |
| Table 16 | Victoria sub-region year-on-year average MLF variation  | 44 |
| Table 17 | South Australia sub-region year-on-year average MLF variation   | 46 |
| Table 18 | Tasmania sub-region year-on-year average MLF variation  | 47 |
| Table 19 | South Pine 275 referred to Sydney West 330 MLF versus New South Wales to Queensland flow coefficient statistics | 49 |
| Table 20 | Sydney West 330 referred to Thomastown 66 MLF versus Victoria to New South Wales flow coefficient statistics    | 50 |
| Table 21 | Torrens Island 66 referred to Thomastown 66 MLF versus Victoria to South Australia flow coefficient statistics  | 51 |
| Table 22 | Regression statistics for Murraylink  | 56 |
| Table 23 | Regression statistics for Terranora   | 58 |
| Table 24 | Factors for inter-regional losses   | 60 |
| Table 25 | Regions and Regional Reference Nodes  | 61 |
| Table 26 | New South Wales virtual transmission nodes  | 63 |

|          |                                      |    |
|----------|--------------------------------------|----|
| Table 27 | Tasmania virtual transmission nodes  | 63 |
| Table 28 | Operational demand                   | 67 |
| Table 29 | Inter-regional limits                | 74 |
| Table 30 | Impact of technology on MLF outcomes | 77 |

## Figures

|           |  |    |
|-----------|--|----|
| Figure 1  | 2021-22 vs 2022-23 MLF interconnector flow projections                                     | 40 |
| Figure 2  | Queensland changes compared to 2022-23 MLFs  | 41 |
| Figure 3  | New South Wales changes compared to 2022-23 MLFs   | 43 |
| Figure 4  | Victoria changes compared to 2022-23 MLFs  | 44 |
| Figure 5  | South Australia changes to 2022-23 MLFs  | 45 |
| Figure 6  | Tasmania changes to 2022-23 MLFs   | 47 |
| Figure 7  | MLF (South Pine 275 referred to Sydney West 330)   | 49 |
| Figure 8  | MLF (Sydney West 330 referred to Thomastown 66)  | 50 |
| Figure 9  | MLF (Torrens Island 66 referred to Thomastown 66)  | 51 |
| Figure 10 | Average losses for New South Wales – Queensland notional link                              | 53 |
| Figure 11 | Average losses for Victoria - New South Wales notional link                                | 53 |
| Figure 12 | Average losses for Victoria – South Australia notional link                                | 54 |
| Figure 13 | Basslink loss factor model   | 55 |
| Figure 14 | Murraylink MLF (Torrens Island 66 referred to Thomastown 66)                               | 57 |
| Figure 15 | Average losses for Murraylink interconnector (Torrens Island 66 referred to Thomastown 66) | 57 |
| Figure 16 | Terranora interconnector MLF (South Pine 275 referred to Sydney West 330)                  | 59 |
| Figure 17 | Average losses for Terranora interconnector (South Pine 275 referred to Sydney West 330)   | 59 |
| Figure 18 | MLFs greater than 1.0 simplified   | 65 |
| Figure 19 | MLFs less than 1.0 simplified  | 66 |
| Figure 20 | Time of day average economic curtailment for 2022-23                                       | 69 |
| Figure 21 | Time-of-day impact of technology on MLF outcomes   | 77 |



# 1 Marginal loss factors by region

This section shows the intra-regional loss factors, commonly known as marginal loss factors (MLFs), for financial year 2022-23, for every existing load or generation transmission connection point (identified by transmission node identifier [TNI] or dispatchable unit identifier [DUID]) in each NEM region. As required by clause 3.6.2 of the National Electricity Rules (Rules), these MLFs have been calculated in accordance with AEMO's published Forward Looking Loss Factor Methodology (Methodology).

The generation profiles for committed but not yet NEM registered projects are included in the MLF calculation, however AEMO does not publish MLFs for connection points relating to projects whose registration has not been completed as at the date of publication. On registration, AEMO will publish MLFs for those connection points. MLF updates and additions that are developed throughout the year will be included in the "2022-23 MLF Applicable from 1 July 2022" spreadsheet, which is also published on AEMO's website<sup>3</sup>.

## 1.1 Queensland marginal loss factors

Table 1 Queensland loads

| Location                         | Voltage [kV] | TNI code | 2022-23 MLF | 2021-22 MLF |
|----------------------------------|--------------|----------|-------------|-------------|
| Abermain                         | 33           | QABM     | 0.9992      | 1.0001      |
| Abermain - Dual MLF (Generation) | 110          | QABR     | 0.9995      | 1.0010      |
| Abermain - Dual MLF (Load)       | 110          | QABR     | 0.9980      | 1.0010      |
| Alan Sherriff                    | 132          | QASF     | 1.0027      | 1.0039      |
| Algester                         | 33           | QALG     | 1.0142      | 1.0134      |
| Alligator Creek                  | 132          | QALH     | 0.9885      | 0.9883      |
| Alligator Creek                  | 33           | QALC     | 0.9972      | 0.9961      |
| Ashgrove West                    | 33           | QAGW     | 1.0137      | 1.0154      |
| Ashgrove West                    | 110          | QCBW     | 1.0113      | 1.0135      |
| Belmont                          | 110          | QBMH     | 1.0108      | 1.0083      |
| Belmont Wecker Road              | 33           | QBBS     | 1.0119      | 1.0097      |
| Biloela                          | 66/11        | QBIL     | 0.9473      | 0.9348      |
| Blackstone                       | 110          | QBKS     | 0.9973      | 0.9975      |
| Blackwater                       | 66/11        | QBWL     | 0.9890      | 0.9791      |
| Blackwater                       | 132          | QBWH     | 0.9844      | 0.9745      |
| Bluff                            | 132          | QBLF     | 0.9859      | 0.9759      |
| Bolingbroke                      | 132          | QBNB     | 0.9775      | 0.9751      |
| Bowen North                      | 66           | QBNN     | 0.9807      | 0.9776      |
| Boyne Island                     | 275          | QBOH     | 0.9794      | 0.9696      |
| Boyne Island                     | 132          | QBOL     | 0.9756      | 0.9663      |
| Braemar – Kumbarella Park        | 275          | QBRE     | 0.9753      | 0.9739      |
| Bulli Creek (Essential Energy)   | 132          | QBK2     | 0.9748      | 0.9731      |

<sup>3</sup> At <https://www.aemo.com.au/Electricity/National-Electricity-Market-NEM/Security-and-reliability/Loss-factor-and-regional-boundaries>.

| Location                           | Voltage [kV] | TNI code | 2022-23 MLF | 2021-22 MLF |
|------------------------------------|--------------|----------|-------------|-------------|
| Bulli Creek (Waggamba)             | 132          | QBLK     | 0.9748      | 0.9731      |
| Bundamba                           | 110          | QBDA     | 0.9992      | 0.9997      |
| Burton Downs                       | 132          | QBUR     | 0.9851      | 0.9812      |
| Cairns                             | 22           | QCRN     | 0.9954      | 1.0090      |
| Cairns City                        | 132          | QCNS     | 0.9860      | 0.9995      |
| Callemondah (Rail)                 | 132          | QCMD     | 0.9676      | 0.9580      |
| Calliope River                     | 132          | QCAR     | 0.9672      | 0.9558      |
| Cardwell                           | 22           | QCDW     | 1.0017      | 1.0052      |
| Chinchilla                         | 132          | QCHA     | 0.9781      | 0.9863      |
| Clare                              | 66           | QCLR     | 1.0003      | 1.0101      |
| Collinsville Load                  | 33           | QCOL     | 0.9719      | 0.9706      |
| Columboola                         | 132          | QCBL     | 0.9828      | 0.9849      |
| Columboola 132 (Bellevue LNG load) | 132          | QCBP     | 0.9841      | 0.9857      |
| Coppabella (Rail)                  | 132          | QCOP     | 0.9917      | 0.9865      |
| Dan Gleeson                        | 66           | QDGL     | 1.0031      | 1.0031      |
| Duarina                            | 132          | QDRG     | 0.9660      | 0.9567      |
| Dysart                             | 66/22        | QDYS     | 0.9939      | 0.9849      |
| Eagle Downs Mine                   | 132          | QEGD     | 0.9898      | 0.9816      |
| Edmonton                           | 22           | QEMT     | 1.0039      | 1.0189      |
| Egans Hill                         | 66           | QEGN     | 0.9524      | 0.9453      |
| El Arish                           | 22           | QELA     | 1.0085      | 1.0146      |
| Garbutt                            | 66           | QGAR     | 1.0064      | 1.0090      |
| Gin Gin                            | 132          | QGNG     | 0.9855      | 0.9792      |
| Gladstone South                    | 66/11        | QGST     | 0.9713      | 0.9602      |
| Goodna                             | 33           | QGDA     | 1.0031      | 1.0030      |
| Goonyella Riverside Mine           | 132          | QGYR     | 1.0015      | 0.9979      |
| Grange (Rail)                      | 132          | QGRN     | 0.9574      | 0.9572      |
| Gregory (Rail)                     | 132          | QGRE     | 0.9677      | 0.9591      |
| Ingham                             | 66           | QING     | 1.0113      | 1.0664      |
| Innisfail                          | 22           | QINF     | 1.0053      | 1.0199      |
| Invicta Load                       | 132          | QINV     | 0.9501      | 0.9272      |
| Kamerunga                          | 22           | QKAM     | 1.0065      | 1.0208      |
| Kemmis                             | 66           | QEMS     | 0.9826      | 0.9820      |
| King Creek                         | 132          | QKCK     | 0.9806      | 0.9781      |
| Lilyvale                           | 66           | QLIL     | 0.9716      | 0.9585      |
| Lilyvale (Barcaldine)              | 132          | QLCM     | 0.9786      | 0.9515      |
| Loganlea                           | 33           | QLGL     | 1.0120      | 1.0117      |
| Loganlea                           | 110          | QLGH     | 1.0087      | 1.0083      |
| Mackay                             | 33           | QMKA     | 0.9896      | 0.9866      |
| Middle Ridge (Energex)             | 110          | QMRX     | 0.9823      | 0.9796      |

| Location                                 | Voltage [kV] | TNI code | 2022-23 MLF | 2021-22 MLF |
|--|--------------|----------|-------------|-------------|
| Middle Ridge (Ergon)                     | 110          | QMRG     | 0.9823      | 0.9796      |
| Mindi (Rail)                             | 132          | QMND     | 0.9726      | 0.9680      |
| Molendinar                               | 110          | QMAR     | 1.0086      | 1.0087      |
| Molendinar                               | 33           | QMAL     | 1.0084      | 1.0082      |
| Moranbah (Mine)                          | 66           | QMRN     | 1.0014      | 0.9949      |
| Moranbah (Town) - Dual MLF (Generation)  | 11           | QMRL     | 1.0026      | 0.9877      |
| Moranbah (Town) - Dual MLF (Load)        | 11           | QMRL     | 1.0026      | 0.9852      |
| Moranbah Substation                      | 132          | QMRH     | 0.9926      | 0.9870      |
| Moura                                    | 66/11        | QMRA     | 0.9537      | 0.9527      |
| Mt McLaren (Rail)                        | 132          | QMTM     | 0.9785      | 0.9773      |
| Mudgeeraba                               | 33           | QMGL     | 1.0083      | 1.0088      |
| Mudgeeraba                               | 110          | QMGB     | 1.0078      | 1.0079      |
| Murarrie (Belmont)                       | 110          | QMRE     | 1.0101      | 1.0090      |
| Nebo                                     | 11           | QNEB     | 0.9718      | 0.9675      |
| Newlands                                 | 66           | QNLN     | 1.0056      | 1.0042      |
| North Goonyella                          | 132          | QNGY     | 1.0030      | 0.9937      |
| Norwich Park (Rail)                      | 132          | QNOR     | 0.9856      | 0.9754      |
| Oakey                                    | 110          | QOKT     | 0.9804      | 0.9765      |
| Oonooie (Rail)                           | 132          | QOON     | 0.9891      | 0.9902      |
| Orana LNG                                | 275          | QORH     | 0.9764      | 0.9767      |
| Palmwoods                                | 132          | QPWD     | 1.0095      | 1.0091      |
| Pandoin                                  | 132          | QPAN     | 0.9539      | 0.9479      |
| Pandoin                                  | 66           | QPAL     | 0.9639      | 0.9484      |
| Peak Downs (Rail)                        | 132          | QPKD     | 0.9996      | 0.9925      |
| Pioneer Valley                           | 66           | QPIV     | 1.0008      | 0.9953      |
| Proserpine                               | 66           | QPRO     | 1.0112      | 1.0061      |
| Queensland Alumina Ltd (Gladstone South) | 132          | QQAQ     | 0.9754      | 0.9652      |
| Queensland Nickel (Yabulu)               | 132          | QQNH     | 0.9899      | 0.9887      |
| Raglan                                   | 275          | QRGL     | 0.9571      | 0.9492      |
| Redbank Plains                           | 11           | QRPN     | 1.0034      | 1.0035      |
| Richlands                                | 33           | QRLD     | 1.0130      | 1.0127      |
| Rockhampton                              | 66           | QROC     | 0.9575      | 0.9506      |
| Rocklea (Archerfield)                    | 110          | QRLE     | 1.0040      | 1.0044      |
| Ross                                     | 132          | QROS     | 0.9906      | 0.9929      |
| Runcorn                                  | 33           | QRBS     | 1.0151      | 1.0142      |
| South Pine                               | 110          | QSPN     | 1.0046      | 1.0052      |
| Stony Creek                              | 132          | QSYC     | 0.9859      | 0.9830      |
| Sumner                                   | 110          | QSUM     | 1.0050      | 1.0052      |
| Tangkem (Dalby) - Dual MLF (Generation)  | 110          | QTKM     | 0.9792      | 0.9774      |
| Tangkem (Dalby) - Dual MLF (Load)        | 110          | QTKM     | 0.9827      | 0.9774      |

| Location                    | Voltage [kV] | TNI code | 2022-23 MLF | 2021-22 MLF |
|-----------------------------|--------------|----------|-------------|-------------|
| Tarong                      | 66           | QTRL     | 0.9734      | 0.9725      |
| Teebar Creek                | 132          | QTBC     | 0.9956      | 0.9918      |
| Tennyson                    | 33           | QTNS     | 1.0077      | 1.0083      |
| Tennyson (Rail)             | 110          | QTNN     | 1.0062      | 1.0065      |
| Townsville East             | 66           | QTVE     | 0.9975      | 1.0026      |
| Townsville South            | 66           | QTVS     | 1.0025      | 1.0043      |
| Townsville South (KZ)       | 132          | QTZS     | 1.0029      | 1.0019      |
| Tully                       | 22           | QTLL     | 1.0223      | 1.0521      |
| Turkinje                    | 66           | QTUL     | 1.0201      | 1.0291      |
| Turkinje (Craiglie)         | 132          | QTUH     | 1.0235      | 1.0376      |
| Wandoan South               | 132          | QWSH     | 0.9953      | 0.9982      |
| Wandoan South (NW Surat)    | 275          | QWST     | 0.9946      | 0.9970      |
| Wandoo (Rail)               | 132          | QWAN     | 0.9760      | 0.9730      |
| Wivenhoe Pump               | 275          | QWIP     | 0.9994      | 0.9974      |
| Woolooga (Energen)          | 132          | QWLG     | 0.9942      | 0.9928      |
| Woolooga (Ergon)            | 132          | QWLN     | 0.9942      | 0.9928      |
| Woree                       | 132          | QWRE     | 0.9938      | 1.0075      |
| Wotonga (Rail)              | 132          | QWOT     | 0.9938      | 0.9864      |
| Wycarbah                    | 132          | QWCB     | 0.9525      | 0.9480      |
| Yarwun – Boat Creek (Ergon) | 132          | QYAE     | 0.9659      | 0.9579      |
| Yarwun – Rio Tinto          | 132          | QYAR     | 0.9632      | 0.9545      |

Table 2 Queensland generation

| Generator                                       | Voltage [kV] | DUID     | Connection Point ID | TNI code | 2022-23 MLF | 2021-22 MLF |
|---|--------------|----------|---------------------|----------|-------------|-------------|
| Baking Board Solar Farm (Chinchilla Solar Farm) | 132          | BAKING1  | QCHS1C              | QCHS     | 0.9664      | 0.9886      |
| Barcaldine PS – Lilyvale                        | 132          | BARCALDN | QBCG                | QBCG     | 0.9350      | 0.9064      |
| Barcaldine Solar at Lilyvale (132)              | 132          | BARCSF1  | QLLV1B              | QLLV     | 0.9334      | 0.9267      |
| Barron Gorge Power Station (PS) Unit 1          | 132          | BARRON-1 | QBGH1               | QBGH     | 0.9623      | 0.9832      |
| Barron Gorge PS Unit 2                          | 132          | BARRON-2 | QBGH2               | QBGH     | 0.9623      | 0.9832      |
| Bluegrass Solar Farm                            | 132          | BLUEGSF1 | QCBS1B              | QCBS     | 0.9600      | 0.9549      |
| Braemar PS Unit 1                               | 275          | BRAEMAR1 | QBRA1               | QBRA     | 0.9630      | 0.9629      |
| Braemar PS Unit 2                               | 275          | BRAEMAR2 | QBRA2               | QBRA     | 0.9630      | 0.9629      |
| Braemar PS Unit 3                               | 275          | BRAEMAR3 | QBRA3               | QBRA     | 0.9630      | 0.9629      |
| Braemar Stage 2 PS Unit 5                       | 275          | BRAEMAR5 | QBRA5B              | QBRA     | 0.9630      | 0.9629      |
| Braemar Stage 2 PS Unit 6                       | 275          | BRAEMAR6 | QBRA6B              | QBRA     | 0.9630      | 0.9629      |
| Braemar Stage 2 PS Unit 7                       | 275          | BRAEMAR7 | QBRA7B              | QBRA     | 0.9630      | 0.9629      |
| Browns Plains Landfill Gas PS                   | 110          | BPLANDF1 | QLGH3B              | QLGH     | 1.0087      | 1.0083      |
| Callide A PS Unit 4                             | 132          | CALL_A_4 | QCAA4               | QCAA     | 0.9392      | 0.9266      |

| Generator                           | Voltage [kV] | DUID     | Connection Point ID | TNI code | 2022-23 MLF | 2021-22 MLF |
|-------------------------------------|--------------|----------|---------------------|----------|-------------|-------------|
| Callide A PS Unit 4 Load            | 132          | CALLNL4  | QCAA2               | QCAA     | 0.9392      | 0.9266      |
| Callide B PS Unit 1                 | 275          | CALL_B_1 | QCAB1               | QCAB     | 0.9404      | 0.9251      |
| Callide B PS Unit 2                 | 275          | CALL_B_2 | QCAB2               | QCAB     | 0.9404      | 0.9251      |
| Callide C PS Unit 3                 | 275          | CPP_3    | QCAC3               | QCAC     | 0.9361      | 0.9274      |
| Callide C PS Unit 4                 | 275          | CPP_4    | QCAC4               | QCAC     | 0.9361      | 0.9274      |
| Callide PS Load                     | 132          | CALLNL1  | QCAX                | QCAX     | 0.9351      | 0.9257      |
| Childers Solar Farm                 | 132          | CHILDSF1 | QTBS1C              | QTBS     | 0.9823      | 0.9797      |
| Clare Solar Farm                    | 132          | CLARESF1 | QCLA1C              | QCLA     | 0.9177      | 0.9197      |
| Clermont Solar Farm                 | 132          | CLERMSF1 | QLLV3C              | QLLV     | 0.9334      | 0.9267      |
| Collinsville Solar Farm             | 33           | CSPVPS1  | QCOS1C              | QCOS     | 0.9268      | 0.9247      |
| Columboola – Condamine PS           | 132          | CPSA     | QCND1C              | QCND     | 0.9744      | 0.9825      |
| Columboola Solar Farm               | 132          | COLUMSF1 | QCBR1C              | QCBR     | 0.9812      | 0.9846      |
| Coopers Gap Wind Farm               | 275          | COOPGWF1 | QCPG1C              | QCPG     | 0.9685      | 0.9683      |
| Daandine PS - Dual MLF (Generation) | 110          | DAANDINE | QTKM1               | QTKM     | 0.9792      | 0.9774      |
| Daandine PS - Dual MLF (Load)       | 110          | DAANDINE | QTKM1               | QTKM     | 0.9827      | 0.9774      |
| Darling Downs PS                    | 275          | DDPS1    | QBRA8D              | QBRA     | 0.9630      | 0.9629      |
| Darling Downs Solar Farm            | 275          | DDSF1    | QBR1D               | QBR1     | 0.9796      | 0.9762      |
| Daydream Solar Farm                 | 33           | DAYDSF1  | QCK1D               | QCK1     | 0.9296      | 0.9268      |
| Emerald Solar Farm                  | 66           | EMERASF1 | QLIS1E              | QLIS     | 0.9333      | 0.9237      |
| Gangarri Solar Farm                 | 132          | GANGARR1 | QWSS1G              | QWSS     | 0.9921      | 0.9959      |
| German Creek Generator              | 66           | GERMCRK  | QLIL2               | QLIL     | 0.9716      | 0.9585      |
| Gladstone PS (132 kV) Unit 3        | 132          | GSTONE3  | QGLD3               | QGLL     | 0.9581      | 0.9470      |
| Gladstone PS (132 kV) Unit 4        | 132          | GSTONE4  | QGLD4               | QGLL     | 0.9581      | 0.9470      |
| Gladstone PS (132kV) Load           | 132          | GLADNL1  | QGLL                | QGLL     | 0.9581      | 0.9470      |
| Gladstone PS (275 kV) Unit 1        | 275          | GSTONE1  | QGLD1               | QGLH     | 0.9623      | 0.9519      |
| Gladstone PS (275 kV) Unit 2        | 275          | GSTONE2  | QGLD2               | QGLH     | 0.9623      | 0.9519      |
| Gladstone PS (275 kV) Unit 5        | 275          | GSTONE5  | QGLD5               | QGLH     | 0.9623      | 0.9519      |
| Gladstone PS (275 kV) Unit 6        | 275          | GSTONE6  | QGLD6               | QGLH     | 0.9623      | 0.9519      |
| Grosvenor PS At Moranbah 66 No 1    | 66           | GROSV1   | QMRN2G              | QMRV     | 0.9923      | 0.9844      |
| Grosvenor PS At Moranbah 66 No 2    | 66           | GROSV2   | QMRV1G              | QMRV     | 0.9923      | 0.9844      |
| Hamilton Solar Farm                 | 33           | HAMISF1  | QSLD1H              | QSLD     | 0.9238      | 0.9239      |
| Haughton Solar Farm                 | 275          | HAUGHT11 | QHAR1H              | QHAR     | 0.9300      | 0.9356      |
| Hayman Solar Farm                   | 33           | HAYMSF1  | QCK2H               | QCK2     | 0.9296      | 0.9268      |
| Hughenden Solar Farm                | 132          | HUGSF1   | QROG2H              | QROG     | 0.9369      | 0.9395      |
| Invicta Sugar Mill                  | 132          | INVICTA  | QINV1I              | QINV     | 0.9501      | 0.9272      |
| Isis CSM                            | 132          | ICSM     | QNG1I               | QTBC     | 0.9956      | 0.9918      |
| Kareeya PS Unit 1                   | 132          | KAREEYA1 | QKAH1               | QKYH     | 0.9702      | 0.9656      |
| Kareeya PS Unit 2                   | 132          | KAREEYA2 | QKAH2               | QKYH     | 0.9702      | 0.9656      |

| Generator                                   | Voltage [kV] | DUID     | Connection Point ID | TNI code | 2022-23 MLF | 2021-22 MLF |
|---|--------------|----------|---------------------|----------|-------------|-------------|
| Kareeya PS Unit 3                           | 132          | KAREEYA3 | QKAH3               | QKYH     | 0.9702      | 0.9656      |
| Kareeya PS Unit 4                           | 132          | KAREEYA4 | QKAH4               | QKYH     | 0.9702      | 0.9656      |
| Kennedy Energy Park Battery (Generation)    | 132          | KEPBG1   | QROW3K              | QROW     | 0.9808      | 0.9912      |
| Kennedy Energy Park Battery (Load)          | 132          | KEPBL1   | QROW4K              | QROW     | 0.9808      | 0.9912      |
| Kennedy Energy Park Solar Farm              | 132          | KEPSF1   | QROW2K              | QROW     | 0.9808      | 0.9912      |
| Kennedy Energy Park Wind Farm               | 132          | KEPWF1   | QROW1K              | QROW     | 0.9808      | 0.9912      |
| Kidston Solar Farm                          | 132          | KSP1     | QROG1K              | QROG     | 0.9369      | 0.9395      |
| Kogan Creek PS                              | 275          | KPP_1    | QBRA4K              | QWDN     | 0.9698      | 0.9694      |
| Koombooloomba                               | 132          | KAREEYA5 | QKYH5               | QKYH     | 0.9702      | 0.9656      |
| Lilyvale Solar Farm                         | 33           | LILYSF1  | QBDR1L              | QBDR     | 0.9323      | 0.9276      |
| Longreach Solar Farm                        | 132          | LRSF1    | QLLV2L              | QLLV     | 0.9334      | 0.9267      |
| Mackay GT                                   | 33           | MACKAYGT | QMKG                | QMKG     | 0.9871      | 0.9549      |
| Maryorough Solar Farm (Brigalow Solar Farm) | 110          | MARYRSF1 | QMRY2M              | QMRY     | 0.9861      | 0.9789      |
| Middlemount Sun Farm                        | 66           | MIDDLSF1 | QLIS2M              | QLIS     | 0.9333      | 0.9237      |
| Millmerran PS Unit 1                        | 330          | MPP_1    | QBCK1               | QMLN     | 0.9762      | 0.9733      |
| Millmerran PS Unit 2                        | 330          | MPP_2    | QBCK2               | QMLN     | 0.9762      | 0.9733      |
| Moranbah Generation - Dual MLF (Generation) | 11           | MORANBAH | QMRL1M              | QMRL     | 1.0026      | 0.9877      |
| Moranbah Generation - Dual MLF (Load)       | 11           | MORANBAH | QMRL1M              | QMRL     | 1.0026      | 0.9852      |
| Moranbah North PS                           | 66           | MBAHNTH  | QMRN1P              | QMRN     | 1.0014      | 0.9949      |
| Mount Emerald Wind farm                     | 275          | MEWF1    | QWKM1M              | QWKM     | 0.9575      | 0.9835      |
| Mt Stuart PS Unit 1                         | 132          | MSTUART1 | QMSP1               | QMSP     | 0.9160      | 0.9286      |
| Mt Stuart PS Unit 2                         | 132          | MSTUART2 | QMSP2               | QMSP     | 0.9160      | 0.9286      |
| Mt Stuart PS Unit 3                         | 132          | MSTUART3 | QMSP3M              | QMSP     | 0.9160      | 0.9286      |
| Oakey 1 Solar Farm                          | 110          | OAKEY1SF | QTKS1O              | QTKS     | 0.9800      | 0.9711      |
| Oakey 2 Solar Farm                          | 110          | OAKEY2SF | QTKS2O              | QTKS     | 0.9800      | 0.9711      |
| Oakey PS Unit 1                             | 110          | OAKEY1   | QOKY1               | QOKY     | 0.9530      | 0.9536      |
| Oakey PS Unit 2                             | 110          | OAKEY2   | QOKY2               | QOKY     | 0.9530      | 0.9536      |
| Oaky Creek 2                                | 66           | OAKY2    | QLIL3O              | QLIL     | 0.9716      | 0.9585      |
| Oaky Creek Generator                        | 66           | OAKYCREK | QLIL1               | QLIL     | 0.9716      | 0.9585      |
| Rocky Point Gen (Loganlea 110kV)            | 110          | RPCG     | QLGH2               | QLGH     | 1.0087      | 1.0083      |
| Roma PS Unit 7 – Columboola                 | 132          | ROMA_7   | QRMA7               | QRMA     | 0.9761      | 0.9679      |
| Roma PS Unit 8 – Columboola                 | 132          | ROMA_8   | QRMA8               | QRMA     | 0.9761      | 0.9679      |
| Ross River Solar Farm                       | 132          | RRSF1    | QROG3R              | QROG     | 0.9369      | 0.9395      |
| Rugby Run Solar Farm                        | 132          | RUGBYR1  | QMPL1R              | QMPL     | 0.9224      | 0.9156      |
| Stanwell PS Load                            | 132          | STANNL1  | QSTX                | QSTX     | 0.9527      | 0.9463      |
| Stanwell PS Unit 1                          | 275          | STAN-1   | QSTN1               | QSTN     | 0.9409      | 0.9338      |
| Stanwell PS Unit 2                          | 275          | STAN-2   | QSTN2               | QSTN     | 0.9409      | 0.9338      |
| Stanwell PS Unit 3                          | 275          | STAN-3   | QSTN3               | QSTN     | 0.9409      | 0.9338      |

| Generator                                    | Voltage [kV] | DUID       | Connection Point ID | TNI code | 2022-23 MLF | 2021-22 MLF |
|--|--------------|------------|---------------------|----------|-------------|-------------|
| Stanwell PS Unit 4                           | 275          | STAN-4     | QSTN4               | QSTN     | 0.9409      | 0.9338      |
| Stapylton                                    | 110          | STAPYLTON1 | QLGH4S              | QLGH     | 1.0087      | 1.0083      |
| Sun Metals Solar Farm                        | 132          | SMCSF1     | QTZS1S              | QTZS     | 1.0029      | 1.0019      |
| Sunshine Coast Solar Farm                    | 132          | VALDORA1   | QPWD1S              | QPWD     | 1.0095      | 1.0091      |
| Susan River Solar Farm                       | 132          | SRSF1      | QTBS2S              | QTBS     | 0.9823      | 0.9797      |
| Swanbank E GT                                | 275          | SWAN_E     | QSWE                | QSWE     | 0.9976      | 0.9971      |
| Tarong North PS                              | 275          | TNPS1      | QTNT                | QTNT     | 0.9737      | 0.9723      |
| Tarong PS Unit 1                             | 275          | TARONG#1   | QTRN1               | QTRN     | 0.9729      | 0.9719      |
| Tarong PS Unit 2                             | 275          | TARONG#2   | QTRN2               | QTRN     | 0.9729      | 0.9719      |
| Tarong PS Unit 3                             | 275          | TARONG#3   | QTRN3               | QTRN     | 0.9729      | 0.9719      |
| Tarong PS Unit 4                             | 275          | TARONG#4   | QTRN4               | QTRN     | 0.9729      | 0.9719      |
| Ti Tree BioReactor                           | 33           | TITREE     | QABM1T              | QABM     | 0.9992      | 1.0001      |
| Wandoan BESS (Generation)                    | 132          | WANDBG1    | QWSB1W              | QWSB     | 0.9767      | 0.9764      |
| Wandoan BESS (Load)                          | 132          | WANDBL1    | QWSB2W              | QWSB     | 1.0007      | 1.0054      |
| Warwick Solar Farm 1                         | 110          | WARWSF1    | QMRY3W              | QMRY     | 0.9861      | 0.9789      |
| Warwick Solar Farm 2                         | 110          | WARWSF2    | QMRY4W              | QMRY     | 0.9861      | 0.9789      |
| Western Downs Green Power Hub                | 275          | WDGPH1     | QWDR1W              | QWDR     | 0.9757      | 0.9704      |
| Whitsunday Solar Farm                        | 33           | WHITSF1    | QSLS1W              | QSLS     | 0.9218      | 0.9231      |
| Windy Hill Wind Farm                         | 66           | WHILL1     | QTUL                | QTUL     | 1.0201      | 1.0291      |
| Wivenhoe Generation Unit 1                   | 275          | W/HOE#1    | QWIV1               | QWIV     | 0.9913      | 0.9903      |
| Wivenhoe Generation Unit 2                   | 275          | W/HOE#2    | QWIV2               | QWIV     | 0.9913      | 0.9903      |
| Wivenhoe Pump 1                              | 275          | PUMP1      | QWIP1               | QWIP     | 0.9994      | 0.9974      |
| Wivenhoe Pump 2                              | 275          | PUMP2      | QWIP2               | QWIP     | 0.9994      | 0.9974      |
| Wivenhoe Small Hydro - Dual MLF (Generation) | 110          | WIVENSH    | QABR1               | QABR     | 0.9995      | 1.0010      |
| Wivenhoe Small Hydro - Dual MLF (Load)       | 110          | WIVENSH    | QABR1               | QABR     | 0.9980      | 1.0010      |
| Woolooga Solar Farm                          | 132          | WOOLGSF1   | QWLS1W              | QWLS     | 0.9832      | 0.9951      |
| Yabulu PS                                    | 132          | YABULU     | QTYP                | QTYP     | 0.9572      | 0.9661      |
| Yabulu Steam Turbine (Garbutt 66kV)          | 66           | YABULU2    | QGAR1               | QYST     | 0.9237      | 0.9755      |
| Yarranlea Solar Farm                         | 110          | YARANSF1   | QMRY1Y              | QMRY     | 0.9861      | 0.9789      |
| Yarwun PS                                    | 132          | YARWUN_1   | QYAG1R              | QYAG     | 0.9627      | 0.9544      |

## 1.2 New South Wales marginal loss factors<sup>4</sup>

Table 3 New South Wales loads

| Location                          | Voltage [kV] | TNI code | 2022-23 MLF | 2021-22 MLF |
|-----------------------------------|--------------|----------|-------------|-------------|
| Alexandria                        | 33           | NALX     | 1.0039      | 1.0048      |
| Albury                            | 132          | NALB     | 0.9551      | 0.9591      |
| Armidale                          | 66           | NAR1     | 0.9429      | 0.9474      |
| Australian Newsprint Mill         | 132          | NANM     | 0.9426      | 0.9456      |
| Balranald                         | 22           | NBAL     | 0.8998      | 0.8921      |
| Beaconsfield North                | 132          | NBFN     | 1.0036      | 1.0044      |
| Beaconsfield South                | 132          | NBFS     | 1.0036      | 1.0044      |
| Belmore Park                      | 132          | NBM1     | 1.0039      | 1.0045      |
| Beryl                             | 66           | NBER     | 0.9813      | 0.9723      |
| BHP (Waratah)                     | 132          | NWR1     | 0.9949      | 0.9921      |
| Boambee South                     | 132          | NWST     | 0.9830      | 0.9833      |
| Boggabri East                     | 132          | NBGE     | 0.9611      | 0.9956      |
| Boggabri North                    | 132          | NBGN     | 0.9630      | 0.9990      |
| Brandy Hill                       | 11           | NBHL     | 0.9988      | 0.9963      |
| Brandy Hill (Essential Energy)    | 11           | NBHX     | 0.9988      | 0.9963      |
| Broken Hill                       | 22           | NBKG     | 0.8685      | 0.8580      |
| Broken Hill                       | 220          | NBKH     | 0.8600      | 0.8423      |
| Bunnerong - Dual MLF (Generation) | 132          | NBG1     | 1.0039      | 1.0040      |
| Bunnerong - Dual MLF (Load)       | 132          | NBG1     | 1.0039      | 1.0045      |
| Bunnerong                         | 33           | NBG3     | 1.0055      | 1.0066      |
| Buronga                           | 220          | NBRG     | 0.8866      | 0.7477      |
| Burrinjuck                        | 132          | NBU2     | 0.9601      | 0.9698      |
| Campbell Street                   | 11           | NCBS     | 1.0060      | 1.0057      |
| Campbell Street                   | 132          | NCS1     | 1.0038      | 1.0047      |
| Canterbury                        | 33           | NCTB     | 1.0175      | 1.0168      |
| Carlingford                       | 132          | NCAR     | 1.0010      | 1.0010      |
| Casino                            | 132          | NCSN     | 0.9864      | 0.9912      |
| Charmhaven                        | 11           | NCHM     | 0.9967      | 0.9952      |
| Coffs Harbour                     | 66           | NCH1     | 0.9747      | 0.9789      |
| Coleambally                       | 132          | NCLY     | 0.9268      | 0.9258      |
| Cooma                             | 66           | NCMA     | 0.9625      | 0.9673      |
| Cooma (AusNet Services)           | 66           | NCM2     | 0.9625      | 0.9673      |
| Croydon                           | 11           | NCRD     | 1.0131      | 1.0135      |

<sup>4</sup> The New South Wales region includes the Australian Capital Territory (ACT). ACT generation and load are detailed separately for ease of reference.



| Location                       | Voltage [kV] | TNI code | 2022-23 MLF | 2021-22 MLF |
|--------------------------------|--------------|----------|-------------|-------------|
| Cowra                          | 66           | NCW8     | 0.9746      | 0.9721      |
| Dapto (Endeavour Energy)       | 132          | NDT1     | 0.9934      | 0.9929      |
| Dapto (Essential Energy)       | 132          | NDT2     | 0.9934      | 0.9929      |
| Darlington Point               | 132          | NDNT     | 0.9397      | 0.9397      |
| Deniliquin                     | 66           | NDN7     | 0.9733      | 0.9704      |
| Dorrigo                        | 132          | NDOR     | 0.9692      | 0.9684      |
| Drummoyne                      | 11           | NDRM     | 1.0131      | 1.0136      |
| Dunoon                         | 132          | NDUN     | 0.9991      | 0.9883      |
| Far North VTN                  |              | NEV1     | 0.9781      | 0.9755      |
| Finley - Dual MLF (Generation) | 132          | NFN2     | 0.9815      | 0.9904      |
| Finley - Dual MLF (Load)       | 132          | NFN2     | 0.9070      | 0.8465      |
| Finley                         | 66           | NFNY     | 0.9708      | 0.9686      |
| Forbes                         | 66           | NFB2     | 1.0018      | 0.9986      |
| Gadara                         | 132          | NGAD     | 0.9693      | 0.9795      |
| Glen Innes                     | 66           | NGLN     | 0.9346      | 0.9365      |
| Gosford                        | 66           | NGF3     | 1.0048      | 1.0037      |
| Gosford                        | 33           | NGSF     | 1.0053      | 1.0043      |
| Grafton East 132               | 132          | NGFT     | 0.9709      | 0.9832      |
| Green Square                   | 11           | NGSQ     | 1.0063      | 1.0073      |
| Griffith                       | 33           | NGRF     | 0.9473      | 0.9688      |
| Gunnedah                       | 66           | NGN2     | 0.9833      | 0.9972      |
| Haymarket                      | 132          | NHYM     | 1.0038      | 1.0046      |
| Heron's Creek                  | 132          | NHNC     | 1.0350      | 1.0396      |
| Holroyd                        | 132          | NHLD     | 1.0020      | 1.0022      |
| Holroyd (Ausgrid)              | 132          | NHLX     | 1.0020      | 1.0022      |
| Hurstville North               | 11           | NHVN     | 1.0048      | 1.0057      |
| Homebush Bay                   | 11           | NHBB     | 1.0161      | 1.0166      |
| Ilford                         | 132          | NLFD     | 0.9639      | 0.9610      |
| Ingleburn                      | 66           | NING     | 0.9976      | 0.9987      |
| Inverell                       | 66           | NNVL     | 0.9461      | 0.9482      |
| Kemps Creek                    | 330          | NKCK     | 0.9959      | 0.9955      |
| Kempsey                        | 66           | NKS2     | 1.0008      | 1.0101      |
| Kempsey                        | 33           | NKS3     | 1.0107      | 1.0158      |
| Koolkhan                       | 66           | NKL6     | 1.0008      | 0.9969      |
| Kurnell                        | 132          | NKN1     | 1.0023      | 1.0030      |
| Kogarah                        | 11           | NKOG     | 1.0066      | 1.0077      |
| Lake Munmorah                  | 132          | NMUN     | 0.9890      | 0.9821      |
| Lane Cove                      | 132          | NLCV     | 1.0130      | 1.0136      |
| Leichhardt                     | 11           | NLDT     | 1.0130      | 1.0135      |

| Location                     | Voltage [kV] | TNI code | 2022-23 MLF | 2021-22 MLF |
|------------------------------|--------------|----------|-------------|-------------|
| Liddell                      | 33           | NLD3     | 0.9678      | 0.9652      |
| Lismore                      | 132          | NLS2     | 1.0079      | 1.0080      |
| Liverpool                    | 132          | NLP1     | 1.0011      | 1.0015      |
| Macarthur                    | 132          | NMC1     | 0.9954      | 0.9951      |
| Macarthur                    | 66           | NMC2     | 0.9972      | 0.9973      |
| Macksville                   | 132          | NMCV     | 0.9966      | 0.9981      |
| Macquarie Park               | 11           | NMQP     | 1.0188      | 1.0183      |
| Macquarie Park               | 33           | NMQS     | 1.0128      | 1.0122      |
| Manildra                     | 132          | NMLD     | 1.0025      | 1.0083      |
| Marrickville                 | 11           | NMKV     | 1.0089      | 1.0097      |
| Marulan (Endeavour Energy)   | 132          | NMR1     | 1.0118      | 1.0122      |
| Marulan (Essential Energy)   | 132          | NMR2     | 1.0118      | 1.0122      |
| Mason Park                   | 132          | NMPK     | 1.0135      | 1.0140      |
| Meadowbank                   | 11           | NMBK     | 1.0167      | 1.0173      |
| Molong                       | 132          | NMOL     | 1.0258      | 1.0292      |
| Moree                        | 66           | NMRE     | 0.9761      | 0.9847      |
| Morven                       | 132          | NMVN     | 0.9431      | 0.9514      |
| Mt Piper                     | 66           | NMP6     | 0.9744      | 0.9757      |
| Mudgee                       | 132          | NMDG     | 0.9797      | 0.9699      |
| Mullumbimby                  | 11           | NML1     | 0.9987      | 0.9898      |
| Mullumbimby                  | 132          | NMLB     | 0.9899      | 0.9805      |
| Munmorah STS 33              | 33           | NMU3     | 0.9937      | 0.9917      |
| Munyang                      | 11           | NMY1     | 0.9633      | 0.9762      |
| Munyang                      | 33           | NMYG     | 0.9633      | 0.9762      |
| Murrumbateman                | 132          | NMBM     | 0.9645      | 0.9681      |
| Murrumburrah                 | 66           | NMRU     | 0.9719      | 0.9723      |
| Muswellbrook                 | 132          | NMRK     | 0.9788      | 0.9764      |
| Nambucca Heads               | 132          | NNAM     | 0.9905      | 0.9923      |
| Narrabri                     | 66           | NNB2     | 0.9926      | 1.0050      |
| Newcastle                    | 132          | NNEW     | 0.9942      | 0.9917      |
| Newcastle (Essential Energy) | 132          | NNEX     | 0.9942      | 0.9917      |
| North of Broken Bay VTN      |              | NEV2     | 0.9970      | 0.9949      |
| Orange                       | 66           | NRGE     | 1.0427      | 1.0478      |
| Orange North                 | 132          | NONO     | 1.0348      | 1.0454      |
| Ourimbah                     | 33           | NORB     | 1.0017      | 1.0010      |
| Ourimbah                     | 132          | NOR1     | 1.0007      | 0.9994      |
| Ourimbah                     | 66           | NOR6     | 1.0013      | 1.0000      |
| Panorama                     | 66           | NPMA     | 1.0252      | 1.0291      |
| Parkes                       | 66           | NPK6     | 1.0026      | 1.0007      |

| Location                        | Voltage [kV] | TNI code | 2022-23 MLF | 2021-22 MLF |
|---------------------------------|--------------|----------|-------------|-------------|
| Parkes                          | 132          | NPKS     | 0.9865      | 0.9909      |
| Peakhurst                       | 33           | NPHT     | 1.0037      | 1.0045      |
| Potts Hill 11                   | 11           | NPHL     | 1.0072      | 1.0081      |
| Potts Hill 132                  | 132          | NPO1     | 1.0044      | 1.0049      |
| Pt Macquarie                    | 33           | NPMQ     | 1.0312      | 1.0344      |
| Pymont                          | 33           | NPT3     | 1.0056      | 1.0065      |
| Pymont                          | 132          | NPT1     | 1.0037      | 1.0045      |
| Queanbeyan 132                  | 132          | NQBY     | 0.9941      | 0.9953      |
| Raleigh                         | 132          | NRAL     | 0.9847      | 0.9857      |
| Ravine                          | 330          | NRVN     | 0.9495      | 0.9483      |
| Regentville                     | 132          | NRGV     | 0.9984      | 0.9983      |
| Rockdale (Ausgrid)              | 11           | NRKD     | 1.0060      | 1.0069      |
| Rookwood Road                   | 132          | NRWR     | 1.0043      | 1.0049      |
| Rose Bay                        | 11           | NRSB     | 1.0069      | 1.0061      |
| Rozelle                         | 132          | NRZH     | 1.0130      | 1.0135      |
| Rozelle                         | 33           | NRZL     | 1.0130      | 1.0135      |
| Snowy Adit                      | 132          | NSAD     | 0.9550      | 0.9623      |
| Somersby                        | 11           | NSMB     | 1.0057      | 1.0049      |
| South of Broken Bay VTN         |              | NEV3     | 1.0057      | 1.0056      |
| St Peters                       | 11           | NSPT     | 1.0069      | 1.0081      |
| Strathfield South               | 11           | NSFS     | 1.0091      | 1.0106      |
| Stroud                          | 132          | NSRD     | 1.0119      | 1.0109      |
| Sydney East                     | 132          | NSE2     | 1.0061      | 1.0068      |
| Sydney North (Ausgrid)          | 132          | NSN1     | 1.0042      | 1.0042      |
| Sydney North (Endeavour Energy) | 132          | NSN2     | 1.0042      | 1.0042      |
| Sydney South                    | 132          | NSYS     | 1.0009      | 1.0015      |
| Sydney West (Ausgrid)           | 132          | NSW1     | 1.0010      | 1.0010      |
| Sydney West (Endeavour Energy)  | 132          | NSW2     | 1.0010      | 1.0010      |
| Tamworth                        | 66           | NTA2     | 0.9660      | 0.9703      |
| Taree (Essential Energy)        | 132          | NTR2     | 1.0411      | 1.0453      |
| Tenterfield                     | 132          | NTTF     | 0.9600      | 0.9603      |
| Terranora                       | 110          | NTNR     | 0.9771      | 0.9947      |
| Tomago                          | 330          | NTMG     | 0.9953      | 0.9926      |
| Tomago (Ausgrid)                | 132          | NTME     | 0.9980      | 0.9952      |
| Tomago (Essential Energy)       | 132          | NTMC     | 0.9980      | 0.9952      |
| Top Ryde                        | 11           | NTPR     | 1.0157      | 1.0163      |
| Tuggerah                        | 132          | NTG3     | 0.9974      | 0.9956      |
| Tumut                           | 66           | NTU2     | 0.9735      | 0.9838      |
| Tumut 66 (AusNet DNSP)          | 66           | NTUX     | 0.9735      | 0.9838      |

| Location                                 | Voltage [kV] | TNI code | 2022-23 MLF | 2021-22 MLF |
|--|--------------|----------|-------------|-------------|
| Vales Pt.                                | 132          | NVP1     | 0.9924      | 0.9893      |
| Vineyard                                 | 132          | NVYD     | 1.0001      | 1.0000      |
| Wagga                                    | 66           | NWG2     | 0.9529      | 0.9492      |
| Wagga North                              | 132          | NWGN     | 0.9487      | 0.9491      |
| Wagga North                              | 66           | NWG6     | 0.9500      | 0.9485      |
| Wallerawang (Endeavour Energy)           | 132          | NWW6     | 0.9747      | 0.9765      |
| Wallerawang (Essential Energy)           | 132          | NWW5     | 0.9747      | 0.9765      |
| Wallerawang 66 (Essential Energy)        | 66           | NWW4     | 0.9752      | 0.9772      |
| Wallerawang 66                           | 66           | NWW7     | 0.9752      | 0.9772      |
| Wallerawang 330 PS Load                  | 330          | NWWP     | 0.9737      | 0.9759      |
| Waverley                                 | 11           | NWAV     | 1.0066      | 1.0058      |
| Wellington                               | 132          | NWL8     | 0.9862      | 0.9903      |
| West Gosford                             | 11           | NGWF     | 1.0063      | 1.0054      |
| Williamsdale (Essential Energy) (Bogong) | 132          | NWD1     | 0.9682      | 0.9379      |
| Wyong                                    | 11           | NWYG     | 0.9992      | 0.9979      |
| Yanco                                    | 33           | NYA3     | 0.9502      | 0.9473      |
| Yass                                     | 66           | NYS6     | 0.9643      | 0.9677      |
| Yass                                     | 132          | NYS1     | 0.9485      | 0.9082      |

Table 4 New South Wales generation

| Generator              | Voltage [kV] | DUID     | Connection Point ID | TNI code | 2022-23 MLF | 2021-22 MLF |
|------------------------|--------------|----------|---------------------|----------|-------------|-------------|
| AGL Sita Landfill 1    | 132          | AGLSITA1 | NLP13K              | NLP1     | 1.0011      | 1.0015      |
| Appin Power Station    | 66           | APPIN    | NAPP1A              | NAPP     | 0.9973      | 0.9975      |
| Bango 973 Wind Farm    | 132          | BANGOWF1 | NBA21B              | NBA2     | 0.9107      | 0.9134      |
| Bango 999 Wind Farm    | 132          | BANGOWF2 | NBB21B              | NBB2     | 0.9283      | 0.9294      |
| Bayswater PS Unit 1    | 330          | BW01     | NBAY1               | NBAY     | 0.9653      | 0.9622      |
| Bayswater PS Unit 2    | 330          | BW02     | NBAY2               | NBAY     | 0.9653      | 0.9622      |
| Bayswater PS Unit 3    | 500          | BW03     | NBAY3               | NBYW     | 0.9653      | 0.9620      |
| Bayswater PS Unit 4    | 500          | BW04     | NBAY4               | NBYW     | 0.9653      | 0.9620      |
| Beryl Solar Farm       | 66           | BERYLSF1 | NBES1B              | NBES     | 0.9289      | 0.9184      |
| Blowering              | 132          | BLOWERNG | NBLW8               | NBLW     | 0.9064      | 0.9444      |
| Boco Rock Wind Farm    | 132          | BOCORWF1 | NCMA3B              | NBCO     | 0.9355      | 0.9359      |
| Bodangora Wind Farm    | 132          | BODWF1   | NBOD1B              | NBOD     | 0.9595      | 0.9581      |
| Bomen Solar Farm       | 132          | BOMENSF1 | NWGS1B              | NWGS     | 0.9089      | 0.8875      |
| Broadwater PS          | 132          | BWTR1    | NLS21B              | NLS2     | 1.0079      | 1.0080      |
| Broken Hill GT 1       | 22           | GB01     | NBKG1               | NBKG     | 0.8685      | 0.8580      |
| Broken Hill Solar Farm | 22           | BROKENH1 | NBK11B              | NBK1     | 0.8381      | 0.7953      |

| Generator                   | Voltage [kV] | DUID     | Connection Point ID | TNI code | 2022-23 MLF | 2021-22 MLF |
|-----------------------------|--------------|----------|---------------------|----------|-------------|-------------|
| Brown Mountain              | 66           | BROWNMT  | NCMA1               | NCMA     | 0.9625      | 0.9673      |
| Burrendong Hydro PS         | 132          | BDONGHYD | NWL81B              | NWL8     | 0.9862      | 0.9903      |
| Burrinjuck PS               | 132          | BURRIN   | NBUK                | NBUK     | 0.9459      | 0.9653      |
| Campbelltown WSLC           | 66           | WESTCBT1 | NING1C              | NING     | 0.9976      | 0.9987      |
| Capital Wind Farm           | 330          | CAPTL_WF | NCWF1R              | NCWF     | 0.9558      | 0.9563      |
| Coleambally Solar Farm      | 132          | COLEASF1 | NCLS1C              | NCLS     | 0.8770      | 0.8478      |
| Collector Wind Farm         | 330          | COLWF01  | NCLW1C              | NCLW     | 0.9581      | 0.9588      |
| Colongra PS Unit 1          | 330          | CG1      | NCLG1D              | NCLG     | 0.9864      | 0.9851      |
| Colongra PS Unit 2          | 330          | CG2      | NCLG2D              | NCLG     | 0.9864      | 0.9851      |
| Colongra PS Unit 3          | 330          | CG3      | NCLG3D              | NCLG     | 0.9864      | 0.9851      |
| Colongra PS Unit 4          | 330          | CG4      | NCLG4D              | NCLG     | 0.9864      | 0.9851      |
| Condong PS                  | 110          | CONDONG1 | NTNR1C              | NTNR     | 0.9771      | 0.9947      |
| Copeton Hydro PS            | 66           | COPTNHYD | NNVL1C              | NNVL     | 0.9461      | 0.9482      |
| Corowa Solar Farm           | 132          | CRWASF1  | NAL11C              | NAL1     | 0.9242      | 0.8813      |
| Crookwell 2 Wind Farm       | 330          | CROOKWF2 | NCKW1C              | NCKW     | 0.9611      | 0.9616      |
| Crudine Ridge Wind Farm     | 132          | CRURWF1  | NCDS1C              | NCDS     | 0.9381      | 0.9246      |
| Cullerin Range Wind Farm    | 132          | CULLRGWF | NYS11C              | NYS1     | 0.9485      | 0.9082      |
| Darlington Point Solar Farm | 132          | DARLSF1  | NDNS1D              | NDNS     | 0.8880      | 0.8587      |
| Eastern Creek               | 132          | EASTCRK  | NSW21               | NSW2     | 1.0010      | 1.0010      |
| Eastern Creek 2             | 132          | EASTCRK2 | NSW23L              | NSW2     | 1.0010      | 1.0010      |
| Eraring 330 BS UN (GT)      | 330          | ERGT01   | NEP35B              | NEP3     | 0.9865      | 0.9849      |
| Eraring 330 PS Unit 1       | 330          | ER01     | NEPS1               | NEP3     | 0.9865      | 0.9849      |
| Eraring 330 PS Unit 2       | 330          | ER02     | NEPS2               | NEP3     | 0.9865      | 0.9849      |
| Eraring 500 PS Unit 3       | 500          | ER03     | NEPS3               | NEPS     | 0.9877      | 0.9858      |
| Eraring 500 PS Unit 4       | 500          | ER04     | NEPS4               | NEPS     | 0.9877      | 0.9858      |
| Eraring PS Load             | 500          | ERNL1    | NEPSL               | NNEW     | 0.9942      | 0.9917      |
| Finley Solar Farm           | 132          | FINLYSF1 | NFNS1F              | NFNS     | 0.9036      | 0.8432      |
| Glenbawn Hydro PS           | 132          | GLBWNHYD | NMRK2G              | NMRK     | 0.9788      | 0.9764      |
| Glenn Innes (Pindari PS)    | 66           | PINDARI  | NGLN1               | NGLN     | 0.9346      | 0.9365      |
| Glennies Creek PS           | 132          | GLENNCRK | NMRK3T              | NMRK     | 0.9788      | 0.9764      |
| Goonumbla Solar Farm        | 66           | GOONSF1  | NPG12G              | NPG1     | 0.8818      | 0.8918      |
| Grange Avenue               | 132          | GRANGEAV | NVYD1               | NVYD     | 1.0001      | 1.0000      |
| Griffith Solar Farm         | 33           | GRISF1   | NGG11G              | NGG1     | 0.8862      | 0.8547      |
| Gullen Range Solar Farm     | 330          | GULLRSF1 | NGUR2G              | NGUR     | 0.9592      | 0.9595      |
| Gullen Range 1 Wind Farm    | 330          | GULLRWF1 | NGUR1G              | NGUR     | 0.9592      | 0.9595      |
| Gullen Range 2 Wind Farm    | 330          | GULLRWF2 | NGUR3G              | NGUR     | 0.9592      | 0.9595      |
| Gunnedah Solar Farm         | 132          | GNNDHSF1 | NGNE1G              | NGNE     | 0.8353      | 0.8960      |
| Gunning Wind Farm           | 132          | GUNNING1 | NYS12A              | NYS1     | 0.9485      | 0.9082      |

| Generator   | Voltage [kV] | DUID     | Connection Point ID | TNI code | 2022-23 MLF | 2021-22 MLF |
|---|--------------|----------|---------------------|----------|-------------|-------------|
| Guthega   | 132          | GUTHEGA  | NGUT8               | NGUT     | 0.8870      | 0.9006      |
| Guthega Auxiliary Supply                                      | 11           | GUTHNL1  | NMY11               | NMY1     | 0.9633      | 0.9762      |
| Hillston Solar Farm   | 132          | HILLSTN1 | NDNH1H              | NDNH     | 0.8906      | 0.8593      |
| Hume (New South Wales Share)                                  | 132          | HUMENSW  | NHUM                | NHUM     | 0.9118      | 0.8989      |
| Hunter Economic Zone  | 132          | HEZ1     | NNEE1H              | NNEE     | 0.9920      | 0.9897      |
| Jemalong Solar Farm   | 66           | JEMALNG1 | NFBS1J              | NFBS     | 0.8833      | 0.8956      |
| Jindabyne Generator   | 66           | JNDABNE1 | NCMA2               | NCMA     | 0.9625      | 0.9673      |
| Jounama PS  | 66           | JOUNAMA1 | NTU21J              | NTU2     | 0.9735      | 0.9838      |
| June Solar Farm   | 132          | JUNEESF1 | NWGJ1J              | NWGJ     | 0.9129      | 0.8799      |
| Kangaroo Valley – Bendeela (Shoalhaven) Generation – Dual MLF | 330          | SHGEN    | NSHL                | NSHN     | 0.9733      | 0.9763      |
| Kangaroo Valley (Shoalhaven) Pumps – Dual MLF                 | 330          | SHPUMP   | NSHP1               | NSHN     | 0.9896      | 0.9919      |
| Keepit  | 66           | KEEPIT   | NKPT                | NKPT     | 0.9833      | 0.9972      |
| Liddell 330 PS Unit 1   | 330          | LD01     | NLDP1               | NLDP     | 0.9659      | 0.9628      |
| Liddell 330 PS Unit 2   | 330          | LD02     | NLDP2               | NLDP     | 0.9659      | 0.9628      |
| Liddell 330 PS Unit 3   | 330          | LD03     | NLDP3               | NLDP     | 0.9659      | 0.9628      |
| Liddell 330 PS Unit 4   | 330          | LD04     | NLDP4               | NLDP     | 0.9659      | 0.9628      |
| Limondale Solar Farm 1  | 220          | LIMOSF11 | NBSF1L              | NBSF     | 0.8314      | 0.8070      |
| Limondale Solar Farm 2  | 22           | LIMOSF21 | NBL21L              | NBL2     | 0.8309      | 0.7985      |
| Liverpool 132 (Jacks Gully)                                   | 132          | JACKSGUL | NLP11               | NSW2     | 1.0010      | 1.0010      |
| Lower Tumut Generation – dual MLF                             | 330          | TUMUT3   | NLTS8               | NLTS     | 0.9092      | 0.9195      |
| Lower Tumut Pumps – dual MLF                                  | 330          | SNOWYP   | NLTS3               | NLTS     | 0.9895      | 0.9525      |
| Lower Tumut Pipeline Auxiliary                                | 66           | TUMT3NL3 | NTU2L3              | NTU2     | 0.9735      | 0.9838      |
| Lower Tumut T2 Auxiliary                                      | 66           | TUMT3NL1 | NTU2L1              | NTU2     | 0.9735      | 0.9838      |
| Lower Tumut T4 Auxiliary                                      | 66           | TUMT3NL2 | NTU2L2              | NTU2     | 0.9735      | 0.9838      |
| Lucas Heights II Power Plant                                  | 132          | LUCASHGT | NSYS2G              | NSYS     | 1.0009      | 1.0015      |
| Lucas Heights Stage 2 Power Station                           | 132          | LUCAS2S2 | NSYS1               | NSYS     | 1.0009      | 1.0015      |
| Manildra Solar Farm   | 132          | MANSLR1  | NMLS1M              | NMLS     | 0.9287      | 0.9333      |
| Metz Solar Farm   | 132          | METZSF1  | NMTZ1M              | NMTZ     | 0.8831      | 0.9208      |
| Molong Solar Farm   | 66           | MOLNGSF1 | NMOS1M              | NMOS     | 0.9433      | 0.9541      |
| Moree Solar Farm  | 66           | MOREESF1 | NMR41M              | NMR4     | 0.8275      | 0.8931      |
| Mt Piper PS Load  | 330          | MPNL1    | NMPPL               | NMTP     | 0.9720      | 0.9726      |
| Mt Piper PS Unit 1  | 330          | MP1      | NMTP1               | NMTP     | 0.9720      | 0.9726      |
| Mt Piper PS Unit 2  | 330          | MP2      | NMTP2               | NMTP     | 0.9720      | 0.9726      |
| Narromine Solar Farm  | 132          | NASF1    | NWLS1N              | NWLS     | 0.9352      | 0.9444      |
| Nevertire Solar Farm  | 132          | NEVERSF1 | NWLS3N              | NWLS     | 0.9352      | 0.9444      |
| Nine Willoughby   | 132          | NINEWIL1 | NSE21R              | NSE2     | 1.0061      | 1.0068      |
| Nyngan Solar Farm   | 132          | NYNGAN1  | NWL82N              | NWL8     | 0.9862      | 0.9903      |
| Parkes Solar Farm   | 66           | PARSF1   | NPG11P              | NPG1     | 0.8818      | 0.8918      |

| Generator                    | Voltage [kV] | DUID     | Connection Point ID | TNI code | 2022-23 MLF | 2021-22 MLF |
|------------------------------|--------------|----------|---------------------|----------|-------------|-------------|
| Queanbeyan BESS (Generation) | 66           | QBYNBG1  | NQBB1Q              | NQBB     | 0.9752      |             |
| Queanbeyan BESS (Load)       | 66           | QBYNBL1  | NQBB2Q              | NQBB     | 0.9917      |             |
| Sapphire Wind Farm           | 330          | SAPHWF1  | NSAP1S              | NSAP     | 0.9470      | 0.9426      |
| Sebastopol Solar Farm        | 132          | SEBSF1   | NWGJ2S              | NWGJ     | 0.9129      | 0.8799      |
| Silverton Wind Farm          | 220          | STWF1    | NBKW1S              | NBKW     | 0.7973      | 0.8456      |
| Sithe (Holroyd Generation)   | 132          | SITHE01  | NSYW1               | NHD2     | 1.0018      | 1.0017      |
| South Keswick Solar Farm     | 132          | SKSF1    | NWLS2S              | NWLS     | 0.9352      | 0.9444      |
| St George Leagues Club       | 33           | STGEORG1 | NPHT1E              | NPHT     | 1.0037      | 1.0045      |
| Sunraysia Solar Farm         | 220          | SUNRSF1  | NBSF2S              | NBSF     | 0.8314      | 0.8070      |
| Suntop Solar Farm            | 132          | SUNTPSF1 | NWLW1S              | NWLW     | 0.9128      | 0.9159      |
| Tahmoor PS                   | 132          | TAHMOOR1 | NLP12T              | NLP1     | 1.0011      | 1.0015      |
| Tallawarra PS                | 132          | TALWA1   | NDT13T              | NTWA     | 0.9901      | 0.9912      |
| Taralga Wind Farm            | 132          | TARALGA1 | NMR22T              | NMR2     | 1.0118      | 1.0122      |
| The Drop Power Station       | 66           | THEDROP1 | NFNY1D              | NFNY     | 0.9708      | 0.9686      |
| Tower Power Plant            | 132          | TOWER    | NLP11T              | NLP1     | 1.0011      | 1.0015      |
| Upper Tumut                  | 330          | UPPTUMUT | NUTS8               | NUTS     | 0.9347      | 0.9335      |
| Uranquinty PS Unit 11        | 132          | URANQ11  | NURQ1U              | NURQ     | 0.8673      | 0.8625      |
| Uranquinty PS Unit 12        | 132          | URANQ12  | NURQ2U              | NURQ     | 0.8673      | 0.8625      |
| Uranquinty PS Unit 13        | 132          | URANQ13  | NURQ3U              | NURQ     | 0.8673      | 0.8625      |
| Uranquinty PS Unit 14        | 132          | URANQ14  | NURQ4U              | NURQ     | 0.8673      | 0.8625      |
| Vales Point 330 PS Load      | 330          | VPNL1    | NVPPL               | NVPP     | 0.9892      | 0.9872      |
| Vales Point 330 PS Unit 5    | 330          | VP5      | NVPP5               | NVPP     | 0.9892      | 0.9872      |
| Vales Point 330 PS Unit 6    | 330          | VP6      | NVPP6               | NVPP     | 0.9892      | 0.9872      |
| Wagga North Solar Farm       | 66           | WAGGNSF1 | NWGG1W              | NWGG     | 0.9064      | 0.8869      |
| Wallgrove BESS (Generation)  | 132          | WALGRVG1 | NSWB1W              | NSWG     | 1.0010      | 1.0011      |
| Wallgrove BESS (Load)        | 132          | WALGRVL1 | NSWB2W              | NSWB     | 1.0009      | 1.0010      |
| Wellington Solar Farm        | 132          | WELLSF1  | NWLS4W              | NWLS     | 0.9352      | 0.9444      |
| Wests Illawara Leagues Club  | 132          | WESTILL1 | NDT14E              | NDT1     | 0.9934      | 0.9929      |
| White Rock Solar Farm        | 132          | WRSF1    | NWRK2W              | NWRK     | 0.8697      | 0.8708      |
| White Rock Wind Farm         | 132          | WRWF1    | NWRK1W              | NWRK     | 0.8697      | 0.8708      |
| Wilga Park A                 | 66           | WILGAPK  | NNB21W              | NNB2     | 0.9926      | 1.0050      |
| Wilga Park B                 | 66           | WILGB01  | NNB22W              | NNB2     | 0.9926      | 1.0050      |
| Woodlawn Bioreactor          | 132          | WDLNGN01 | NMR21W              | NMR2     | 1.0118      | 1.0122      |
| Woodlawn Wind Farm           | 330          | WOODLWN1 | NCWF2W              | NCWF     | 0.9558      | 0.9563      |
| Wyangala A PS                | 66           | WYANGALA | NCW81A              | NCW8     | 0.9746      | 0.9721      |
| Wyangala B PS                | 66           | WYANGALB | NCW82B              | NCW8     | 0.9746      | 0.9721      |

Table 5 ACT loads

| Location                      | Voltage [kV] | TNI code | 2022-23 MLF | 2021-22 MLF |
|-------------------------------|--------------|----------|-------------|-------------|
| Angle Crossing                | 132          | AAXG     | 0.9549      | 0.9397      |
| Belconnen                     | 132          | ABCN     | 0.9675      | 0.9673      |
| City East                     | 132          | ACTE     | 0.9695      | 0.9684      |
| Civic                         | 132          | ACVC     | 0.9672      | 0.9663      |
| East lake                     | 132          | AELK     | 0.9681      | 0.9669      |
| Gilmore                       | 132          | AGLM     | 0.9678      | 0.9682      |
| Gold Creek                    | 132          | AGCK     | 0.9693      | 0.9708      |
| Latham                        | 132          | ALTM     | 0.9688      | 0.9696      |
| Telopea Park                  | 132          | ATLP     | 0.9687      | 0.9681      |
| Theodore                      | 132          | ATDR     | 0.9691      | 0.9716      |
| Wanniassa                     | 132          | AWSA     | 0.9693      | 0.9695      |
| Woden                         | 132          | AWDN     | 0.9685      | 0.9680      |
| ACT VTN                       | 132          | AAVT     | 0.9687      | 0.9683      |
| Queanbeyan (ACTEW)            | 66           | AQB1     | 0.9866      | 0.9882      |
| Queanbeyan (Essential Energy) | 66           | AQB2     | 0.9866      | 0.9882      |

The Regional Reference Node (RRN) for ACT load and generation is the Sydney West 330 kV node.

Table 6 ACT generation

| Generator               | Voltage [kV] | DUID     | Connection Point ID | TNI code | 2022-23 MLF | 2021-22 MLF |
|-------------------------|--------------|----------|---------------------|----------|-------------|-------------|
| Capital East Solar Farm | 66           | CESF1    | AQB21C              | AQB2     | 0.9866      | 0.9882      |
| Mugga Lane Solar Farm   | 132          | MLSP1    | ACA12M              | AMS1     | 0.9606      | 0.9440      |
| Mugga Lane landfill     | 132          | MLLFGEF1 | AGLM1M              | AAVT     | 0.9687      | 0.9683      |
| Royalla Solar Farm      | 132          | ROYALLA1 | ACA11R              | ARS1     | 0.9596      | 0.9436      |

The RRN for ACT load and generation is the Sydney West 330 kV node.

## 1.3 Victoria marginal loss factors

Table 7 Victoria loads

| Location            | Voltage [kV] | TNI code | 2022-23 MLF | 2021-22 MLF |
|---------------------|--------------|----------|-------------|-------------|
| Altona              | 66           | VATS     | 1.0108      | 1.0086      |
| Altona              | 220          | VAT2     | 0.9949      | 0.9936      |
| Ballarat            | 66           | VBAT     | 0.9699      | 0.9699      |
| Bendigo             | 66           | VBE6     | 1.0084      | 1.0101      |
| Bendigo             | 22           | VBE2     | 1.0072      | 1.0101      |
| BHP Western Port    | 220          | VJLA     | 0.9926      | 0.9915      |
| Brooklyn (Jemena)   | 22           | VL2      | 1.0014      | 1.0005      |
| Brooklyn (Jemena)   | 66           | VL6      | 1.0066      | 1.0062      |
| Brooklyn (POWERCOR) | 22           | VL3      | 1.0014      | 1.0005      |



| Location                           | Voltage [kV] | TNI code | 2022-23 MLF | 2021-22 MLF |
|------------------------------------|--------------|----------|-------------|-------------|
| Brooklyn (POWERCOR)                | 66           | VL7      | 1.0066      | 1.0062      |
| Brunswick (CitiPower)              | 22           | VB2      | 0.9980      | 0.9977      |
| Brunswick (Jemena)                 | 22           | VBTS     | 0.9980      | 0.9977      |
| Brunswick 66 (CitiPower)           | 66           | VB6      | 0.9971      | 0.9971      |
| Cranbourne                         | 220          | VCB2     | 0.9916      | 0.9905      |
| Cranbourne (AusNet Services)       | 66           | VCBT     | 0.9935      | 0.9921      |
| Cranbourne (United Energy)         | 66           | VCB5     | 0.9935      | 0.9921      |
| Deer Park                          | 66           | VDPT     | 0.9994      | 0.9992      |
| East Rowville (AusNet Services)    | 66           | VER2     | 0.9962      | 0.9944      |
| East Rowville (United Energy)      | 66           | VERT     | 0.9962      | 0.9944      |
| Fishermans Bend (CITIPOWER)        | 66           | VFBT     | 0.9997      | 0.9995      |
| Fishermans Bend (POWERCOR)         | 66           | VFB2     | 0.9997      | 0.9995      |
| Fosterville                        | 220          | VFVT     | 1.0034      | 1.0057      |
| Geelong                            | 66           | VGT6     | 0.9933      | 0.9918      |
| Glenrowan                          | 66           | VGNT     | 1.0182      | 1.0299      |
| Heatherton                         | 66           | VHTS     | 0.9981      | 0.9965      |
| Heywood                            | 22           | VHY2     | 0.9923      | 0.9862      |
| Horsham                            | 66           | VHOT     | 0.9092      | 0.9328      |
| Keilor (Jemena)                    | 66           | VKT2     | 0.9991      | 0.9977      |
| Keilor (POWERCOR)                  | 66           | VKTS     | 0.9991      | 0.9977      |
| Kerang                             | 22           | VKG2     | 1.0092      | 1.0156      |
| Kerang                             | 66           | VKG6     | 1.0136      | 1.0234      |
| Khancoban                          | 330          | NKHN     | 1.0239      | 1.0422      |
| Loy Yang Substation                | 66           | VL6      | 0.9791      | 0.9764      |
| Malvern                            | 22           | VMT2     | 0.9960      | 0.9947      |
| Malvern                            | 66           | VMT6     | 0.9950      | 0.9938      |
| Malvern (CitiPower)                | 66           | VMT7     | 0.9950      | 0.9938      |
| Morwell Power Station Units 1 to 3 | 66           | VMWG     | 0.9756      | 0.9736      |
| Morwell PS (G4&5)                  | 11           | VMWP     | 0.9801      | 0.9777      |
| Morwell TS                         | 66           | VMWT     | 0.9977      | 0.9936      |
| Mt Beauty                          | 66           | VMBT     | 1.0190      | 1.0292      |
| Portland                           | 500          | VAPD     | 0.9945      | 0.9908      |
| Red Cliffs                         | 22           | VRC2     | 0.9732      | 0.9721      |
| Red Cliffs                         | 66           | VRC6     | 0.9744      | 0.9730      |
| Red Cliffs (Essential Energy)      | 66           | VRCA     | 0.9744      | 0.9730      |
| Richmond                           | 22           | VRT2     | 0.9970      | 0.9978      |
| Richmond (CITIPOWER)               | 66           | VRT7     | 0.9973      | 0.9978      |
| Richmond (United Energy)           | 66           | VRT6     | 0.9973      | 0.9978      |
| Ringwood (AusNet Services)         | 22           | VRW3     | 0.9978      | 0.9968      |

| Location                       | Voltage [kV] | TNI code | 2022-23 MLF | 2021-22 MLF |
|--------------------------------|--------------|----------|-------------|-------------|
| Ringwood (AusNet Services)     | 66           | VRW7     | 1.0002      | 0.9988      |
| Ringwood (United Energy)       | 22           | VRW2     | 0.9978      | 0.9968      |
| Ringwood (United Energy)       | 66           | VRW6     | 1.0002      | 0.9988      |
| Shepparton                     | 66           | VSHT     | 1.0313      | 1.0346      |
| South Morang (Jemena)          | 66           | VSM6     | 0.9951      | 0.9956      |
| South Morang (AusNet Services) | 66           | VSMT     | 0.9951      | 0.9956      |
| Springvale (CITIPOWER)         | 66           | VSVT     | 0.9972      | 0.9957      |
| Springvale (United Energy)     | 66           | VSV2     | 0.9972      | 0.9957      |
| Templestowe (CITIPOWER)        | 66           | VTST     | 0.9996      | 0.9987      |
| Templestowe (Jemena)           | 66           | VTST     | 0.9996      | 0.9987      |
| Templestowe (AusNet Services)  | 66           | VTST     | 0.9996      | 0.9987      |
| Templestowe (United Energy)    | 66           | VTST     | 0.9996      | 0.9987      |
| Terang                         | 66           | VTGT     | 0.9972      | 1.0035      |
| Thomastown (Jemena)            | 66           | VTTT     | 1.0000      | 1.0000      |
| Thomastown (AusNet Services)   | 66           | VTT2     | 1.0000      | 1.0000      |
| Tyabb                          | 66           | VTBT     | 0.9938      | 0.9930      |
| Wemen 66 (Essential Energy)    | 66           | VWEA     | 0.9622      | 0.9472      |
| Wemen TS                       | 66           | VWET     | 0.9622      | 0.9472      |
| West Melbourne                 | 22           | VWM2     | 0.9995      | 0.9984      |
| West Melbourne (CITIPOWER)     | 66           | VWM7     | 0.9985      | 0.9982      |
| West Melbourne (Jemena)        | 66           | VWM6     | 0.9985      | 0.9982      |
| Wodonga                        | 22           | VWO2     | 1.0260      | 1.0411      |
| Wodonga                        | 66           | VWO6     | 1.0198      | 1.0393      |
| Yallourn                       | 11           | VYP1     | 0.9638      | 0.9639      |

Table 8 Victoria generation

| Generator   | Voltage [kV] | DUID     | Connection Point ID | TNI code | 2022-23 MLF | 2021-22 MLF |
|---|--------------|----------|---------------------|----------|-------------|-------------|
| Ararat Wind Farm  | 220          | ARWF1    | VART1A              | VART     | 0.8894      | 0.8987      |
| Bairnsdale Power Station  | 66           | BDL01    | VMWT2               | VBDL     | 0.9913      | 0.9874      |
| Bairnsdale Power Station Generator Unit 2                         | 66           | BDL02    | VMWT3               | VBDL     | 0.9913      | 0.9874      |
| Bald Hills Wind Farm  | 66           | BALDHWF1 | VMWT9B              | VMWT     | 0.9977      | 0.9936      |
| Ballarat BESS (Generation)  | 22           | BALBG1   | VBA21B              | VBA2     | 0.9663      | 0.9573      |
| Ballarat BESS (Load)  | 22           | BALBL1   | VBA22B              | VBA2     | 0.9629      | 0.9573      |
| Ballarat Health Services  | 66           | BBASEHOS | VBAT1H              | VBAT     | 0.9699      | 0.9699      |
| Banimboola  | 220          | BAPS     | VDPS2               | VDPS     | 0.9542      | 0.9861      |
| Bannerton Solar Farm  | 66           | BANN1    | VWES1B              | VWES     | 0.8928      | 0.8633      |
| Basslink (Loy Yang Power Station Switchyard) Tasmania to Victoria | 500          | BLNKVIC  | VLYP13              | VTBL     | 0.9749      | 0.9735      |

| Generator   | Voltage [kV] | DUID      | Connection Point ID | TNI code | 2022-23 MLF | 2021-22 MLF |
|---|--------------|-----------|---------------------|----------|-------------|-------------|
| Basslink (Loy Yang Power Station Switchyard) Victoria to Tasmania | 500          | BLNKVIC   | VLYP13              | VTBL     | 0.9821      | 0.9803      |
| Berrybank Wind Farm   | 220          | BRYB1WF1  | VBBT1B              | VBBT     | 0.9496      | 0.9431      |
| Broadmeadows Power Plant  | 66           | BROADMDW  | VTTS2B              | VTTS     | 1.0000      | 1.0000      |
| Brooklyn Landfill & Recycling Facility                            | 66           | BROOKLYN  | VBL61               | VBL6     | 1.0066      | 1.0062      |
| Bulgana BESS (Generation)   | 220          | BULBESG1  | VBGT2B              | VBGT     | 0.8839      | 0.8949      |
| Bulgana BESS (Load)   | 220          | BULBESL1  | VBGT3B              | VBGT     | 0.8839      | 0.8949      |
| Bulgana Green Power Hub   | 220          | BULGANA1  | VBGT1B              | VBGT     | 0.8839      | 0.8949      |
| Challicum Hills Wind Farm   | 66           | CHALLHWF  | VHOT1               | VBAT     | 0.9699      | 0.9699      |
| Chepstowe Wind Farm   | 66           | CHPSTWF1  | VBAT3C              | VBAT     | 0.9699      | 0.9699      |
| Cherry Tree Wind Farm   | 66           | CHYTW1    | VSM71C              | VSM7     | 0.9955      | 0.9959      |
| Clayton Landfill Gas Power Station                                | 66           | CLAYTON   | VSV21B              | VSV2     | 0.9972      | 0.9957      |
| Clover PS   | 66           | CLOVER    | VMBT1               | VMBT     | 1.0190      | 1.0292      |
| Codrington Wind Farm  | 66           | CODRNGTON | VTGT2C              | VTGT     | 0.9972      | 1.0035      |
| Cohuna Solar Farm   | 66           | COHUNSF1  | VKGS2C              | VKGS     | 0.9336      | 0.9127      |
| Coonooer Bridge Wind Farm   | 66           | CBWF1     | VBE61C              | VBE6     | 1.0084      | 1.0101      |
| Corio LFG PS  | 66           | CORIO1    | VGT61C              | VGT6     | 0.9933      | 0.9918      |
| Crowlands Wind Farm   | 220          | CROWLWF1  | VCWL1C              | VCWL     | 0.8877      | 0.8985      |
| Dartmouth PS  | 220          | DARTM1    | VDPS                | VDPS     | 0.9542      | 0.9861      |
| Diapur Wind Farm  | 66           | DIAPURWF1 | VHOG2D              | VHOG     | 0.8788      | 0.9005      |
| Dundonnell Wind Farm 1  | 500          | DUNDWF1   | VM051D              | VM05     | 0.9824      | 0.9789      |
| Dundonnell Wind Farm 2  | 500          | DUNDWF2   | VM052D              | VM05     | 0.9824      | 0.9789      |
| Dundonnell Wind Farm 3  | 500          | DUNDWF3   | VM053D              | VM05     | 0.9824      | 0.9789      |
| Eildon Hydro PS   | 66           | EILDON3   | VTT22E              | VSMT     | 0.9951      | 0.9956      |
| Eildon PS Unit 1  | 220          | EILDON1   | VEPS1               | VEPS     | 0.9887      | 0.9995      |
| Eildon PS Unit 2  | 220          | EILDON2   | VEPS2               | VEPS     | 0.9887      | 0.9995      |
| Elaine Wind Farm  | 220          | ELAINWF1  | VELT3E              | VELT     | 0.9480      | 0.9459      |
| Ferguson North Wind Farm  | 66           | FNWF1     | VTGT6F              | VTGT     | 0.9972      | 1.0035      |
| Ferguson South Wind Farm  | 66           | FSWF1     | VTGT7F              | VTGT     | 0.9972      | 1.0035      |
| Gannawarra BESS (Generation)                                      | 66           | GANNBG1   | VKGB1G              | VKGB     | 1.0026      | 0.9773      |
| Gannawarra BESS (Load)  | 66           | GANNBL1   | VKGB2G              | VKGL     | 0.9846      | 0.9933      |
| Gannawarra Solar Farm   | 66           | GANNBSF1  | VKGS1G              | VKGS     | 0.9336      | 0.9127      |
| Glenmaggie Hydro PS   | 66           | GLENMAG1  | VMWT8G              | VMWT     | 0.9977      | 0.9936      |
| Glenrowan West Sun Farm   | 66           | GLRWNSF1  | VGNS1G              | VGNS     | 0.9671      | 0.9976      |
| Hallam Mini Hydro   | 66           | HLMSEW01  | VER21H              | VCBT     | 0.9935      | 0.9921      |
| Hallam Road Renewable Energy Facility                             | 66           | HALAMRD1  | VER22L              | VER2     | 0.9962      | 0.9944      |
| Hepburn Community Wind Farm                                       | 66           | HEPWIND1  | VBAT2L              | VBAT     | 0.9699      | 0.9699      |
| Hume (Victorian Share)  | 66           | HUMEV     | VHUM                | VHUM     | 0.9535      | 0.9933      |
| Jeeralang A PS Unit 1   | 220          | JLA01     | VJLGA1              | VJLG     | 0.9727      | 0.9755      |

| Generator                         | Voltage [kV] | DUID      | Connection Point ID | TNI code | 2022-23 MLF | 2021-22 MLF |
|-----------------------------------|--------------|-----------|---------------------|----------|-------------|-------------|
| Jeeralang A PS Unit 2             | 220          | JLA02     | VJLGA2              | VJLG     | 0.9727      | 0.9755      |
| Jeeralang A PS Unit 3             | 220          | JLA03     | VJLGA3              | VJLG     | 0.9727      | 0.9755      |
| Jeeralang A PS Unit 4             | 220          | JLA04     | VJLGA4              | VJLG     | 0.9727      | 0.9755      |
| Jeeralang B PS Unit 1             | 220          | JLB01     | VJLGB1              | VJLG     | 0.9727      | 0.9755      |
| Jeeralang B PS Unit 2             | 220          | JLB02     | VJLGB2              | VJLG     | 0.9727      | 0.9755      |
| Jeeralang B PS Unit 3             | 220          | JLB03     | VJLGB3              | VJLG     | 0.9727      | 0.9755      |
| Jindabyne pump at Guthega         | 132          | SNOWYGJP  | NGJP                | NGJP     | 1.0914      | 1.1350      |
| Karadoc Solar Farm                | 66           | KARSF1    | VRCS1K              | VRCS     | 0.8886      | 0.8673      |
| Kiamal Solar Farm                 | 220          | KIAMSF1   | VKMT1K              | VKMT     | 0.8775      | 0.8504      |
| Kiata Wind Farm                   | 66           | KIATAWF1  | VHOG1K              | VHOG     | 0.8788      | 0.9005      |
| Laverton PS (LNGS1)               | 220          | LNGS1     | VAT21L              | VAT2     | 0.9949      | 0.9936      |
| Laverton PS (LNGS2)               | 220          | LNGS2     | VAT22L              | VAT2     | 0.9949      | 0.9936      |
| Longford                          | 66           | LONGFORD  | VMWT6               | VMWT     | 0.9977      | 0.9936      |
| Loy Yang A PS Load                | 500          | LYNL1     | VLYPL               | VLYP     | 0.9783      | 0.9759      |
| Loy Yang A PS Unit 1              | 500          | LYA1      | VLYP1               | VLYP     | 0.9783      | 0.9759      |
| Loy Yang A PS Unit 2              | 500          | LYA2      | VLYP2               | VLYP     | 0.9783      | 0.9759      |
| Loy Yang A PS Unit 3              | 500          | LYA3      | VLYP3               | VLYP     | 0.9783      | 0.9759      |
| Loy Yang A PS Unit 4              | 500          | LYA4      | VLYP4               | VLYP     | 0.9783      | 0.9759      |
| Loy Yang B PS Unit 1              | 500          | LOYYB1    | VLYP5               | VLYP     | 0.9783      | 0.9759      |
| Loy Yang B PS Unit 2              | 500          | LOYYB2    | VLYP6               | VLYP     | 0.9783      | 0.9759      |
| MacArthur Wind Farm               | 500          | MACARTH1  | VTRT1M              | VTRT     | 0.9807      | 0.9753      |
| Maroona Wind Farm                 | 66           | MAROOWF1  | VBAT5M              | VBAT     | 0.9699      | 0.9699      |
| McKay Creek / Bogong PS           | 220          | MCKAY1    | VMKP1               | VT14     | 0.9665      | 0.9726      |
| Moorabool Wind Farm               | 220          | MOORAWF1  | VELT2M              | VELT     | 0.9480      | 0.9459      |
| Mortlake Unit 1                   | 500          | MORTLK11  | VM0P1O              | VM0P     | 0.9901      | 0.9865      |
| Mortlake Unit 2                   | 500          | MORTLK12  | VM0P2O              | VM0P     | 0.9901      | 0.9865      |
| Mortlake South Wind Farm          | 220          | MRTLSTWF1 | VTG21M              | VTG2     | 0.9573      | 0.9768      |
| Mortons Lane Wind Farm            | 66           | MLWF1     | VTGT4M              | VTGT     | 0.9972      | 1.0035      |
| Mt Gellibrand Windfarm            | 66           | MTGELWF1  | VGW1M               | VGW      | 0.9879      | 0.9862      |
| Mt Mercer Windfarm                | 220          | MERCER01  | VELT1M              | VELT     | 0.9480      | 0.9459      |
| Murra Warra Wind Farm             | 220          | MUWAWF1   | VMRT1M              | VMRT     | 0.8661      | 0.8883      |
| Murra Warra Wind Farm - stage 2   | 220          | MUWAWF2   | VMRT2M              | VMRT     | 0.8661      | 0.8883      |
| Murray                            | 330          | MURRAY    | NMUR8               | NMUR     | 0.9719      | 0.9966      |
| Murray (Geehi Tee off Auxiliary)  | 330          | MURAYNL3  | NMURL3              | NMUR     | 0.9719      | 0.9966      |
| Murray Power Station M1 Auxiliary | 330          | MURAYNL1  | NMURL1              | NMUR     | 0.9719      | 0.9966      |
| Murray Power Station M2 Auxiliary | 330          | MURAYNL2  | NMURL2              | NMUR     | 0.9719      | 0.9966      |
| Newport PS                        | 220          | NPS       | VNPS                | VNPS     | 0.9919      | 0.9926      |
| Numurkah Solar Farm               | 66           | NUMURSF1  | VSHS1N              | VSHS     | 0.9715      | 0.9963      |
| Oaklands Hill Wind Farm           | 66           | OAKLAND1  | VTGT3A              | VTGT     | 0.9972      | 1.0035      |

| Generator                          | Voltage [kV] | DUID     | Connection Point ID | TNI code | 2022-23 MLF | 2021-22 MLF |
|------------------------------------|--------------|----------|---------------------|----------|-------------|-------------|
| Rubicon Mountain Streams Station   | 66           | RUBICON  | VTT21R              | VSMT     | 0.9951      | 0.9956      |
| Salt Creek Wind Farm               | 66           | SALTCRK1 | VTG61S              | VTG6     | 0.9584      | 0.9515      |
| Shepparton Waste Gas               | 66           | SHEP1    | VSHT2S              | VSHT     | 1.0313      | 1.0346      |
| Somerton Power Station             | 66           | AGLSOM   | VTTS1               | VSOM     | 0.9924      | 0.9932      |
| Springvale Power Plant             | 66           | SVALE1   | VSV22S              | VSV2     | 0.9972      | 0.9957      |
| Stockyard Hill Wind Farm           | 500          | STOCKYD1 | VHGT1S              | VHGT     | 0.9799      | 0.9782      |
| Tatura                             | 66           | TATURA01 | VSHT1               | VSHT     | 1.0313      | 1.0346      |
| Timboon West Wind Farm             | 66           | TIMWEST  | VTGT5T              | VTGT     | 0.9972      | 1.0035      |
| Toora Wind Farm                    | 66           | TOORAWF  | VMWT5               | VMWT     | 0.9977      | 0.9936      |
| Traralgon NSS                      | 66           | TGNSS1   | VMWT1T              | VMWT     | 0.9977      | 0.9936      |
| Valley Power Unit 1                | 500          | VPGS1    | VLYP07              | VLYP     | 0.9783      | 0.9759      |
| Valley Power Unit 2                | 500          | VPGS2    | VLYP08              | VLYP     | 0.9783      | 0.9759      |
| Valley Power Unit 3                | 500          | VPGS3    | VLYP09              | VLYP     | 0.9783      | 0.9759      |
| Valley Power Unit 4                | 500          | VPGS4    | VLYP010             | VLYP     | 0.9783      | 0.9759      |
| Valley Power Unit 5                | 500          | VPGS5    | VLYP011             | VLYP     | 0.9783      | 0.9759      |
| Valley Power Unit 6                | 500          | VPGS6    | VLYP012             | VLYP     | 0.9783      | 0.9759      |
| Victorian Big Battery (Generation) | 220          | VBBG1    | VMLB1V              | VMLB     | 0.9848      | 0.9820      |
| Victorian Big Battery (Load)       | 220          | VBBL1    | VMLB2V              | VMLB     | 0.9870      | 0.9864      |
| Waubra Wind Farm                   | 220          | WAUBRAWF | VWBT1A              | VWBT     | 0.9233      | 0.9221      |
| Wemen Solar Farm                   | 66           | WEMENSF1 | VWES2W              | VWES     | 0.8928      | 0.8633      |
| West Kiewa PS Unit 1               | 220          | WKIEWA1  | VWKP1               | VWKP     | 1.0049      | 1.0096      |
| West Kiewa PS Unit 2               | 220          | WKIEWA2  | VWKP2               | VWKP     | 1.0049      | 1.0096      |
| William Hovell Hydro PS            | 66           | WILLHOV1 | VW061W              | VGNT     | 1.0182      | 1.0299      |
| Winton Solar Farm                  | 66           | WINTSF1  | VGNS2W              | VGNS     | 0.9671      | 0.9976      |
| Wollert Renewable Energy Facility  | 66           | WOLLERT1 | VSMT1W              | VSMT     | 0.9951      | 0.9956      |
| Wonthaggi Wind Farm                | 66           | WONWP    | VMWT7               | VMWT     | 0.9977      | 0.9936      |
| Yallourn W PS 220 Load             | 220          | YWNL1    | VYP2L               | VYP2     | 0.9602      | 0.9596      |
| Yallourn W PS 220 Unit 1           | 220          | YWPS1    | VYP21               | VYP3     | 0.9690      | 0.9663      |
| Yallourn W PS 220 Unit 2           | 220          | YWPS2    | VYP22               | VYP2     | 0.9602      | 0.9596      |
| Yallourn W PS 220 Unit 3           | 220          | YWPS3    | VYP23               | VYP2     | 0.9602      | 0.9596      |
| Yallourn W PS 220 Unit 4           | 220          | YWPS4    | VYP24               | VYP2     | 0.9602      | 0.9596      |
| Yaloak South Wind Farm             | 66           | YSWF1    | VBAT4Y              | VBAT     | 0.9699      | 0.9699      |
| Yambuk Wind Farm                   | 66           | YAMBUKWF | VTGT1               | VTGT     | 0.9972      | 1.0035      |
| Yarrowonga Hydro PS                | 66           | YWNGAHYD | VSHT3Y              | VSHT     | 1.0313      | 1.0346      |
| Yatpool Solar Farm                 | 66           | YATSF1   | VRCS2Y              | VRCS     | 0.8886      | 0.8673      |
| Yawong Wind Farm                   | 66           | YAWWF1   | VBE62Y              | VBE6     | 1.0084      | 1.0101      |
| Yendon Wind Farm                   | 66           | YENDWF1  | VBAW1Y              | VBAW     | 0.9497      | 0.9422      |

## 1.4 South Australia marginal loss factors

Table 9 South Australia loads

| Location   | Voltage [kV] | TNI code | 2022-23 MLF | 2021-22 MLF |
|--|--------------|----------|-------------|-------------|
| Angas Creek  | 33           | SANC     | 1.0096      | 1.0113      |
| Ardrossan West                                       | 33           | SARW     | 0.9472      | 0.9485      |
| Back Callington                                      | 11           | SBAC     | 1.0063      | 1.0099      |
| Baroota - Dual MLF (Generation)                      | 33           | SBAR     | 0.9680      | 0.9670      |
| Baroota - Dual MLF (Load)                            | 33           | SBAR     | 0.9893      | 0.9946      |
| Berri  | 66           | SBER     | 0.9875      | 1.0072      |
| Berri (POWERCOR)                                     | 66           | SBE1     | 0.9875      | 1.0072      |
| Blanche  | 33           | SBLA     | 1.0038      | 1.0333      |
| Blanche (POWERCOR)                                   | 33           | SBL1     | 1.0038      | 1.0333      |
| Brinkworth   | 33           | SBRK     | 0.9876      | 0.9918      |
| Bungama Industrial                                   | 33           | SBUN     | 0.9817      | 0.9868      |
| Bungama Rural  | 33           | SBUR     | 0.9905      | 0.9958      |
| City West  | 66           | SACR     | 1.0068      | 1.0067      |
| Clare North  | 33           | SCLN     | 0.9846      | 0.9884      |
| Dalrymple  | 33           | SDAL     | 0.9127      | 0.9128      |
| Davenport  | 275          | SDAV     | 0.9788      | 0.9841      |
| Davenport  | 33           | SDAW     | 0.9812      | 0.9874      |
| Dorrien  | 33           | SDRN     | 1.0036      | 1.0051      |
| East Terrace   | 66           | SETC     | 1.0009      | 1.0021      |
| Happy Valley   | 66           | SHVA     | 1.0030      | 1.0052      |
| Hummocks   | 33           | SHUM     | 0.9587      | 0.9640      |
| Kadina East  | 33           | SKAD     | 0.9864      | 0.9745      |
| Kanmantoo  | 11           | SKAN     | 1.0108      | 1.0128      |
| Keith  | 33           | SKET     | 1.0119      | 1.0263      |
| Kilburn  | 66           | SKLB     | 1.0010      | 1.0008      |
| Kincraig   | 33           | SKNC     | 1.0053      | 1.0258      |
| Lefevre  | 66           | SLFE     | 1.0003      | 1.0003      |
| Leigh Creek South                                    | 33           | SLCS     | 1.0033      | 1.0579      |
| Magill   | 66           | SMAG     | 1.0026      | 1.0041      |
| Mannum   | 33           | SMAN     | 1.0185      | 1.0169      |
| Mannum – Adelaide Pipeline 1                         | 3.3          | SMA1     | 1.0141      | 1.0206      |
| Mannum – Adelaide Pipeline 2 - Dual MLF (Generation) | 3.3          | SMA2     | 0.9944      | 1.0016      |
| Mannum – Adelaide Pipeline 2 - Dual MLF (Load)       | 3.3          | SMA2     | 1.0143      | 1.0182      |
| Mannum – Adelaide Pipeline 3 - Dual MLF (Generation) | 3.3          | SMA3     | 0.9934      | 1.0012      |
| Mannum – Adelaide Pipeline 3 - Dual MLF (Load)       | 3.3          | SMA3     | 1.0141      | 1.0178      |

| Location  | Voltage [kV] | TNI code | 2022-23 MLF | 2021-22 MLF |
|---|--------------|----------|-------------|-------------|
| Middleback  | 33           | SMDL     | 0.9923      | 0.9997      |
| Middleback  | 132          | SMBK     | 0.9955      | 1.0003      |
| Millbrook   | 132          | SMLB     | 1.0019      | 1.0041      |
| Mobilong  | 33           | SMBL     | 1.0091      | 1.0140      |
| Morgan Whyalla Pump Station 1 PV                            | 3.3          | SMW1     | 1.0018      | 1.0271      |
| Morgan Whyalla Pump Station 2 PV - Dual MLF (Generation)    | 3.3          | SMW2     | 0.9999      | 0.9664      |
| Morgan Whyalla Pump Station 2 PV - Dual MLF (Load)          | 3.3          | SMW2     | 0.9999      | 0.9994      |
| Morgan Whyalla Pump Station 3 PV - Dual MLF (Generation)    | 3.3          | SMW3     | 0.9717      | 0.9719      |
| Morgan Whyalla Pump Station 3 PV - Dual MLF (Load)          | 3.3          | SMW3     | 0.9864      | 0.9927      |
| Morgan Whyalla Pump Station 4 PV - Dual MLF (Generation)    | 3.3          | SMW4     | 0.9889      | 0.9751      |
| Morgan Whyalla Pump Station 4 PV - Dual MLF (Load)          | 3.3          | SMW4     | 0.9889      | 0.9874      |
| Morphett Vale East  | 66           | SMVE     | 1.0036      | 1.0055      |
| Mount Barker South  | 66           | SMBS     | 1.0038      | 1.0063      |
| Mt Barker   | 66           | SMBA     | 1.0024      | 1.0049      |
| Mt Gambier  | 33           | SMGA     | 1.0060      | 1.0356      |
| Mt Gunson South   | 132          | SMGS     | 0.9895      | 0.9947      |
| Mt Gunson   | 33           | SMGU     | 0.9883      | 0.9939      |
| Munno Para  | 66           | SMUP     | 0.9980      | 0.9992      |
| Murray Bridge – Hahndorf Pipeline 1                         | 11           | SMH1     | 1.0115      | 1.0198      |
| Murray Bridge - Hahndorf Pipeline 2 – Dual MLF (Generation) | 11           | SMH2     | 1.0190      | 1.0058      |
| Murray Bridge - Hahndorf Pipeline 2 – Dual MLF (Load)       | 11           | SMH2     | 1.0190      | 1.0205      |
| Murray Bridge – Hahndorf Pipeline 3                         | 11           | SMH3     | 1.0104      | 1.0169      |
| Neuroodla   | 33           | SNEU     | 0.9952      | 1.0190      |
| New Osborne   | 66           | SNBN     | 1.0008      | 1.0005      |
| North West Bend   | 66           | SNWB     | 0.9892      | 0.9982      |
| Northfield  | 66           | SNFD     | 1.0023      | 1.0027      |
| Para  | 66           | SPAR     | 1.0000      | 1.0012      |
| Parafield Gardens West                                      | 66           | SPGW     | 1.0002      | 1.0011      |
| Penola West 33  | 33           | SPEN     | 1.0009      | 1.0236      |
| Pimba   | 132          | SPMB     | 0.9952      | 1.0015      |
| Playford  | 132          | SPAA     | 0.9773      | 0.9828      |
| Port Lincoln  | 33           | SPLN     | 0.9786      | 0.9813      |
| Port Pirie  | 33           | SPPR     | 0.9867      | 0.9912      |
| Roseworthy  | 11           | SRSW     | 1.0067      | 1.0082      |
| Snuggery Industrial   | 33           | SSNN     | 1.0029      | 1.0358      |



| Location                   | Voltage [kV] | TNI code | 2022-23 MLF | 2021-22 MLF |
|----------------------------|--------------|----------|-------------|-------------|
| Snuggery Rural             | 33           | SSNR     | 0.9797      | 1.0030      |
| South Australian VTN       |              | SJP1     | 0.9962      | 1.0003      |
| Stony Point                | 11           | SSPN     | 0.9843      | 0.9904      |
| Tailem Bend                | 33           | STAL     | 1.0110      | 1.0173      |
| Templers                   | 33           | STEM     | 1.0011      | 1.0029      |
| Torrens Island             | 66           | STSY     | 1.0000      | 1.0000      |
| Waterloo                   | 33           | SWAT     | 0.9786      | 0.9821      |
| Whyalla Central Substation | 33           | SWYC     | 0.9845      | 0.9909      |
| Whyalla Terminal BHP       | 33           | SBHP     | 0.9847      | 0.9902      |
| Woomera                    | 132          | SWMA     | 0.9902      | 0.9956      |
| Wudina                     | 66           | SWUD     | 0.9945      | 1.0001      |
| Yadnarie                   | 66           | SYAD     | 0.9792      | 0.9864      |

Table 10 South Australia generation

| Generator  | Voltage [kV] | DUID     | Connection Point ID | TNI code | 2022-23 MLF | 2021-22 MLF |
|--|--------------|----------|---------------------|----------|-------------|-------------|
| Adelaide Desalination Plant Battery (Generation)             | 66           | ADPBA1G  | SMVE4D              | SMVE     | 1.0036      | 1.0055      |
| Adelaide Desalination Plant Battery (Load)                   | 66           | ADPBA1L  | SMVE5D              | SMVE     | 1.0036      | 1.0055      |
| Adelaide Desalination Plant Hydro                            | 66           | ADPMH1   | SMVE9D              | SMVE     | 1.0036      | 1.0055      |
| Adelaide Desalination Plant PV1                              | 66           | ADPPV1   | SMVE6D              | SMVE     | 1.0036      | 1.0055      |
| Adelaide Desalination Plant PV2                              | 66           | ADPPV2   | SMVE7D              | SMVE     | 1.0036      | 1.0055      |
| Adelaide Desalination Plant PV3                              | 66           | ADPPV3   | SMVE8D              | SMVE     | 1.0036      | 1.0055      |
| Angaston Power Station                                       | 33           | ANGAST1  | SDRN1               | SANG     | 1.0027      | 1.0020      |
| Barker Inlet PS  | 275          | BARKIPS1 | SBPS1B              | SBPS     | 0.9996      | 0.9997      |
| Bolivar WWT Plant  | 66           | BOLIVAR1 | SPGW1B              | SPGW     | 1.0002      | 1.0011      |
| Bolivar Wastewater Treatment Plant PV                        | 66           | BOWWPV1  | SPGW2B              | SPGW     | 1.0002      | 1.0011      |
| Bolivar Wastewater Treatment Plant Reserve Diesel            | 66           | BOWWDG1  | SPGW5B              | SPGW     | 1.0002      | 1.0011      |
| Bolivar Wastewater Treatment Plant Reserve BESS (Generation) | 66           | BOWWBA1G | SPGW3B              | SPGW     | 1.0002      | 1.0011      |
| Bolivar Wastewater Treatment Plant Reserve BESS (Load)       | 66           | BOWWBA1L | SPGW4B              | SPGW     | 1.0002      | 1.0011      |
| Bungala One Solar Farm                                       | 132          | BNGSF1   | SBEM1B              | SBEM     | 0.9567      | 0.9597      |
| Bungala Two Solar Farm                                       | 132          | BNGSF2   | SBEM2B              | SBEM     | 0.9567      | 0.9597      |
| Canunda Wind Farm  | 33           | CNUNDAWF | SSNN1               | SCND     | 0.9742      | 0.9944      |
| Cathedral Rocks Wind Farm                                    | 132          | CATHROCK | SCRK                | SCRK     | 0.9281      | 0.9166      |
| Christies Beach BESS Gen                                     | 66           | CBWWBA1G | SMVE7C              | SMVE     | 1.0036      |             |
| Christies Beach BESS Load                                    | 66           | CBWWBA1L | SMVE8C              | SMVE     | 1.0036      |             |
| Christies Beach Biogas                                       | 66           | CBWWBG1  | SMVE11              | SMVE     | 1.0036      |             |
| Christies Beach Diesel 1                                     | 66           | CBWWDG1  | SMVE12              | SMVE     | 1.0036      |             |



| Generator  | Voltage [kV] | DUID     | Connection Point ID | TNI code | 2022-23 MLF | 2021-22 MLF |
|--|--------------|----------|---------------------|----------|-------------|-------------|
| Christies Beach Diesel 2   | 66           | CBWWDG2  | SMVE13              | SMVE     | 1.0036      |             |
| Christies Beach Solar 1  | 66           | CBWWPV1  | SMVE9C              | SMVE     | 1.0036      |             |
| Christies Beach Solar 2  | 66           | CBWWPV2  | SMVE10              | SMVE     | 1.0036      |             |
| Clements Gap Wind Farm   | 132          | CLEMGPWF | SCGW1P              | SCGW     | 0.9530      | 0.9564      |
| Cummins Lonsdale PS  | 66           | LONSDALE | SMVE1               | SMVE     | 1.0036      | 1.0055      |
| Dalrymple North BESS (Generation)  | 33           | DALNTH01 | SDAN1D              | SDAM     | 0.9432      | 0.9212      |
| Dalrymple North BESS (Load)  | 33           | DALNTHL1 | SDAN2D              | SDAN     | 0.9113      | 0.9073      |
| Dry Creek PS Unit 1  | 66           | DRYCGT1  | SDCA1               | SDPS     | 0.9991      | 1.0002      |
| Dry Creek PS Unit 2  | 66           | DRYCGT2  | SDCA2               | SDPS     | 0.9991      | 1.0002      |
| Dry Creek PS Unit 3  | 66           | DRYCGT3  | SDCA3               | SDPS     | 0.9991      | 1.0002      |
| Hallet 2 Wind Farm   | 275          | HALLWF2  | SMOK1H              | SMOK     | 0.9572      | 0.9606      |
| Hallett 1 Wind Farm  | 275          | HALLWF1  | SHPS2W              | SHPS     | 0.9599      | 0.9630      |
| Hallett PS   | 275          | AGLHAL   | SHPS1               | SHPS     | 0.9599      | 0.9630      |
| Happy Valley BESS (Generation)   | 66           | HVWWBA1G | SHVA1H              | SHVA     | 1.0030      | 1.0052      |
| Happy Valley BESS (Load)   | 66           | HVWWBA1L | SHVA2H              | SHVA     | 1.0030      | 1.0052      |
| Happy Valley Solar   | 66           | HVWWPV1  | SHVA3H              | SHVA     | 1.0030      | 1.0052      |
| Hornsedale Battery (Generation)  | 275          | HPRG1    | SMTL1H              | SMTL     | 0.9652      | 0.9772      |
| Hornsedale Battery (Load)  | 275          | HPRL1    | SMTL2H              | SMTL     | 0.9681      | 0.9693      |
| Hornsedale Wind Farm Stage 1   | 275          | HDWF1    | SHDW1H              | SHDW     | 0.9479      | 0.9518      |
| Hornsedale Wind Farm Stage 2   | 275          | HDWF2    | SHDW2H              | SHDW     | 0.9479      | 0.9518      |
| Hornsedale Wind Farm Stage 3   | 275          | HDWF3    | SHDW3H              | SHDW     | 0.9479      | 0.9518      |
| Ladbroke Grove PS Unit 1   | 132          | LADBROK1 | SPEW1               | SPEW     | 0.9553      | 0.9883      |
| Ladbroke Grove PS Unit 2   | 132          | LADBROK2 | SPEW2               | SPEW     | 0.9553      | 0.9883      |
| Lake Bonney BESS (Generation)  | 33           | LBBG1    | SLBB1L              | SLBB     | 0.9851      | 1.0022      |
| Lake Bonney BESS (Load)  | 33           | LBBL1    | SLBB2L              | SLBB     | 1.0230      | 1.0094      |
| Lake Bonney Wind Farm  | 33           | LKBONNY1 | SMAY1               | SMAY     | 0.9585      | 0.9803      |
| Lake Bonney Wind Farm Stage 2  | 33           | LKBONNY2 | SMAY2               | SMAY     | 0.9585      | 0.9803      |
| Lake Bonney Wind Farm Stage 3  | 33           | LKBONNY3 | SMAY3W              | SMAY     | 0.9585      | 0.9803      |
| Lincoln Gap Wind Farm  | 275          | LGAPWF1  | SLGW1L              | SLGW     | 0.9628      | 0.9644      |
| Lincoln Gap Wind Farm (Stage 2)  | 275          | LGAPWF2  | SLGW4L              | SLGW     | 0.9628      | 0.9644      |
| Mannum-Adelaide Pipeline Pumping Station No 2 Solar Farm – dual MLF (Generation) | 3.3          | MAPS2PV1 | SMA21M              | SMA2     | 0.9944      | 1.0016      |
| Mannum-Adelaide Pipeline Pumping Station No 2 Solar Farm – dual MLF (Load)       | 3.3          | MAPS2PV1 | SMA21M              | SMA2     | 1.0143      | 1.0182      |
| Mannum-Adelaide Pipeline Pumping Station No 3 Solar Farm – dual MLF (Generation) | 3.3          | MAPS3PV1 | SMA31M              | SMA3     | 0.9934      | 1.0012      |
| Mannum-Adelaide Pipeline Pumping Station No 3 Solar Farm – dual MLF (Load)       | 3.3          | MAPS3PV1 | SMA31M              | SMA3     | 1.0141      | 1.0178      |
| Mintaro PS   | 132          | MINTARO  | SMPS                | SMPS     | 0.9793      | 0.9865      |
| Morgan Whyalla Pump Station 1 PV   | 3.3          | MWPS1PV1 | SMW11M              | SMW1     | 1.0018      | 1.0271      |
| Morgan Whyalla Pump Station 2 PV – Dual MLF (Generation)                         | 3.3          | MWPS2PV1 | SMW21M              | SMW2     | 0.9999      | 0.9664      |

| Generator   | Voltage [kV] | DUID     | Connection Point ID | TNI code | 2022-23 MLF | 2021-22 MLF |
|---|--------------|----------|---------------------|----------|-------------|-------------|
| Morgan Whyalla Pump Station 2 PV – Dual MLF (Load)          | 3.3          | MWPS2PV1 | SMW21M              | SMW2     | 0.9999      | 0.9994      |
| Morgan Whyalla Pump Station 3 PV – Dual MLF (Generation)    | 3.3          | MWPS3PV1 | SMW31M              | SMW3     | 0.9717      | 0.9719      |
| Morgan Whyalla Pump Station 3 PV – Dual MLF (Load)          | 3.3          | MWPS3PV1 | SMW31M              | SMW3     | 0.9864      | 0.9927      |
| Morgan Whyalla Pump Station 4 PV – Dual MLF (Generation)    | 3.3          | MWPS4PV1 | SMW41M              | SMW4     | 0.9889      | 0.9751      |
| Morgan Whyalla Pump Station 4 PV – Dual MLF (Load)          | 3.3          | MWPS4PV1 | SMW41M              | SMW4     | 0.9889      | 0.9874      |
| Morphett Vale East 66                                       | 66           | SATGS1   | SMVG1L              | SMVG     | 1.0015      | 1.0021      |
| Mt Millar Wind Farm   | 33           | MTMILLAR | SMTM1               | SMTM     | 0.9245      | 0.9287      |
| Murray Bridge - Hahndorf Pipeline 2 – Dual MLF (Generation) | 11           | MBPS2PV1 | SMH21M              | SMH2     | 1.0190      | 1.0058      |
| Murray Bridge - Hahndorf Pipeline 2 – Dual MLF (Load)       | 11           | MBPS2PV1 | SMH21M              | SMH2     | 1.0190      | 1.0205      |
| North Brown Hill Wind Farm                                  | 275          | NBHWF1   | SBEL1A              | SBEL     | 0.9539      | 0.9571      |
| O.C.P.L. Unit 1   | 66           | OSB-AG   | SNBN1               | SOCP     | 0.9999      | 0.9999      |
| Pelican Point PS  | 275          | PPCCGT   | SPPT                | SPPT     | 0.9983      | 0.9987      |
| Port Augusta Renewable Energy Park - Wind                   | 275          | PAREPW1  | SDAP1P              | SDAP     | 0.9641      | 0.9728      |
| Port Lincoln 3  | 33           | POR03    | SPL31P              | SPL3     | 0.9945      | 0.9467      |
| Port Lincoln PS   | 132          | POR01    | SPLN1               | SPTL     | 0.9899      | 0.9505      |
| Pt Stanvac PS   | 66           | PTSTAN1  | SMVE3P              | SMVE     | 1.0036      | 1.0055      |
| Quarantine PS Unit 1  | 66           | QPS1     | SQPS1               | SQPS     | 0.9871      | 0.9858      |
| Quarantine PS Unit 2  | 66           | QPS2     | SQPS2               | SQPS     | 0.9871      | 0.9858      |
| Quarantine PS Unit 3  | 66           | QPS3     | SQPS3               | SQPS     | 0.9871      | 0.9858      |
| Quarantine PS Unit 4  | 66           | QPS4     | SQPS4               | SQPS     | 0.9871      | 0.9858      |
| Quarantine PS Unit 5  | 66           | QPS5     | SQPS5Q              | SQPS     | 0.9871      | 0.9858      |
| Snapper Point PS  | 275          | SNAPPER1 | SNPT1S              | SNPT     | 0.9990      | 0.9990      |
| Snowtown Wind Farm  | 33           | SNOWTWN1 | SNWF1T              | SNWF     | 0.9162      | 0.9134      |
| Snowtown Wind Farm Stage 2 – North                          | 275          | SNOWNTH1 | SBLWS1              | SBLW     | 0.9666      | 0.9678      |
| Snowtown Wind Farm Stage 2 – South                          | 275          | SNOWSTH1 | SBLWS2              | SBLW     | 0.9666      | 0.9678      |
| Snuggery PS Units 1 to 3                                    | 132          | SNUG1    | SSGA1               | SSPS     | 0.9388      | 0.9533      |
| Starfish Hill Wind Farm                                     | 66           | STARHLWF | SMVE2               | SMVE     | 1.0036      | 1.0055      |
| Tailem Bend Solar Farm                                      | 132          | TBSF1    | STBS1T              | STBS     | 1.0029      | 1.0113      |
| Tatiara Meat Co   | 33           | TATIARA1 | SKET1E              | SKET     | 1.0119      | 1.0263      |
| The Bluff wind Farm   | 275          | BLUFF1   | SBEL2P              | SBEL     | 0.9539      | 0.9571      |
| Torrens Island PS A Unit 3                                  | 275          | TORRA3   | STSA3               | STPS     | 0.9994      | 0.9999      |
| Torrens Island PS B Unit 1                                  | 275          | TORRB1   | STSB1               | STPS     | 0.9994      | 0.9999      |
| Torrens Island PS B Unit 2                                  | 275          | TORRB2   | STSB2               | STPS     | 0.9994      | 0.9999      |
| Torrens Island PS B Unit 3                                  | 275          | TORRB3   | STSB3               | STPS     | 0.9994      | 0.9999      |
| Torrens Island PS B Unit 4                                  | 275          | TORRB4   | STSB4               | STPS     | 0.9994      | 0.9999      |
| Torrens Island PS Load                                      | 66           | TORN1    | STSYL               | STSY     | 1.0000      | 1.0000      |

| Generator              | Voltage [kV] | DUID     | Connection Point ID | TNI code | 2022-23 MLF | 2021-22 MLF |
|------------------------|--------------|----------|---------------------|----------|-------------|-------------|
| Waterloo Wind Farm     | 132          | WATERLWF | SWLE1R              | SWLE     | 0.9582      | 0.9594      |
| Wattle Point Wind Farm | 132          | WPWF     | SSYP1               | SSYP     | 0.8174      | 0.8110      |
| Willogoleche Wind Farm | 275          | WGWF1    | SWGL1W              | SWGL     | 0.9549      | 0.9583      |
| Wingfield 1 LFG PS     | 66           | WINGF1_1 | SKLB1W              | SKLB     | 1.0010      | 1.0008      |
| Wingfield 2 LFG PS     | 66           | WINGF2_1 | SNBN2W              | SNBN     | 1.0008      | 1.0005      |

## 1.5 Tasmania marginal loss factors

Table 11 Tasmania loads

| Location                | Voltage (kV) | TNI code | 2022-23 MLF | 2021-22 MLF |
|-------------------------|--------------|----------|-------------|-------------|
| Arthurs Lake            | 6.6          | TAL2     | 0.9774      | 0.9815      |
| Avoca                   | 22           | TAV2     | 1.0104      | 1.0023      |
| Boyer SWA               | 6.6          | TBYA     | 1.0144      | 1.0003      |
| Boyer SWB               | 6.6          | TBYB     | 1.0248      | 1.0092      |
| Bridgewater             | 11           | TBW2     | 1.0206      | 1.0154      |
| Burnie                  | 22           | TBU3     | 0.9872      | 0.9781      |
| Chapel St.              | 11           | TCS3     | 1.0051      | 1.0001      |
| Comalco                 | 220          | TCO1     | 1.0006      | 1.0006      |
| Creek Road              | 33           | TCR2     | 1.0069      | 1.0009      |
| Derby                   | 22           | TDE2     | 0.9614      | 0.9483      |
| Derwent Bridge          | 22           | TDB2     | 0.9177      | 0.9117      |
| Devonport               | 22           | TDP2     | 0.9880      | 0.9785      |
| Electrona               | 11           | TEL2     | 1.0218      | 1.0157      |
| Emu Bay                 | 11           | TEB2     | 0.9850      | 0.9746      |
| Fisher (Rowallan)       | 220          | TFI1     | 0.9655      | 0.9561      |
| Fisher 220 DNSP         | 220          | TFI2     | 0.9655      | 0.9561      |
| George Town             | 22           | TGT3     | 1.0013      | 1.0020      |
| George Town (Basslink)  | 220          | TGT1     | 1.0000      | 1.0000      |
| Gordon                  | 22           | TGO2     | 0.9879      | 0.9710      |
| Greater Hobart Area VTN |              | TVN1     | 1.0092      | 1.0027      |
| Hadspen                 | 22           | THA3     | 0.9931      | 0.9902      |
| Hampshire               | 110          | THM2     | 0.9834      | 0.9736      |
| Huon River              | 11           | THR2     | 1.0299      | 1.0189      |
| Kermandie               | 11           | TKE2     | 1.0288      | 1.0203      |
| Kingston                | 33           | TK13     | 1.0119      | 1.0067      |
| Kingston                | 11           | TKI2     | 1.0165      | 1.0114      |
| Knights Road            | 11           | TKR2     | 1.0267      | 1.0176      |
| Lindisfarne             | 33           | TLF2     | 1.0101      | 1.0039      |

| Location         | Voltage (kV) | TNI code | 2022-23 MLF | 2021-22 MLF |
|------------------|--------------|----------|-------------|-------------|
| Meadowbank       | 22           | TMB2     | 0.9972      | 0.9829      |
| Mornington       | 33           | TMT2     | 1.0104      | 1.0051      |
| Mowbray          | 22           | TMY2     | 0.9924      | 0.9896      |
| New Norfolk      | 22           | TNN2     | 1.0054      | 0.9954      |
| Newton           | 22           | TNT2     | 0.9709      | 0.9524      |
| Newton           | 11           | TNT3     | 0.9582      | 0.9369      |
| North Hobart     | 11           | TNH2     | 1.0066      | 0.9996      |
| Norwood          | 22           | TNW2     | 0.9921      | 0.9882      |
| Palmerston       | 22           | TPM3     | 0.9759      | 0.9728      |
| Port Latta       | 22           | TPL2     | 0.9644      | 0.9480      |
| Que              | 22           | TQU2     | 0.9805      | 0.9612      |
| Queenstown       | 11           | TQT3     | 0.9623      | 0.9437      |
| Queenstown       | 22           | TQT2     | 0.9617      | 0.9434      |
| Railton          | 22           | TRA2     | 0.9876      | 0.9783      |
| Risdon           | 33           | TRI4     | 1.0133      | 1.0042      |
| Risdon           | 11           | TRI3     | 1.0184      | 1.0046      |
| Rokeby           | 11           | TRK2     | 1.0138      | 1.0094      |
| Rosebery         | 44           | TRB2     | 0.9694      | 0.9505      |
| Savage River     | 22           | TSR2     | 1.0054      | 0.9876      |
| Scottsdale       | 22           | TSD2     | 0.9734      | 0.9639      |
| Sheffield        | 22           | TSH3     | 0.9813      | 0.9713      |
| Smithton         | 22           | TST2     | 0.9507      | 0.9330      |
| Sorell           | 22           | TSO2     | 1.0300      | 1.0264      |
| St Leonard       | 22           | TSL2     | 0.9935      | 0.9882      |
| St. Marys        | 22           | TSM2     | 1.0271      | 1.0153      |
| Starwood         | 110          | TSW1     | 1.0001      | 1.0006      |
| Tamar Region VTN |              | TVN2     | 0.9937      | 0.9908      |
| Temco            | 110          | TTE1     | 1.0030      | 1.0032      |
| Trevallyn        | 22           | TTR2     | 0.9932      | 0.9901      |
| Triabunna        | 22           | TTB2     | 1.0395      | 1.0300      |
| Tungatinah       | 22           | TTU2     | 0.9176      | 0.9142      |
| Ulverstone       | 22           | TUL2     | 0.9864      | 0.9772      |
| Waddamana        | 22           | TWA2     | 0.9298      | 0.9395      |
| Wayatinah        | 11           | TWY2     | 0.9910      | 0.9802      |
| Wesley Vale      | 22           | TWV2     | 0.9847      | 0.9753      |

Table 12 Tasmania generation

| Generator description  | Voltage [kV] | DUID    | Connection Point ID | TNI code | 2022-23 MLF | 2021-22 MLF |
|------------------------|--------------|---------|---------------------|----------|-------------|-------------|
| Basslink (George Town) | 220          | BLNKTAS | TGT11               | TGT1     | 1.0000      | 1.0000      |

| Generator description                   | Voltage [kV] | DUID      | Connection Point ID | TNI code | 2022-23 MLF | 2021-22 MLF |
|---|--------------|-----------|---------------------|----------|-------------|-------------|
| Bastyan                                 | 220          | BASTYAN   | TFA11               | TFA1     | 0.9334      | 0.9286      |
| Bell Bay No.3                           | 110          | BBTHREE1  | TBB11               | TBB1     | 0.9975      | 0.9982      |
| Bell Bay No.3                           | 110          | BBTHREE2  | TBB12               | TBB1     | 0.9975      | 0.9982      |
| Bell Bay No.3                           | 110          | BBTHREE3  | TBB13               | TBB1     | 0.9975      | 0.9982      |
| Bluff Point and Studland Bay Wind Farms | 110          | WOOLNTH1  | TST11               | TST1     | 0.8951      | 0.8794      |
| Butlers Gorge                           | 110          | BUTLERSG  | TBG11               | TBG1     | 0.9140      | 0.9049      |
| Catagunya                               | 220          | LI_WY_CA  | TLI11               | TLI1     | 0.9845      | 0.9789      |
| Cethana                                 | 220          | CETHANA   | TCE11               | TCE1     | 0.9544      | 0.9512      |
| Cluny                                   | 220          | CLUNY     | TCL11               | TCL1     | 0.9850      | 0.9798      |
| Devils gate                             | 110          | DEVILS_G  | TDG11               | TDG1     | 0.9594      | 0.9566      |
| Fisher                                  | 220          | FISHER    | TFI11               | TFI1     | 0.9655      | 0.9561      |
| Gordon                                  | 220          | GORDON    | TGO11               | TGO1     | 0.9400      | 0.9280      |
| Granville Harbour Wind Farm             | 220          | GRANWF1   | TGH11G              | TGH1     | 0.9543      | 0.9314      |
| John Butters                            | 220          | JBUTTERS  | TJB11               | TJB1     | 0.9395      | 0.9258      |
| Lake Echo                               | 110          | LK_ECHO   | TLE11               | TLE1     | 0.9142      | 0.9133      |
| Lemonthyme                              | 220          | LEM_WIL   | TSH11               | TSH1     | 0.9672      | 0.9608      |
| Liapootah                               | 220          | LI_WY_CA  | TLI11               | TLI1     | 0.9845      | 0.9789      |
| Mackintosh                              | 110          | MACKNTSH  | TMA11               | TMA1     | 0.9186      | 0.9158      |
| Meadowbank                              | 110          | MEADOWB K | TMB11               | TMB1     | 0.9824      | 0.9830      |
| Midlands PS                             | 22           | MIDLDP S1 | TAV21M              | TAV2     | 1.0104      | 1.0023      |
| Musselroe                               | 110          | MUSSELR1  | TDE11M              | TDE1     | 0.9168      | 0.8999      |
| Paloona                                 | 110          | PALOONA   | TPA11               | TPA1     | 0.9642      | 0.9587      |
| Poatina                                 | 220          | POAT220   | TPM11               | TPM1     | 0.9771      | 0.9691      |
| Poatina                                 | 110          | POAT110   | TPM21               | TPM2     | 0.9625      | 0.9512      |
| Reece No.1                              | 220          | REECE1    | TRCA1               | TRCA     | 0.9229      | 0.9193      |
| Reece No.2                              | 220          | REECE2    | TRCB1               | TRCB     | 0.9195      | 0.9147      |
| Repulse                                 | 220          | REPULSE   | TCL12               | TCL1     | 0.9850      | 0.9798      |
| Rowallan                                | 220          | ROWALLAN  | TFI12               | TFI1     | 0.9655      | 0.9561      |
| St Leonards Scheduled Load              | 22           | SLDCBLK1  | TSL3SL1S            | TSL3     | 0.9945      | 0.9888      |
| Tamar Valley CCGT                       | 220          | TVCC201   | TTV11A              | TTV1     | 1.0000      | 1.0000      |
| Tamar Valley OCGT                       | 110          | TVPP104   | TBB14A              | TBB1     | 0.9975      | 0.9982      |
| Tarraleah                               | 110          | TARRALEA  | TTA11               | TTA1     | 0.9216      | 0.9106      |
| Trevallyn                               | 110          | TREVALLN  | TTR11               | TTR1     | 0.9891      | 0.9848      |
| Tribute                                 | 220          | TRIBUTE   | TTI11               | TTI1     | 0.9263      | 0.9133      |
| Tungatinah                              | 110          | TUNGATIN  | TTU11               | TTU1     | 0.8795      | 0.8859      |
| Wayatinah                               | 220          | LI_WY_CA  | TLI11               | TLI1     | 0.9845      | 0.9789      |
| Wild Cattle Hill Wind Farm              | 220          | CTHLWF1   | TWC11C              | TWC1     | 0.9888      | 0.9809      |
| Wilmot                                  | 220          | LEM_WIL   | TSH11               | TSH1     | 0.9672      | 0.9608      |

## 2 Changes in marginal loss factors

### 2.1 Marginal loss factors in the NEM

The MLF for a connection point represents the marginal electrical transmission losses in electrical power flow between that connection point and the RRN for the region in which the connection point is located.

An MLF below 1 indicates that an incremental increase in power flow from the connection point to the RRN would increase total losses in the network. An MLF above 1 indicates the opposite.

According to the current NEM design, the difference between the cost of electricity at a connection point remote from the RRN and the cost of electricity at the RRN is directly proportional to the MLF for the connection point. If the MLF for a connection point is 0.9, then the effective values of electricity purchased or sold at that connection point will be 90% of the regional reference price. Consequently, a fall in MLF at a connection point is likely to have a positive impact on customers and a negative impact on generators.

More information on the treatment of electricity losses in the NEM is available on AEMO's website<sup>5</sup>.

### 2.2 Reasons marginal loss factors change

There are three main reasons why the MLF for a connection point changes from year to year:

1. Changes to projected power flows over the transmission network caused by projected changes to power system generation and demand, including building new generation, retirement of power stations, and revised electricity consumption forecasts.
  - If the projected power flow from a connection point towards the RRN increases, then the MLF for that connection point would be expected to decrease. Conversely, if the projected power flow from a connection point towards the regional reference node decreases, then the MLF for that connection point would be expected to increase.
2. Forecast variations in seasonal patterns, diurnal patterns, intra-year commencement of operation, intra-year cessation of operation.
  - As MLF outcomes are volume weighted, year-on-year variations in patterns of either consumption or export (load and generation respectively) can result in material variations in MLF outcomes. For further detail on the impact of volume weighting on MLF outcomes, please refer to Appendix A3.
3. Changes to the impedance of the transmission network caused by augmentation of the transmission network, such as building new transmission lines.
  - If augmentations decrease the impedance of the transmission network between a connection point and the RRN, then the MLF for the connection point would be expected to move closer to 1.

<sup>5</sup> AEMO, Treatment of Loss Factors in the National Electricity Market, 1 July 2012, at [https://www.aemo.com.au/-/media/Files/Electricity/NEM/Security\\_and\\_Reliability/Loss\\_Factors\\_and\\_Regional\\_Boundaries/2016/Treatment\\_of\\_Loss\\_Factors\\_in\\_the\\_NEM.pdf](https://www.aemo.com.au/-/media/Files/Electricity/NEM/Security_and_Reliability/Loss_Factors_and_Regional_Boundaries/2016/Treatment_of_Loss_Factors_in_the_NEM.pdf).

The location of new generation projects and load developments on the transmission and distribution network has a significant impact on the MLFs in an area. As more generation is connected to electrically weak areas of the network that are remote from the RRN, MLFs in these areas will continue to decline.

## 2.3 Changes between the preliminary 2022-23 MLFs and the final 2022-23 MLFs

In December 2021, AEMO published a preliminary report containing indicative MLFs for 2022-23. While the preliminary report is intended to provide stakeholders with early insight into possible future MLF outcomes, there are several variances between the input data utilised in the preliminary and draft/final MLF studies. Table 13 provides a high level summary of these differences.

**Table 13 Preliminary vs draft/final study variations**

| Item                                   | Preliminary   | Draft/final  |
|--|---|--|
| <b>New generation projects</b>         | Inclusion based on generator project status in October 2021 Generation Information page <sup>A</sup> . Projects are included where the status is COM or COM* <sup>B</sup> . | Inclusion based on generator project status in February 2022 Generation Information page. Projects are included where the status is COM or COM*. |
| <b>Load profiles</b>                   | Scaled historical load profiles from 2020-21.   | Forecast load profiles for 2022-23.  |
| <b>Network model</b>                   | 2021-22 MLF study network model.  | Revised network model incorporating future augmentations that are committed.   |
| <b>Intra-regional limit management</b> | Intra-regional limits as identified and incorporated into the 2021-22 MLF study.  | Intra-regional limits reviewed for 2022-23, revised and incorporated into the 2022-23 MLF study.   |

A. The Generation Information page provides stakeholders with information on the capacity of existing, withdrawn, committed, and proposed generation projects in the NEM. See <https://www.aemo.com.au/Electricity/National-Electricity-Market-NEM/Planning-and-forecasting/Generation-information>.

B. Committed (COM) projects meet all five of AEMO's commitment criteria (relating to site, components, planning, finance, and date). Committed\* (COM\*) projects are classified as Advanced, have commenced construction or installation, and meet AEMO's site, finance, and date criteria, but are required to meet only one of the components or planning criteria.

## 2.4 Changes between 2021-22 MLFs and 2022-23 MLFs

This section summarises the changes in MLFs for 2021-22 compared to the 2022-23 MLFs at a sub-regional level, and the general trends driving the changes. Appendix A2 provides more detailed information on the inputs, methodology, and assumptions for the 2022-23 calculations, and key changes from 2021-22.

For further details on how MLFs are calculated, refer to Section A1.2.

Figure 1 shows the annual projected gigawatt-hours (GWh) flows for all interconnectors within the NEM for both the 2021-22 and 2022-23 MLF studies.

**Figure 1 2021-22 vs 2022-23 MLF interconnector flow projections**

### 2.4.1 Changes to marginal loss factors in Queensland

Figure 2 shows a geographical representation of MLF variations at Queensland connection points between 2021-22 and 2022-23. Table 14 shows the average sub-regional year-on-year MLF variations between 2021-22 and 2022-23.

The primary drivers of change in Queensland are variations in projected generation within Queensland between 2021-22 and 2022-23.

The north sub-region MLFs have decreased for both generation and load, by 2.32% and 0.17% respectively. This has primarily been driven by a forecast increase in generation within this sub-region due to committed projects.

The central sub-region MLFs have increased for both generation and load, by 1.13% and 0.93% respectively. This has primarily been driven by a forecast decrease in thermal generation within this sub-region, which has been offset by an increase in semi-scheduled generation capacity within Queensland.



Figure 2 Queensland changes compared to 2022-23 MLFs




Table 14 Queensland sub-region year-on-year average MLF variation

| Sub-region | Average MLF change 2021-22 to 2022-23 |        |
|------------|---------------------------------------|--------|
|            | Gen                                   | Load   |
| Central    | 1.13%                                 | 0.93%  |
| North      | -2.32%                                | -0.17% |
| South-east | 0.12%                                 | 0.02%  |
| South-west | 0.14%                                 | -0.24% |



## 2.4.2 Changes to marginal loss factors in New South Wales

Figure 3 shows a geographical representation of MLF variations at New South Wales connection points between 2021-22 and 2022-23. Table 15 shows the average sub-regional year on year MLF variations between 2021-22 and 2022-23.

The primary drivers of change in New South Wales are variations in projected imports from both Victoria and Queensland (coinciding with increases in interconnector capacity expected from “QNI Minor” and “VNI Minor” projects), and a projected increase in remote generation and the closure of the of Liddell power station.

Notably, in addition to the above the projected diurnal nature of flows between Victoria and New South Wales have changed. During hours of daylight, northerly flows have been materially suppressed. This has partially been driven by a material increase in the capacity of grid scale solar generation within both New South Wales and Queensland.

The north New South Wales sub-region MLFs decreased for both generation and load, by 2.77% and 0.72% respectively. This has primarily been driven by a material increase in generation within this sub-region, especially generation connected to the 132 kV network where committed generation projects are also due to connect. Notably, the generation capacity within this region is almost entirely made up of solar. The resultant strong correlation of high output at times of low demand has increased the downward pressure on the underlying MLF outcomes for these generators.

The Hunter sub-region forecast MLFs have slightly increased for both generation and load, despite the increased generation capacity in north New South Wales the closure of Liddell has resulted in a material reduction in the forecast level of generation within the Hunter sub-region.

The south-west sub-region has seen a material increase to forecast MLF outcomes for generation with a 2.84% increase on average, the key driver of this change is a combination of much of this generation being solar and the diurnal variation in imports from Victoria which has resulted in a projected decrease in northerly flows during daylight hours. While the average generation MLF outcomes have increased, there is generation within this sub-region than has seen material declines. This is primarily due to the projected behaviour of these generators and the result impact on weighting.

While the Snowy and ACT sub-regions have on average seen reductions to forecast MLF outcomes, solar generation has seen increases driven by the diurnal variation in imports from Victoria.

Figure 3 New South Wales changes compared to 2022-23 MLFs




Table 15 New South Wales sub-region year-on-year average MLF variation

| Sub-region | Average MLF change 2021-22 to 2022-23 |        |
|------------|---------------------------------------|--------|
|            | Gen                                   | Load   |
| ACT        | -0.30%                                | 0.52%  |
| Hunter     | 0.56%                                 | 0.29%  |
| North      | -2.77%                                | -0.72% |
| South-west | 2.84%                                 | 0.58%  |
| Snowy      | -0.96%                                | -0.78% |
| Sydney     | -0.89%                                | 0.00%  |
| West       | -0.41%                                | 0.04%  |

### 2.4.3 Changes to marginal loss factors in Victoria

Figure 4 shows a geographical representation of MLF variations at Victorian connection points between 2021-22 and 2022-23. Table 16 shows the average sub-regional year on year MLF variations between 2021-22 and 2022-23.


The primary drivers of change in Victoria are variations in projected exports to New South Wales, projected imports from Heywood, and projected exports from Murraylink between 2021-22 and 2022-23.

The north-west sub-region has seen slight increases of 0.96% to MLF outcomes for generation, primarily due to intra-regional limits. For north-west loads an average decrease of 1.67% has been observed, this is primarily the result of increased generation within this sub-region as well as decreased exports to New South Wales.

The north sub-region has seen material decreases of 2.39% for generation and 1.26% for load, this is primarily due to decreased exports to New South Wales.

The west sub-region has seen relatively small increases to both load and generation, this is primarily due to a material decrease in imports from South Australia.

**Figure 4** Victoria changes compared to 2022-23 MLFs



**Table 16** Victoria sub-region year-on-year average MLF variation

| Sub-region     | Average MLF change 2021-22 to 2022-23 |        |
|----------------|---------------------------------------|--------|
|                | Gen                                   | Load   |
| Central        | -0.35%                                | 0.33%  |
| Latrobe Valley | 0.32%                                 | 1.00%  |
| Melbourne      | -0.02%                                | 0.08%  |
| North          | -2.39%                                | -1.26% |
| North-west     | 0.96%                                 | -1.67% |
| West           | 0.20%                                 | 0.46%  |

## 2.4.4 Changes to marginal loss factors in South Australia

Figure 5 shows a geographical representation of MLF variations at South Australian connection points between 2021-22 and 2022-23. Table 17 shows the average sub-regional year on year MLF variations between 2021-22 and 2022-23.

The primary drivers of change in South Australia are projected variations in exports to Victoria via Heywood which have been materially impacted by the restriction on easterly flows as a result of a Para static VAR compensator (SVC) outage. Additionally, easterly flows have been further reduced by the fact the vast majority of new generation capacity is outside of South Australia.

The Para SVC outage has resulted in easterly flows on Heywood being limited to 420MW until 4 January 2023, for further detail refer to Table 29 in section A2.6 of this report.

The Riverland sub-region MLFs decreased on average by 2.57%, primarily driven by increased generation (combined with load) within this sub-region.

The south-east sub-region MLFs decreased on average by 4.85% for generation and 1.57% for load, primarily driven by a projected decrease in exports to Victoria via Heywood as a result of the Para SVC outage.

**Figure 5 South Australia changes to 2022-23 MLFs**




Table 17 South Australia sub-region year-on-year average MLF variation

| Sub-region | Average MLF change 2021-22 to 2022-23 |        |
|------------|---------------------------------------|--------|
|            | Gen                                   | Load   |
| Adelaide   | -0.06%                                | -0.05% |
| North      | -0.04%                                | 0.41%  |
| Riverland  | NA                                    | -2.57% |
| South-east | -4.85%                                | -1.57% |

### 2.4.5 Changes to marginal loss factors in Tasmania

Figure 6 shows a geographical representation of MLF variations at Tasmanian connection points between 2021-22 and 2022-23. Table 18 shows the average sub-regional year on year MLF variations between 2021-22 and 2022-23.

The primary drivers of change in Tasmania are a projected reversal in the direction of net Basslink flows between 2021-22 and 2022-23.

All subregions except Georgetown have seen increases in average MLF outcomes. This is due to the increased flows from the RRN to these sub-regions which as mentioned is supported by the change in Basslink flows.



Figure 6 Tasmania changes to 2022-23 MLFs




Table 18 Tasmania sub-region year-on-year average MLF variation

| Sub-region | Average MLF change 2021-22 to 2022-23 |        |
|------------|---------------------------------------|--------|
|            | Gen                                   | Load   |
| Georgetown | 0.06%                                 | -0.03% |
| North-west | 0.44%                                 | 1.23%  |
| North      | 1.28%                                 | 0.65%  |
| South      | 0.40%                                 | 0.73%  |
| West coast | 0.78%                                 | 2.05%  |

### 3 Inter-regional loss factor equations

This section describes the inter-regional loss factor equations.

Inter-regional loss factor equations describe the variation in loss factor at one RRN with respect to an adjacent RRN. These equations are necessary to cater for the large variations in loss factors that may occur between RRNs as a result of different power flow patterns. This is important in minimising the distortion of economic dispatch of generating units.

Loss factor equation (South Pine 275 referred to Sydney West 330)

$$= 0.8870 + 2.0126E-04*NQt + 1.5623E-05*Qd + 5.6774E-06*Nd$$

Loss factor equation (Sydney West 330 referred to Thomastown 66)

$$= 1.0912 + 1.8863E-04*VNt + -8.2056E-06*Vd + 3.5899E-06*Nd + -5.7448E-05*Sd$$

Loss factor equation (Torrens Island 66 referred to Thomastown 66)

$$= 1.0181 + 3.5925E-04*VSAAt + -3.4191E-06*Vd + 1.8182E-08*Sd$$

Where:

Qd = Queensland demand

Vd = Victorian demand

Nd = New South Wales demand


Sd = South Australian demand

NQt = transfer from New South Wales to Queensland

VNt = transfer from Victoria to New South Wales


VSAAt = transfer from Victoria to South Australia



**Figure 7** MLF (South Pine 275 referred to Sydney West 330)**Table 19** South Pine 275 referred to Sydney West 330 MLF versus New South Wales to Queensland flow coefficient statistics

| Coefficient       | Qd         | Nd         | NQt        | Constant |
|-------------------|------------|------------|------------|----------|
| Coefficient value | 1.5623E-05 | 5.6774E-06 | 2.0126E-04 | 0.887    |


**Figure 8 MLF (Sydney West 330 referred to Thomastown 66)**



**Table 20 Sydney West 330 referred to Thomastown 66 MLF versus Victoria to New South Wales flow coefficient statistics**

| Coefficient       | Sd          | Nd         | Vd          | VNt        | Constant |
|-------------------|-------------|------------|-------------|------------|----------|
| Coefficient value | -5.7448E-05 | 3.5899E-06 | -8.2056E-06 | 1.8863E-04 | 1.0912   |

**Figure 9** MLF (Torrens Island 66 referred to Thomastown 66)



**Table 21** Torrens Island 66 referred to Thomastown 66 MLF versus Victoria to South Australia flow coefficient statistics

| Coefficient       | Sd         | Vd          | VSA <sub>t</sub> | Constant |
|-------------------|------------|-------------|------------------|----------|
| Coefficient value | 1.8182E-08 | -3.4191E-06 | 3.5925E-04       | 1.0181   |

## 4 Inter-regional loss equations

This section describes how inter-regional loss equations are derived.

Inter-regional loss equations are derived by integrating the equation (Loss factor – 1) with respect to the interconnector flow, i.e.:

$$\text{Losses} = \int (\text{Loss factor} - 1) d\text{Flow}$$

South Pine 275 referred to Sydney West 330 notional link average losses

$$= (-0.1130 + 1.5623\text{E-}05 \cdot Q_d + 5.6774\text{E-}06 \cdot N_d) \cdot N_{Qt} + 1.0063\text{E-}04 \cdot (N_{Qt})^2$$

Sydney West 330 referred to Thomastown 66 notional link average losses

$$= (0.0912 + -8.2056\text{E-}06 \cdot V_d + 3.5899\text{E-}06 \cdot N_d + -5.7448\text{E-}05 \cdot S_d) \cdot V_{Nt} + 9.4314\text{E-}05 \cdot (V_{Nt})^2$$

Torrens Island 66 referred to Thomastown 66 notional link average losses

$$= (0.0181 + -3.4191\text{E-}06 \cdot V_d + 1.8182\text{E-}08 \cdot S_d) \cdot V_{SAt} + 1.7963\text{E-}04 \cdot (V_{SAt})^2$$

Where:

$Q_d$  = Queensland demand

$V_d$  = Victorian demand

$N_d$  = New South Wales demand

$S_d$  = South Australia demand


$N_{Qt}$  = transfer from New South Wales to Queensland

$V_{Nt}$  = transfer from Victoria to New South Wales

$V_{SAt}$  = transfer from Victoria to South Australia




**Figure 10** Average losses for New South Wales – Queensland notional link




New South Wales to Queensland notional link losses versus New South Wales to Queensland notional link flow

**Figure 11** Average losses for Victoria - New South Wales notional link



Victoria to New South Wales notional link losses versus Victoria to New South Wales notional link flow

**Figure 12** Average losses for Victoria – South Australia notional link



Victoria to South Australia notional link losses versus Victoria to South Australia notional link flow

## 5 Basslink, Murraylink, Terranora loss equations


This section describes the loss equations for the DC interconnectors.

### 5.1 Basslink

The loss factor model for Basslink is made up of the following parts:

- George Town 220 kV MLF referred to Tasmania RRN = 1.0000
- Basslink (Loy Yang PS Switchyard) 500 kV MLF referred to Victorian RRN is 0.9821 when exporting power to Tasmania and 0.9749 when importing power from Tasmania.
- Receiving end dynamic loss factor referred to the sending end =  $0.99608 + 2.0786 \times 10^{-4} \times P(\text{receive})$ , where  $P(\text{receive})$  is the Basslink flow measured at the receiving end.

**Figure 13 Basslink loss factor model**



The equation describing the losses between the George Town 220 kV and Loy Yang 500 kV connection points can be determined by integrating the (loss factor equation – 1), giving:

$$P(\text{send}) = P(\text{receive}) + [(-3.92 \times 10^{-3}) \times P(\text{receive}) + (1.0393 \times 10^{-4}) \times P(\text{receive})^2 + 4]$$

where:

$P(\text{send})$ : Power in megawatts (MW) measured at the sending end,

$P(\text{receive})$ : Power in MW measured at the receiving end.

The model is limited from 40 MW to 630 MW. When the model falls below 40 MW, this is within the  $\pm 50$  MW 'no-go zone' requirement for Basslink operation.

## 5.2 Murraylink

Murraylink is a regulated interconnector. In accordance with clause 3.6.1(a) of the Rules, the Murraylink loss model consists of a single dynamic MLF from the Victorian RRN to the South Australian RRN.

The measurement point is the 132 kV connection to the Monash converter, which effectively forms part of the boundary between the Victorian and South Australian regions.

The losses between the Red Cliffs 220 kV and Monash 132 kV connection points are given by the following equation:

$$\text{Losses} = (0.0039 * \text{Flow}_t + 2.8177 * 10^{-4} * \text{Flow}_t^2)$$

AEMO determined the following Murraylink MLF model using regression analysis:

$$\text{Murraylink MLF (Torrens Island 66 referred to Thomastown 66)} = 0.9376 + 1.8360\text{E-}03 * \text{Flow}_t$$

This model, consisting of a constant and a Murraylink flow coefficient, is suitable because most of the loss is due to variations in the Murraylink flow, and other potential variables do not improve the model.

The regression statistics for this Murraylink loss factor model are presented in the following table:

**Table 22 Regression statistics for Murraylink**

| Coefficient       | Murraylink flow | Constant   |
|-------------------|-----------------|------------|
| Coefficient Value | 1.8360E-03      | 9.3761E-01 |


The loss model for a regulated Murraylink interconnector can be determined by integrating (MLF-1), giving:

$$\text{Murraylink los} = -0.0624 * \text{Flow}_t + 9.1798\text{E-}04 * (\text{Flow}_t)^2$$






**Figure 14** Murraylink MLF (Torrens Island 66 referred to Thomastown 66)



Torrens Island 66 referred to Thomastown 66 versus Murraylink interconnector flow (Victoria to South Australia).

**Figure 15** Average losses for Murraylink interconnector (Torrens Island 66 referred to Thomastown 66)



Murraylink notional link losses versus Murraylink flow (Victoria to South Australia).

## 5.3 Terranora

Terranora is a regulated interconnector. In accordance with clause 3.6.1(a) of the Rules, the Terranora loss model consists of a single dynamic MLF from the New South Wales RRN to the Queensland RRN.

The measurement point is 10.8 km north from Terranora on the two 110 kV lines between Terranora and Mudgeeraba, which effectively forms part of the boundary between the New South Wales and Queensland regions.

The losses between the Mullumbimby 132 kV and Terranora 110 kV connection points are given by the following equation:

$$\text{Losses} = (-0.0013 * \text{Flow}_t + 2.7372 * 10^{-4} * \text{Flow}_t^2)$$

AEMO determined the following Terranora MLF model using regression analysis:

Terranora interconnector MLF (South Pine 275 referred to Sydney West 330)

$$= 1.0673 + 2.7640\text{E-}03 * \text{Flow}_t$$

This model consisting of a constant and a Terranora flow coefficient is suitable because most of the loss is due to variations in the Terranora flow and other potential variables do not improve the model.

The regression statistics for this Terranora loss factor model are presented in the following table:


**Table 23 Regression statistics for Terranora**

| Coefficient       | Terranora Flow | Constant |
|-------------------|----------------|----------|
| Coefficient Value | 2.7640E-03     | 1.0673   |

The loss model for a regulated Terranora interconnector can be determined by integrating (MLF-1), giving:


$$\text{Terranora loss} = 0.0673 * \text{Flow} + 1.3820\text{E-}03 * (\text{Flow}_t)^2$$

**Figure 16** Terranora interconnector MLF (South Pine 275 referred to Sydney West 330)



South Pine 275 referred to Sydney West 330 MLF versus Terranora interconnector flow (New South Wales to Queensland).

**Figure 17** Average losses for Terranora interconnector (South Pine 275 referred to Sydney West 330)



Terranora interconnector notional link losses versus flow (New South Wales to Queensland)

## 6 Proportioning of inter-regional losses to regions

This section details how the inter-regional losses are proportioned by the National Electricity Market Dispatch Engine (NEMDE).

NEMDE implements inter-regional loss factors by allocating the inter-regional losses to the two regions associated with a notional interconnector.

The proportioning factors are used to allocate the inter-regional losses to two regions by an increment of load at one RRN from the second RRN. The incremental changes to the inter-regional losses in each region are found from changes to interconnector flow and additional generation at the second RRN.

The average proportion of inter-regional losses in each region constitutes a single static loss factor.

The following table provides the factors used to allocate inter-regional losses to the associated regions for the 2022-23 financial year:

**Table 24 Factors for inter-regional losses**

| Notional interconnector                                 | Proportioning factor | Applied to      |
|---|----------------------|-----------------|
| Queensland – New South Wales (QNI)                      | 0.5383               | New South Wales |
| Queensland – New South Wales (Terranora Interconnector) | 0.5868               | New South Wales |
| Victoria – New South Wales                              | 0.2815               | Victoria        |
| Victoria – South Australia (Heywood)                    | 0.7893               | Victoria        |
| Victoria – South Australia (Murraylink)                 | 0.5651               | Victoria        |

## 7 Regions and regional reference nodes

This section describes the NEM regions, the RRN for each region and regional boundaries.

### 7.1 Regions and Regional Reference Nodes

**Table 25 Regions and Regional Reference Nodes**

| Region          | Regional Reference Node     |
|-----------------|-----------------------------|
| Queensland      | South Pine 275kV node       |
| New South Wales | Sydney West 330kV node      |
| Victoria        | Thomastown 66kV node        |
| South Australia | Torrens Island PS 66kV node |
| Tasmania        | George Town 220 kV node     |

### 7.2 Region boundaries

Physical metering points defining the region boundaries are at the following locations.

#### 7.2.1 Between the Queensland and New South Wales regions

- At Dumaresq Substation on the 8L and 8M Dumaresq to Bulli Creek 330kV lines<sup>6</sup>.
- 10.8 km north of Terranora on the two 110kV lines between Terranora and Mudgeeraba (lines 757 & 758). Metering at Mudgeeraba adjusted for that point.

#### 7.2.2 Between the New South Wales and Victoria regions

- At Wodonga Terminal Station (WOTS) on the 060 Wodonga to Jindera 330kV line.
- At Red Cliffs Terminal Station (RCTS) on the Red Cliffs to Buronga 220kV line.
- At Murray Switching Station on the MSS to UTSS 330kV lines.
- At Murray Switching Station on the MSS to LTSS 330kV line.
- At Guthega Switching Station on the Guthega to Jindabyne PS 132kV line.
- At Guthega Switching Station on the Guthega to Geehi Dam Tee 132kV line.

#### 7.2.3 Between the Victoria and South Australia regions

- At South East Switching Station (SESS) on the SESS to Heywood 275kV lines.
- At Monash Switching Station (MSS) on the Berri (Murraylink) converter 132kV line.

<sup>6</sup> The metering at Dumaresq is internally scaled to produce an equivalent flow at the New South Wales/Queensland State borders.

#### **7.2.4 Between the Victoria and Tasmania regions**

Basslink is not a regulated interconnector, it has the following metering points:

- At Loy Yang 500 kV PS.
- At George Town 220 kV Switching Station.

## 8 Virtual transmission nodes

This section describes the configuration of the different virtual transmission nodes (VTNs), that have been advised to AEMO at time of publication.

VTNs are aggregations of transmission nodes for which a single MLF is applied. AEMO has considered the following VTNs which have been approved by the Australian Energy Regulator (AER).

### 8.1 New South Wales virtual transmission nodes

**Table 26 New South Wales virtual transmission nodes**

| VTN TNI code | Description         | Associated transmission connection points (TCPs)   |
|--------------|---------------------|--|
| NEV1         | Far North           | Muswellbrook 132 and Liddell 33  |
| NEV2         | North of Broken Bay | Brandy Hill 11, Charmhaven 11, Gosford 66, Gosford 33, West Gosford 11, Munmorah STS 33, Lake Munmorah 132, Newcastle 132, Ourimbah 132, Ourimbah 66, Ourimbah 33, Somersby 11, Tomago 132, Tuggerah 132, Vales Pt 132, Waratah 132 and Wyong 11   |
| NEV3         | South of Broken Bay | Alexandria 33, Beaconsfield North 132, Beaconsfield South 132, Bunnerong 132, Bunnerong 33, Belmore Park 132, Campbell Street 11, Campbell Street 132, Canterbury 33, Green Square 11, Homebush Bay 11, Hurstville North 11, Haymarket 132, Kurnell 132, Kogarah 11, Lane Cove 132, Meadowbank 11, Marrickville 11, Mason Park 132, Peakhurst 33, Macquarie Park 11, Macquarie Park 33, Potts Hill 11, Rockdale 11, Rookwood Road 132, Rose Bay 11, Strathfield South 11, Sydney East 132, Sydney North 132, St Peters 11, Sydney West 132, Sydney South 132, Top Ryde 11, Waverley 11 |
| AAVT         | ACT                 | Angle Crossing 132, Belconnen 132, City East 132, Civic 132, East Lake 132, Gilmore 132, Gold Creek 132, Latham 132, Telopea Park 132, Theodore 132, Wanniasa 132, Woden 132   |

### 8.2 South Australia virtual transmission nodes

The SJP1 VTN for South Australia includes all South Australian load transmission connection points, excluding:

- Snuggery Industrial, as nearly its entire capacity services an industrial facility at Millicent.
- Whyalla MLF, as its entire capacity services an industrial plant in Whyalla.

### 8.3 Tasmania virtual transmission nodes

**Table 27 Tasmania virtual transmission nodes**

| VTN TNI code | Description         | Associated transmission connection points (TCPs)  |
|--------------|---------------------|---|
| TVN1         | Greater Hobart Area | Chapel Street 11, Creek Road 33, Lindisfarne 33, Mornington 33, North Hobart 11, Risdon 33 and Rokeby 11. |
| TVN2         | Tamar Region        | Hadspen 22, Mowbray 22, Norwood 22, St Leonards 22, Trevallyn 22, George Town 22                          |

# A1. Background to marginal loss factors

This section summarises the method AEMO uses to account for electricity losses in the NEM. It also specifies AEMO's Rules responsibilities related to regions, calculation of MLFs, and calculation of inter-regional loss factor equations.

The NEM uses marginal costs to set electricity prices that need to include pricing of transmission electrical losses.

For electricity transmission, electrical losses are a transport cost that needs to be recovered. A feature of electrical losses is that they also increase with an increase in the electrical power transmitted. That is, the more a transmission line is loaded, the higher the percentage losses. Thus, the price differences between the sending and receiving ends is not determined by the average losses, but by the marginal losses of the last increment of electrical power delivered.

Electrical power in the NEM is traded through the spot market managed by AEMO. The central dispatch process schedules generation to meet demand to maximise the value of trade.

Static MLFs represent intra-regional electrical losses of transporting electricity between a connection point and the RRN. In the dispatch process, generation prices within each region are adjusted by MLFs to determine dispatch of generation.

Dynamic inter-regional loss factor equations calculate losses between regions. Depending on flows between regions, inter-regional losses also adjust the prices in determining generation dispatch to meet demand.

AEMO calculates the Regional Reference Price (RRP) for each region, which is then adjusted by reference to the MLFs between customer connection points and the RRN.

## A1.1 Rules requirements

Clause 2A.1.3 of the Rules requires AEMO to establish, maintain, review and publish by 1 April each year a list of regions, RRNs, and the market connection points (represented by TNIs) in each region.

Rule 3.6 of the Rules requires AEMO to calculate the inter-regional loss factor equations (clause 3.6.1) and intra-regional loss factors (MLFs) (clause 3.6.2) by 1 April each year that will apply for the next financial year.

Clauses 3.6.1, 3.6.2 and 3.6.2A specify the requirements for calculating the inter-regional loss factor equations and MLFs, and the data used in the calculation.

The Rules require AEMO to calculate and publish a single, volume-weighted average, intra-regional MLF for each connection point. The Rules also require AEMO to calculate and publish dual MLFs for connection points where one MLF does not satisfactorily represent transmission network losses for active energy generation and consumption.



## A1.2 Application of marginal loss factors

Under marginal pricing, the spot price for electricity is the incremental cost of additional generation (or demand reduction) for each spot market trading interval.

Consistent with this, the marginal losses are the incremental increase in total losses for each incremental additional unit of electricity. The MLF of a connection point represents the marginal losses to deliver electricity to that connection point from the RRN.

The tables in Section 1 show the MLFs for each region. The price of electricity at a TNI is the price at the RRN multiplied by the MLF. Depending on network and loading configurations MLFs vary, ranging from below 1.0 to above 1.0.

### A1.2.1 Marginal loss factors greater than 1.0

At any instant at a TNI, the marginal value of electricity will equal the cost of generating additional electrical power at the RRN and transmitting it to that point. Any increase or decrease in total losses is then the marginal loss associated with transmitting electricity from the RRN to this TNI. If the marginal loss is positive, less power can be taken from this point than at the RRN, the difference having been lost in the network. In this case, the MLF is above 1.0. This typically applies to loads but would also apply to generation in areas where the local load is greater than the local level of generation.


For example, a generating unit supplying an additional 1 MW at the RRN may find that a customer at a connection point can only receive an additional 0.95 MW. Marginal losses are 0.05 MW, or 5% of generation, resulting in an MLF of 1.05.

#### Marginal loss factors greater than 1.0 – simplified

Figure 18 shows this effect in a simple manner using a scale as an analogy. While this is an oversimplification of the underlying drivers of MLF outcomes, thinking of changes as being driven by localised shifts in load/generation balance can be a helpful way to understand MLF outcomes.

In particular, expanding this thinking to interconnector behaviour where an interconnector exporting can be thought of as ‘load’ and importing as ‘generation’ can help with understanding year-on-year variations in MLF outcomes at connection points in close proximity to interconnectors.

**Figure 18 MLFs greater than 1.0 simplified**



### A1.2.2 Marginal loss factors less than 1.0

Losses increase with distance, so the greater the distance between the RRN and a connection point, the higher the MLF. However additional line flow only raises total losses if it moves in the same direction as existing net flow. At any instant, when additional flow is against net flow, total network losses are reduced. In this case, the MLF is


below 1.0. This typically applies to generation but would also apply to loads in areas where the local generation level is greater than local load.

Using the example above, if net flow is in the direction from the connection point to the RRN, a generating unit at the RRN is only required to supply an additional 0.95 MW to meet an additional load of 1 MW at the connection point. Marginal losses are then -0.05 MW, or 5% reduction in generation, resulting in an MLF of 0.95.

### Marginal loss factors less than 1.0 – simplified

Figure 19 shows this effect in a simple manner using a scale as an analogy. While this is an oversimplification of the underlying drivers of MLF outcomes, thinking of changes as being driven by localised shifts in load/generation balance can be a helpful way to understand MLF outcomes. In particular, expanding this thinking to interconnector behaviour where an interconnector exporting can be thought of as ‘load’ and importing as ‘generation’ can help with understanding year-on-year variations in MLF outcomes at connection points in close proximity to interconnectors.

Figure 19 MLFs less than 1.0 simplified



### A1.2.3 Marginal loss factors impact on National Electricity Market settlements

For settlement purposes, the value of electricity purchased or sold at a connection point is multiplied by the connection point MLF. For example:

**A Market Customer** at a connection point with an MLF of 1.05 purchases \$1,000 of electricity. The MLF of 1.05 multiplies the purchase value to  $1.05 \times 1,000 = \$1,050$ . The higher purchase value covers the cost of the electrical losses in transporting electricity to the Market Customer’s connection point from the RRN.

**A Market Generator** at a connection point with an MLF of 0.95 sells \$1,000 of electricity. The MLF of 0.95 multiplies the sales value to  $0.95 \times 1,000 = \$950$ . The lower sales value covers the cost of the electrical losses in transporting electricity from the Market Generator’s connection point to the RRN.

Therefore, it follows that in the settlements process:

- Higher MLFs tend to advantage, and lower MLFs tend to disadvantage, generation connection points.
- Higher MLFs tend to disadvantage, and lower MLFs tend to advantage, load connection points.

## A2. Methodology, inputs, and assumptions

This section outlines the principles underlying the MLF calculation, the load and generation data inputs AEMO obtains and uses for the calculation, and how AEMO checks the quality of this data. It also explains how networks and interconnectors are modelled in the MLF calculation.

### A2.1 Marginal loss factors calculation methodology

AEMO uses a forward-looking loss factor (FLLF) methodology (Methodology)<sup>7</sup> for calculating MLFs. The Methodology uses the principle of “minimal extrapolation”, the high level steps in this can be summarised as:

- Develop a load flow model of the transmission network that includes committed augmentations for the year that the MLFs will apply.
- Obtain connection point demand forecasts for the year that the MLFs will apply.
- Estimate the dispatch of committed new generating units.
- Adjust the dispatch of new and existing generating units to restore the supply-demand balance in accordance with section 5.5 of the Methodology.
- Calculate the MLFs using the resulting power flows in the transmission network.

### A2.2 Load data requirements for the MLF calculation

The annual energy targets used in load forecasting for the 2022-23 MLF calculation are in the table below.

**Table 28 Operational demand**

| Region          | 2021-22 forecast operational energy (GWh) <sup>A</sup> | 2022-23 forecast operational energy (GWh) <sup>A</sup> |
|-----------------|--|--|
| Queensland      | 50,078   | 47,380   |
| New South Wales | 65,667   | 60,671   |
| Victoria        | 38,724   | 36,902   |
| South Australia | 11,264   | 10,964   |
| Tasmania        | 10,333   | 10,520   |

A. Forecasting operational energy – as sent out energy was sourced from the most recent published Electricity Statement of Opportunities (for 2022-23), available at: <http://www.aemo.com.au/Electricity/National-Electricity-Market-NEM/Planning-and-forecasting/NEM-Electricity-Statement-of-Opportunities>.

<sup>7</sup> Forward Looking Transmission Loss Factors (Version 8), at [https://aemo.com.au/-/media/files/electricity/nem/security\\_and\\_reliability/loss\\_factors\\_and\\_regional\\_boundaries/forward-looking-loss-factor-methodology.pdf?la=en](https://aemo.com.au/-/media/files/electricity/nem/security_and_reliability/loss_factors_and_regional_boundaries/forward-looking-loss-factor-methodology.pdf?la=en).



### A2.2.1 Historical data accuracy and due diligence of the forecast data

AEMO regularly verifies the accuracy of historical connection point data. AEMO calculates the losses using this historical data, by adding the summated generation values to the interconnector flow and subtracting the summated load values. These transmission losses are used to verify that no large errors occur in the data.

AEMO also performs due diligence checks of connection point load traces to ensure that:

- The demand forecast is consistent with the latest Electricity Statement of Opportunities (ESOO).
- Load profiles are reasonable, and the drivers for load profiles that have changed from the historical data are identifiable.
- The forecast for connection points is inclusive of any relevant embedded generators, where the embedded generators are not considered as part of operational demand<sup>8</sup>.
- Industrial and auxiliary type loads are not scaled with residential drivers.

## A2.3 Generation data requirements for the MLF calculation

AEMO obtains historical real power (MW) and reactive power (MVar) data for each trading interval (half-hour) covering every generation connection point in the NEM from 1 July 2020 to 30 June 2021 from its settlements database.

AEMO also obtains the following data:

- Generation capacity data from AEMO's Generation Information Page published on its website as at 21 February 2022.
- Historical generation availability, as well as on-line and off-line status data from AEMO's Market Management System (MMS).
- Future generation availability based on most recent medium term projected assessment of system adequacy (MT PASA) data, as of 1 January 2022, as a trigger for initiating discussions with participants with the potential to use an adjusted generation profile for the loss factor calculation.

### A2.3.1 New generation


The new generation included is taken from the Generation Information Page as published on 21 February 2022. Projects listed as committed (Committed/Committed\*) and with a target commercial operation date that implies generation in the target year are included. These generating systems are incorporated into the network model and forecast generation profiles are created.

For new solar and wind projects, AEMO created half-hourly profiles based on nameplate capacity and the Full Commercial Use Date indicated on the Generation Information Page, using the reference year 2020-21 weather data. Default hold point schedules were applied to these profiles prior to their full commercial operating date. Historical data from the previous financial year was incorporated into the profile if available. Relevant proponents for each project were consulted during the process.

<sup>8</sup> Demand Terms in EMMS Data Model, at <https://www.aemo.com.au/energy-systems/electricity/national-electricity-market-nem/system-operations/dispatch-information/policy-and-process-documentation#demandterms>.

Economic curtailment was factored into the solar and wind forecast generation profiles to align them with historical generation data. AEMO calculated the time of day average curtailment by region for the reference year 2020-21. Forecast generation profiles were reduced by the time of day percentage of curtailment for the appropriate region.

**Figure 20 Time of day average economic curtailment for 2022-23**



For new thermal generation, the relevant proponents were requested to provide forecasts. For new storage projects, the relevant proponents were requested to provide forecasts; where forecasts were not provided, the data utilised has been based on historical data.

The following committed generation was included in the modelling, but AEMO does not publish MLFs for connections that are not yet registered:

### Queensland new generation

- Dulacca Wind Farm
- Columboola Solar Farm
- Kaban Green Power Hub Wind Farm
- Moura Solar Farm
- Woolooga Solar Farm

### New South Wales and Australian Capital Territory new generation

- New England Solar Farm
- Riverina Solar Farm
- Rye Park Wind Farm
- Wyalong Solar Farm

## Victoria new generation

- None

## South Australia new generation

- Port Augusta Renewable Energy Park - Solar
- Mannum Adelaide Pumping Station 3 Solar Farm

## Tasmania new generation

- None

### A2.3.2 Registered unit forecasts

AEMO created half-hourly profiles for registered solar and wind projects that did not operate at full capacity for the entire reference year or where historical generation data does not represent generation in the target year (i.e. due to unit specific constraints). Forecast generation profiles for registered units are modelled using the reference year 2020-21 weather data and the registered maximum capacity for the project. Historical data from the reference year was incorporated into the profile where available.

Relevant proponents for each project were consulted during the process to provide feedback or propose their own generation profile. Where applicable, adjustments based on the feedback received were made or the proponent modelled profiles were implemented where deemed appropriate.

For registered thermal and storage projects where not operational at full capacity for the entire reference year, relevant proponents were requested to provide forecasts. Where forecasts were not provided, the data utilised has been based on historical data.

### A2.3.3 Abnormal generation patterns

AEMO replaced a number of historical generation profiles with adjusted profiles as an input to the 2022-23 MLF calculation process.

In accordance with section 5.5.7 of the Methodology, AEMO used adjusted generation profiles based on verifiable information, where it was satisfied that the reference year profile was clearly unrepresentative of the expected generation for 2021-22. Historical generation patterns were adjusted to backfill historical outages and incorporate future outages identified through MT PASA data submitted as of 1 January 2022. This was performed where outages longer than 30 days have been identified, and only if deemed practicable. For example, highly variable sources of generation such as 'peakers' would not be backfilled due to the inconsistent nature of the generation.

## A2.4 Intra-regional limit management

When performing MLF calculations, AEMO has identified several high impact system normal intra-regional limits that are likely to have a material impact on MLFs for the target year. To minimise deviations between the MLF calculations and actual market outcomes, AEMO incorporated these limits by reducing local generation levels to ensure the limits are not exceeded.

Constraints were incorporated into the 2022-23 MLF study using the approaches discussed below.

## Limiting total output from relevant generators

When the total output of set of generators are defined as a limit, the input profiles are reduced on a pro-rata basis (in line with FLLF supply/demand balance theory) to adhere to the limit. The constrained generation profiles are then utilised in the initial FLLF study to obtain results reflective of these limits. The following limits were applied in this way:

- North-west Victoria voltage collapse limit (simplified to reflect previously invoked  $V^V\_NIL\_ARWBBA$ ).

## Thermal/transfer limit

When a thermal or transfer limit on a line or cutset is defined, this limit was first assessed using an unconstrained study with the relevant line flows being observed. The input profiles of renewable generators are then locationally grouped and reduced on a pro-rata basis (in line with FLLF supply/demand balance theory). The constrained generation profiles are then utilised in a second FLLF study to obtain results reflective of the impact of these limits. The following limits were applied in this way:

- Balranald to Darlington Point voltage collapse limit ( $N^{NN\_NIL\_3}$ ).
- Darlington Point to Wagga Wagga voltage collapse limit ( $N::N\_NIL\_63$ , previously  $N^{NN\_NIL\_2}$ ).
- Waubra to Ballarat transfer limit ( $V>>V\_NIL\_9$ ).
- Murray to Dederang transfer limit ( $V>>V\_NIL\_1A$  and  $V>>V\_NIL\_1B$ ).

AEMO continuously monitors and assesses the impact of other system normal limits. The following lists the limits which have been considered but **not** modelled for the 2022-23 MLFs:

- Queensland Central to South transfer limit ( $Q^N\_NIL\_CS$ ).
- Queensland North system strength limit<sup>9</sup>.
- South Australia system strength limit<sup>10</sup>.
- Victoria system strength limit.

## A2.5 Network representation in the marginal loss factors calculation

An actual network configuration recorded by AEMO's Energy Management System (EMS) is used to prepare the NEM interconnected power system load flow model for the MLF calculation. This recording is referred to as a 'snapshot'. AEMO reviews the snapshot and modifies it where necessary to represent all normally connected equipment. AEMO also checks switching arrangements for the Victorian Latrobe Valley's 220 kilovolt (kV) and 500 kV networks to ensure they reflect normal operating conditions.

AEMO adds relevant network augmentations that are scheduled to occur in 2022-23. The snapshot is thus representative of the anticipated normally operating power system in 2022-23.

<sup>9</sup> Based on limit advice available from [https://aemo.com.au/-/media/files/electricity/nem/security\\_and\\_reliability/congestion-information/nqld-system-strength-constraints.pdf?la=en](https://aemo.com.au/-/media/files/electricity/nem/security_and_reliability/congestion-information/nqld-system-strength-constraints.pdf?la=en).

<sup>10</sup> The commissioning of 4 Synchronous Condensers in SA from April 2021 onwards will potentially increase the level of non-synchronous generation for 2021-22, however AEMO is unable to quantify the impact compared to historical generation using currently available information.



### A2.5.1 Network augmentation for 2022-23

Relevant Transmission Network Service Providers (TNSPs) advised of the following network augmentations to be completed in 2022-23.

#### Queensland network augmentations

Powerlink provided the following list of planned network augmentations in 2022-23 in Queensland:

- Rebuilding CP.01710 Gin Gin substation:
  - Establish tee between 813/815 and T2
  - re-establish a bus at Gin Gin
- Replacement of CP.02339 Kemmis Transformer 2:
  - updated line parameters for transformer 2 based on Powerlink advice
- Decommissioning of OR.02253 Belmont 3T:
  - updated Belmont transformers based on Powerlink advice
- Replacement of CP.02371 H010 Bouldercombe - Transformer 1 and 2
  - updated two existing transformers data based on Powerlink advice
- Restore FNQ original configuration (Line impedance update)
- Replacement of H035 Strathmore/Kumbarilla Park (Transformer replacement)

#### New South Wales network augmentations

New South Wales NSPs provided the following list of planned network augmentations in 2022-23 in New South Wales:

- New Macquarie 132/33kV sub-transmission substation (connection to 92A and 92B)
- Replacement of 132kV feeder 265 between Bunnorrong STS and Maroubra ZS with a spare duct
- Bango Wind Farm line parameters update - 132kV lines 973 and 999
- Collector Wind Farm line parameters update – 330kV Collector to Marulan
- Gunnedah East (for Gunnedah Solar Farm) Line parameters update – 132kV tee connected to 9U3 Gunnedah to Boggabri East
- Tallawarra "B" Open Cycle Gas Turbine (deletion of four 132kV Series Reactors at Dapto) (Endeavour Energy)
- Sydney East transformer changes –
  - Decommissioning of Sydney East transformer #1
  - Updated the parameters in Sydney East transformer #2

#### Victoria network augmentations

AEMO's Victorian Planning Group provided the following list of planned network augmentations in 2022-23 in Victoria:



- Fishermans Bend FBTS B2 transformer updates
- Minor VIC to NSW Upgrade:
  - Added SMTS second transformer
  - Updated SMTS-DDTS 330kV lines ratings

### South Australia network augmentations

ElectraNet provided the following list of planned network augmentations in 2022-23 in South Australia:

- Replacement of Leigh Creek South transformer
- Eyre Peninsula Transmission Supply
  - Updated line configuration and impedances

### Tasmania network augmentations

TasNetworks provided the following list of planned network augmentations in 2022-23 in Tasmania:

- De Port Latta Substation
  - 110/22 kV Supply transformer replacement

## A2.5.2 Treatment of Basslink interconnector

Basslink consists of a controllable network element that transfers power between Tasmania and Victoria.

In accordance with sections 5.3.1 and 5.3.2 of the Methodology, AEMO calculates the Basslink connection point MLFs using historical data, adjusted to reflect any change in forecast generation in Tasmania.

## A2.5.3 Treatment of Terranora interconnector

The Terranora interconnector is a regulated interconnector.

The boundary between Queensland and New South Wales between Terranora and Mudgeeraba is north of Directlink. The Terranora interconnector is in series with Directlink and, in the MLF calculation, AEMO manages the Terranora interconnector limit by varying the Directlink limit when necessary.

For the 2022-23 MLFs, the relationship between Terranora and QNI has been derived from historical system normal (excludes data where limits applied that were related to network outages) observations from the 2020-21.

As Directlink resides entirely within NSW, considerations were made for load between Directlink and Terranora to ensure that the intended relationship between QNI and Terranora was achieved.

## A2.5.4 Treatment of the Murraylink interconnector

The Murraylink interconnector is a regulated interconnector.

In accordance with section 5.3 of the Methodology, AEMO treats the Murraylink interconnector as a controllable network element in parallel with the regulated Heywood interconnector.

For the 2022-23 MLFs, the relationship between Murraylink and Heywood has been derived from historical system normal (excludes data where limits applied that were related to network outages) observations from the 2020-21.

## A2.5.5 Treatment of Yallourn unit 1

Yallourn Power Station Unit 1 can be connected to either the 220 kV or 500 kV network in Victoria.

AEMO modelled Yallourn Unit 1 at the two connection points (one at 220 kV and the other one at 500 kV) and calculated loss factors for each connection point. AEMO then calculated a single volume-weighted loss factor for Yallourn Unit 1 based on the individual loss factors at 220 kV and at 500 kV, and the output of the unit.

## A2.6 Interconnector capacity

In accordance with section 5.5.4 of the Methodology, AEMO estimates nominal interconnector limits for summer peak, summer off-peak, winter peak, and winter off-peak periods. These values are in the table below. AEMO also sought feedback from the relevant TNSPs as to whether there were any additional factors that might influence these limits.

**Table 29 Inter-regional limits**

| From region                  | To region                        | Summer day (MW) <sup>A</sup>           | Summer night (MW) <sup>A</sup>         | Winter day (MW) <sup>A</sup>           | Winter night (MW) <sup>A</sup>         |
|------------------------------|----------------------------------|--|--|--|--|
| Queensland                   | NSW <sup>B</sup>                 | 1,278                                  | 1,278                                  | 1,278                                  | 1,278                                  |
| NSW                          | Queensland <sup>B</sup>          | 600                                    | 750                                    | 600                                    | 750                                    |
| NSW                          | Victoria                         | 1,700                                  | 1,700                                  | 1,700                                  | 1,700                                  |
| Victoria                     | NSW <sup>C</sup>                 | 1,670                                  | 1,670                                  | 1,670                                  | 1,670                                  |
| Victoria                     | South Australia                  | 650                                    | 650                                    | 650                                    | 650                                    |
| South Australia              | Victoria                         | 420 <sup>D</sup> /550                  | 420 <sup>D</sup> /550                  | 420 <sup>D</sup> /550                  | 420 <sup>D</sup> /550                  |
| Victoria (Murraylink)        | South Australia (Murraylink)     | 220                                    | 220                                    | 220                                    | 220                                    |
| South Australia (Murraylink) | Victoria (Murraylink)            | 188 minus Northwest Bend & Berri loads | 198 minus Northwest Bend & Berri loads | 215 minus Northwest Bend & Berri loads | 215 minus Northwest Bend & Berri loads |
| Queensland (Terranora)       | NSW (Terranora)                  | 224                                    | 224                                    | 224                                    | 224                                    |
| NSW (Terranora)              | Queensland (Terranora)           | 107                                    | 107                                    | 107                                    | 107                                    |
| Tasmania (Basslink)          | Victoria (Basslink) <sup>E</sup> | 594                                    | 594                                    | 594                                    | 594                                    |
| Victoria (Basslink)          | Tasmania (Basslink) <sup>E</sup> | 478                                    | 478                                    | 478                                    | 478                                    |

A. The peak interconnector capability does not necessarily correspond to the network capability at the time of the maximum regional demand; it refers to average capability during daytime, which corresponds to 6.00 am to 6.00 pm (AEST) in MLF studies.

B. The “QNI minor” upgrade is modelled with an additional headroom of 200MW in both directions.

C. The “VNI minor” upgrade is modelled with an additional headroom of 170MW in the Victoria to New South Wales direction.

D. Para 275kV substation SVC outage limiting flows on Heywood from SA to VIC, reduced capacity applies until 04/01/2023 as per Network Outage Schedule at <https://aemo.com.au/en/energy-systems/electricity/national-electricity-market-nem/data-nem/network-data/network-outage-schedule>.

E. Limit referring to the receiving end.

## A2.7 Calculation of MLFs

AEMO uses the TPRICE<sup>11</sup> software to calculate MLFs using the following method:

<sup>11</sup> TPRICE is a transmission pricing software package. It is capable of running a large number of consecutive load flow cases quickly. The program outputs loss factors for each trading interval as well as averaged over a financial year using volume weighting.

- Convert the half-hourly forecast load and historical generation data, generating unit capacity and availability data together with interconnector data into a format suitable for input to TPRICE.
- Adjust the load flow case to ensure a reasonable voltage profile in each region at times of high demand.
- Convert the load flow case into a format suitable for use in TPRICE.
- Feed into TPRICE, one trading interval at a time, the half-hourly generation and load data for each connection point, generating unit capacity and availability data, with interconnector data. TPRICE allocates the load and generation values to the appropriate connection points in the load flow case.
- TPRICE iteratively dispatches generation to meet forecast demand and solves each half-hourly load flow case subject to the rules in section 5.5.2 of the Methodology, and calculates the loss factors appropriate to the load flow conditions.
- Refer the loss factors at each connection point in each region are referred to the RRN.
- Average the loss factors for each trading interval and for each connection point using volume weighting.

In accordance with section 5.6.1 of the Methodology, AEMO calculates dual MLF values at connection points where one MLF does not satisfactorily represent active power generation and consumption.

#### A2.7.1 MLF calculation quality control

As with previous years, AEMO has engaged consultants to review the quality and accuracy of the MLF calculation. The consultants will perform the following work:

- An independent verification of AEMO's data inputs to the MLF calculation.
- A verification study using AEMO's input data to independently validate AEMO's calculation results. AEMO will utilise the verification study to ensure that AEMO's MLF calculation methods and results are accurate.

## A3. Impact of technology on MLF outcomes

As discussed in Appendix A2, MLFs are calculated by simulating power flows on the network for every half-hour, in the next financial year, using forecast supply and demand values. The calculated raw loss factors for each half-hour are then weighted by the volume of energy at the TNI to calculate the MLF for that TNI.

Calculated raw MLFs reflect the supply and demand at each half-hour and, as with supply and demand outcomes, can drastically vary. In remote locations with material levels of grid connected PV capacity an increasingly stronger diurnal pattern in half-hourly MLFs is observed due to increased supply and low demand (driven by rooftop PV) during daylight hours. The combination of increased generation and reduced local demand results in the energy produced needing to travel longer distances to supply load resulting in increased losses over the transmission network and lower MLF outcomes for these generators.

While this diurnal volatility in underlying half-hourly MLFs does result in poor outcomes for grid connected PV, it can present potential opportunities for storage technologies which may be able to achieve a delta between load and generation MLFs that will compliment arbitrage behaviour.


As a hypothetical example, Figure 21 shows the time-of-day average raw MLFs and generation (% of capacity) for several technologies, all connected to the same location within the shared transmission network.

Table 30 shows the MLF outcomes for the different technologies shown in Figure 21. As can be seen, despite all having the same underlying raw half-hourly MLFs the outcomes vary drastically.

- Solar Farm
  - The solar farm is generating into the middle of the day, when the underlying half-hourly MLFs are low which is reflective of generation at this location needing to travel long distances to serve load during these times. The result is the second lowest MLF outcome, given the lowest MLF outcome is the battery load the solar farm MLF outcome is the least favourable.
- Wind Farm
  - The wind farm weighting tends toward the evening peak, when the underlying half-hourly MLFs are high which is reflective of generation at this location not needing to travel long distances to serve load during these times. The result is the highest MLF outcome of all technologies, which is favourable.
- Battery – Generation
  - The battery is generating into both morning and evening peaks, when the underlying half hourly MLFs are above average which reflective of generation at this location not needing to travel long distances to serve load during these times. The result is the second highest MLF outcome of all technologies, which is favourable.
- Battery – Load
  - The battery is loading into the middle of the day, when the underlying half-hourly MLFs are low which is reflective of generation at this location needing to travel long distances to serve load during these times. As

the battery is increasing local load, this decreases the volume of energy that is required to travel long distances to serve load. The result is the lowest outcome of all technologies, which is favourable.

**Figure 21 Time-of-day impact of technology on MLF outcomes**



**Table 30 Impact of technology on MLF outcomes**

| Technology           | Indicative MLF |
|----------------------|----------------|
| Solar farm           | 0.7657         |
| Wind farm            | 0.8364         |
| Battery (generation) | 0.8130         |
| Battery (load)       | 0.7431         |

# Glossary

| Term               | Definition  |
|--------------------|---|
| <b>AC</b>          | Alternating current                               |
| <b>ACT</b>         | Australian Capital Territory                      |
| <b>AEMO</b>        | Australian Energy Market Operator                 |
| <b>AER</b>         | Australian Energy Regulator                       |
| <b>DC</b>          | Direct current                                    |
| <b>ESOO</b>        | Electricity Statement Of Opportunities            |
| <b>FLLF</b>        | Forward Looking Loss Factor                       |
| <b>GWh</b>         | Gigawatt-hour                                     |
| <b>km</b>          | Kilometre   |
| <b>kV</b>          | Kilovolt  |
| <b>LNG</b>         | Liquefied natural gas                             |
| <b>MLF</b>         | Marginal Loss Factor (intra-regional loss factor) |
| <b>Methodology</b> | Forward-looking Loss Factor Methodology           |
| <b>MNSP</b>        | Market Network Service Provider                   |
| <b>MVAr</b>        | Megavolt-ampere-reactive                          |
| <b>MW</b>          | Megawatt  |
| <b>NEFR</b>        | National Energy Forecasting Report                |
| <b>NEM</b>         | National Electricity Market                       |
| <b>NEMDE</b>       | National Electricity Market Dispatch Engine       |
| <b>NSP</b>         | Network Service Provider                          |
| <b>NSW</b>         | New South Wales                                   |
| <b>PS</b>          | Power station                                     |
| <b>RRN</b>         | Regional Reference Node                           |
| <b>Rules</b>       | National Electricity Rules                        |
| <b>TNI</b>         | Transmission Node Identity                        |
| <b>TNSP</b>        | Transmission Network Service Provider             |
| <b>VTN</b>         | Virtual Transmission Node                         |