



INITIAL CONSULTATION – PARTICIPANT RESPONSE PACK

METROLOGY PROCEDURE:

Part A National Electricity Market Version 5.30

Part B: Metering Data Validation, Substitution and
Estimation Procedure for Metering Types 1 – 7 Version
5.30

Participant: Origin Energy

Completion Date: 24 October 2014

Table of Contents

- 1. PROPOSED CHANGES3
 - A. PROPOSED CHANGES TO METROLOGY PROCEDURE: PART A3
 - B. PROPOSED CHANGES TO METROLOGY PROCEDURE: PART B4
- 2. **OTHER ISSUES RELATED TO CONSULTATION SUBJECT MATTER.....8**
 - A. OTHER CONSULTATION RELATED ISSUES – METROLOGY PROCEDURE: PART A8
 - B. OTHER CONSULTATION RELATED ISSUES – METROLOGY PROCEDURE: PART B9

1. Proposed Changes

This section lists the changes proposed by participants or by AEMO since the last completed consultation of the *Metrology Procedure*.

- Section 1A covers the proposed changes for the *Metrology Procedure: Part A Version 5.30*
- Section 1B covers the proposed changes for the *Metrology Procedure: Part B Version 5.30*

NOTE: All proposed additions to the Metrology Procedures are highlighted in red colour text and are underlined. All proposed deletions from the Metrology Procedures are highlighted in red strike through text. Example: ~~Reference~~.

Please include your comments in the 'Participant Comment' column below.

A. Proposed Changes to Metrology Procedure: Part A

Item	Description	Comments
1	PROPOSED/ REQUESTED CHANGES	
1.1	Align version numbering Align version number of Metrology Procedure: Part A with that for Part B to Version 5.30.	Agree
1.2	Clause 2.4.26 Correct clause reference to 2.2.24, i.e. change 2.4.23 to 2.4.24.	Agree
1.3	3.3.3(d) Italicise <i>calculated metering data</i> .	Agree
1.4	Clause 3.9.4 Correct clause reference to 3.9.1, i.e. change 3.10.1 to 3.9.1.	Agree
1.5	Effective Date of the Metrology Procedure: Part A The proposed effective date of the Metrology Procedure: Part A is 24 April 2015.	Agree

B. Proposed Changes to Metrology Procedure: Part B

Item	Description	Comments
1	PROPOSED/ REQUESTED CHANGES	
1.1	Type 65 Substitution Table 1.8 Change “Type 65 EST” to “Type 65 SUB or EST”.	Agree
1.2	Type 65 Substitution Clause 4.2.7 The <i>Metering Data Provider</i> may use type 65 substitution or forward <i>estimation</i> type 65 only when the <i>metering data</i> from the same, or similar, <i>meter</i> reading period last year or the <i>metering data</i> from the previous <i>meter</i> reading period is not available (i.e. when type 61 and type 62 substitution or forward <i>estimation</i> methods cannot be used).	Agree
1.3	Type 65 Substitution 4.2.9(a) Substitutions may be type 61, 62, 63, 64, 65 , 66, 67 or 68.	Agree
1.4	Type 65 Substitution and replace “meter reading” with “energy consumption” 4.3.5 Type 65 – Forward Estimation by ADL Method The <i>Metering Data Provider</i> must provide a substitution or forward <i>estimation</i> of the meter reading energy consumption in accordance with the following formula: Meter Reading Energy Consumption = Average Daily Load * number of days required.	Origin suggests the following wording below. This provides clarity that the meter reading for MDFF is accurately reflected as per the derived consumption calculation. It is the meter reading that is used to calculate Settlement or Billing and provided on customer bills (i.e. new meter reading = previous meter reading + estimated energy consumption) The <i>Metering Data Provider</i> must provide a substitution or forward <i>estimation</i> of the meter reading

Item	Description	Comments
		by calculating the <i>energy consumption</i> in accordance with the following formula:
1.5	<p>Replace “meter reading” with “energy consumption” 4.3.1</p> <p>Type 61 - Previous Year Method (Average Daily Consumption method)</p> <p>The <i>Metering Data Provider</i> must provide a <i>substitution</i> or forward estimation of the meter reading <i>energy consumption</i> as per the following formula:</p> <p style="text-align: center;">Meter Reading Energy Consumption = ADC_{LY} * number of days required</p> <p style="text-align: center;">where</p> <p>ADC_{LY} = average daily consumption from the same or similar <i>meter</i> reading period last year.</p>	The <i>Metering Data Provider</i> must provide a <i>substitution</i> or forward estimation of the meter reading by calculating the <i>energy consumption</i> in accordance with the following formula:
1.6	<p>Replace “meter reading” with “energy consumption” 4.3.2</p> <p>Type 62 - Previous Meter Reading Method (Average Daily Consumption Method)</p> <p>The <i>Metering Data Provider</i> must provide a <i>substitution</i> or forward estimation of the meter reading <i>energy consumption</i> as per the following formula:</p> <p style="text-align: center;">Meter Reading Energy Consumption = ADC_{PP} * number of days required.</p> <p style="text-align: center;">where</p> <p>ADC_{PP} = average daily consumption from the previous <i>meter</i> reading period.</p>	The <i>Metering Data Provider</i> must provide a <i>substitution</i> or forward estimation of the meter reading by calculating the <i>energy consumption</i> in accordance with the following formula:
1.7	<p>Replace “meter reading” with “energy consumption” 4.3.3</p>	The <i>Metering Data Provider</i> must provide a <i>substitution</i> or forward

Item	Description	Comments
	<p>Type 63 Customer Class Method</p> <p>The <i>Metering Data Provider</i> must provide a <i>substitution</i> or forward <i>estimation</i> of the meter reading <i>energy consumption</i> as per the following formula:</p> <p style="text-align: center;">Meter Reading Energy Consumption = ADC_{cc} * number of days required</p> <p style="text-align: center;">where</p> <p>ADC_{cc} = average daily consumption for this customer class with the same type of usage.</p>	<p><i>estimation</i> of the meter reading <i>by calculating the energy consumption</i> in accordance with the following formula:</p>
1.8	<p>Correction 14.3.3(a)(v) – change “shall” to “must” to be consistent with 14.4.3(a)(iii). If a device is shared with another <i>NMI</i>, the proportion of <i>load</i> that is agreed by affected <i>Registered Participants</i> to be attributable to that <i>NMI</i> (k). Each k factor will be less than 1. The sum of the k factors for a shared device across each respective <i>NMI</i> shall must be equal to 1,</p>	Agree
1.9	<p>Correction 14.3.3(b) – clarify apportioning of shared devices. Each device in the <i>inventory table</i> is a unique combination of physical hardware, time control classification and shared portion, for example, if a device is shared with another <i>NMI</i>, the individual portion(s) of the device(s) must be included in the <i>inventory table</i> as a separate device type.</p>	Agree
1.10	<p>Correction 14.3.5(b) – use <i>Rules</i> defined term <i>Eastern Standard Time</i>. The <i>responsible person</i> must ensure that the appropriate sunset times and sunrise times are obtained from the Australian Government Geoscience website (www.ga.gov.au/geodesy/astro/sunrise.jsp), based on the longitude and latitude of the relevant town as specified below, and Australian Eastern Time Eastern Standard Time:</p>	Agree
1.11	Correction	

Item	Description	Comments
	14.3.5(b) – change “SP AusNet” to “AusNet Services” in latitude/longitude table to reflect entity name change.	
1.12	<p>Correction 14.3.4(b) – clarify apportioning of shared devices Each device in the <i>inventory table</i> is a unique combination of physical hardware, time control classification and shared portion, for example, if a device is shared with another <i>NMI</i>, the individual portion(s) of the device(s) must be included in the <i>inventory table</i> as a separate device type.</p>	Agree
1.13	<p>Insert new section 14.6 – Traffic signal dimming New section 14.6 added to Metrology Procedure: Part B facilitate the calculation of metering data for traffic signals operating in dimmed mode – refer to change marked version of Metrology procedure: Part B included with consultation document package.</p>	Agree
1.14	<p>Effective Date of the Metrology Procedure: Part B The proposed effective date of the Metrology Procedure: Part B is 24 April 2015.</p> <p>Effective Date for Clause 14.6: Proposed effective date for new clause 14.6 is 1 July 2015.</p>	Agree

2. Other Issues Related to Consultation Subject Matter

This section lists the changes proposed by respondents that are related to the subject matter of the consultation.

A. Other Consultation Related Issues – Metrology Procedure: Part A

Clause	Issue/Comment	Proposed Text	Rating (H/M/L)	AEMO Comments

B. Other Consultation Related Issues – Metrology Procedure: Part B

Clause	Issue/Comment	Proposed Text	Rating (H/M/L)	AEMO Comments